

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

ph: 910-893-7550

fax: 910-893-9429

Ankit Patel  
2100 Weaver Forest Way  
Morrisville, NC 27560

Champs Fresh Food  
8909 US-401  
Fuquay-Varina, NC 27526

Re: BCOM2311-0004

Dear Mr. Patel,

The plans and specifications for the above referenced facility have been reviewed and approved. The revised site plan received on June 25<sup>th</sup> with the addition of the two door freezer, along with additional changes from the original site plan submitted to Central Permitting, is approved. This revised site plan must be submitted to Central Permitting, reviewed and approved by Building and Fire.

The approval for this facility is granted with the following conditions:

1-All meat must arrive ready to cook. The one compartment food prep sink shall be designated for the preparation of vegetables only.

2-The half wall located between the food prep sink and dishsink is not necessary. A splashguard will suffice as a barrier to separate the two areas.

3-Area on plan labeled STORAGE must have adequate storage space dedicated for the food, single service items, and all other supplies for the food service operation.

4- Finishes shall be smooth, non-absorbent and easily cleanable. Floors, walls and ceilings shall meet requirements as set forth in 6-101.11 and 6-201.11 NC Food Code.

5-Lighting shall meet minimum requirements as set forth in 6-202.11 Light Bulbs, Protective Shielding and 6-303.11 Intensity of the NC Food Code.

6-Hot water demands shall meet 5-103.11 and 5-103.12 of the NC Food Code. Refer to the hot water calculation sheet.

7-Any changes to equipment, site plan, menu and food process sheets must be approved by the Health Department.

8-A preoperational inspection shall be conducted to verify that the food establishment is constructed and equipped in accordance with the approved plans and any approved modifications of those plans. 8-203.10 Preoperational Inspections.

9- This review does not cover any aspects of construction regulated by other jurisdictions.

This establishment must comply with the requirements of the 2017 NC Food Code and 15A NCAC 18A .2600 "Rules Governing the Food Protection and Sanitation of Food Establishments". These documents are available at [FDA Food Code 2017.pdf \(ncdhhs.gov\)](#) [Sanitation-of-FoodEstablishments-15ANCAC18A-2600.pdf \(ncdhhs.gov\)](#).

Please contact Environmental Health at (910) 893-7547 if you have questions or concerns.

Thank you,

A handwritten signature in black ink that reads "Jamie Turlington, REHS". The signature is written in a cursive style.

Jamie Turlington, REHS  
Harnett County Environmental Health  
Harnett County Health Dept.