

October 13, 2025

Ankit Patel
2100 Weaver Forest Way
Morrisville, NC 27560

Champs Fresh Food
8909 US-401
Fuquay-Varina, NC 27526

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550
fax: 910-893-9429

Re: BCOM2311-0004 (revision submitted 10-2-25)

Dear Mr. Patel,


The resubmitted plans, specifications and application resubmitted to Central Permitting on 10-2-25, are approved with the following conditions:

1. Splashguards shall be integral to handsinks or positioned at prep sinks and dish sink to be effective and adequately sized to eliminate contamination to food and utensils.
2. Finishes shall be smooth, non-absorbent, and easily cleanable. Floors, walls, and ceilings shall meet requirements as set forth in the NC Food Code 6-101.11 and 6-201.11.
3. Lighting shall meet minimum requirements as set forth in NC Food Code 6-202.11 Light Bulbs, Protective Sheilding and 6-303.11 Intensity.
4. Hot water demands shall meet 5-103.11 and 5-103.12 of the NC Food Code.
5. All equipment, including cabinetry and counters must comply with 4-205.10 of the NC Food Code and be installed as specified in 4-402.11 and 4-402.12. All food on display or otherwise exposed to the public will be protected by shields, dispensers or packaging.
6. Any changes to equipment, site plan, menu and food processes shall be approved by the Health Department.

This establishment must comply with the requirements of the 2017 NC Food Code and 15A NCAC 18A .2600 "Rules Governing the Food Protection and Sanitation of Food Establishments". This review does not cover any aspects of construction regulated by other jurisdictions.

Please direct any questions to jturlington@harnett.org or Harnett County Environmental Health at (910) 893-7547.

Sincerely,



Jamie Turlington, REHS
Harnett County Environmental Health
Harnett County Health Dept.