

- KEYED NOTES: #
1. DEMO EXISTING NOTIFICATION APPLIANCES ON EXISTING NACS 2 & 3. INSTALL NEW CIRCUIT WIRING AS SHOWN TO CONNECT THE NEW NOTIFICATION APPLIANCES TO THE EXISTING REMOTE POWER SUPPLY.
 2. RELOCATE THE EXISTING REMOTE TEST STATION TO THE NEW LAY-IN CEILING UNDER THE DUCT DETECTOR (TYPICAL).



1 2ND FLOOR FIRE ALARM PLAN
FA-2 Scale: 1/8"=1'-0"

NO.	DATE	REVISION	BY

PATTERSON
GROUP SERVICES
POWERED BY API GROUP
1824 DOUGLAS DRIVE
SANFORD, NC 27330
(919) 776-2403
NC LICENSE # 30023-SP-FALLY

FIRE ALARM SYSTEM ALTERATIONS FOR:
CFVH HARNETT MOB -
1ST & 2ND FLOOR FIT-UP
225 BRIGHTWATER DRIVE
LILLINGTON, NC 27546

2ND FLOOR
FIRE ALARM PLAN

DATE:	02/26/2024
DRAWN BY:	JRC
CHECKED BY:	CP
SCALE:	1/8"=1'-0"

SHEET:
FA-3
SHEET 3 OF 4

NOTIFIER Standby Battery Calculation NFS-320 Fire Alarm Control Panel					
Protected Premises: CFVH - Harnett MOB 1st & 2nd Floor Fit-Up Date: 2/26/2024					
Address: 225 Brightwater Drive					
City: Lillington State: NC Zip: 27546					
Panel ID: FACP Location: Main Elec. 107					
System Device	Qty	Standby Current Draw	Alarm Current Draw	Draw	Alarm
CRUI-120 Main Board	1	0.250000	0.250000	0.250000	0.250000
#NACS In Use	1	0.030000	0.030000	0.030000	0.030000
KZM-R2 Display (Backlight on)	1	0.100000	0.100000	0.100000	0.100000
LCCD-80 LCD Remote Annunciator	1	0.045000	0.045000	0.045000	0.045000
HW-AV-LTE Communicator	1	0.060000	0.060000	0.060000	0.060000
FSP-951 Photoelectric Detector	17	0.002000	0.003400	0.004000	0.007000
FST-851R Thermal Detector-135 W/ ROR	2	0.002000	0.004400	0.004000	0.006000
NEQ-123 Manual Pull Station	14	0.002000	0.002500	0.002000	0.007000
DNR Duct Detector w/FSP-951R	10	0.002000	0.002000	0.004000	0.004000
RTS155KEY	10	0.000000	0.000000	0.012000	0.020000
FMM-1 Monitor Module	15	0.000375	0.005625	0.005000	0.075000
FMM-1 Relay Module	19	0.000255	0.004845	0.005000	0.125000
SP-134M Ten Input Monitor Module	1	0.002000	0.003000	0.003000	0.006000
HFF-PS10B Tagger	3	0.000000	0.000000	0.020000	0.060000
*FSP-951 Photoelectric Detector	1	0.002000	0.000000	0.004000	0.004000
*FMR Duct Detector w/FSP-951R	1	0.002000	0.000000	0.004000	0.004000
*FMM-1 Monitor Module	3	0.000375	0.001125	0.005000	0.015000
*FMM-1 Relay Module	1	0.000255	0.000255	0.005000	0.005000
*RTS155KEY	1	0.000000	0.000000	0.012000	0.020000
Total Standby:	0.817	Total Alarm:	1.369		

Secondary Load Requirements **15.02** Amp Hours
 Total Secondary Load from the calculation table below:
 Current Draw (Amp) Time (Hours) Total (AH)
 Secondary Standby Load 0.817 24 19.608
 Secondary Alarm Load 1.369 0.94 1.28686
 Total Secondary Load 12.52
 Derating Factor 1.2
 Secondary Load Requirement **15.02**

Battery Selection **18** Amp Hours
 *Devices added for this project.

FACP STANDBY BATTERY CALCULATION

NOTIFIER Standby Battery Calculation HFF-PS10B Remote Power Supply					
Protected Premises: CFVH Harnett MOB 1st & 2nd Floor Fit-Up Date: 2/26/2024					
Address: 225 Brightwater Drive					
City: Lillington State: NC Zip: 27546					
Panel ID: PS1 Location: 1st Floor, Electrical 103					
System Device	Qty	Standby Current Draw	Alarm Current Draw	Draw	Alarm
HFF-PS1010 Main Board	1	0.150000	0.150000	0.170000	0.170000
*PCZWLED10	6	0.000000	0.000000	0.030000	0.230000
*PCZWLED15	12	0.000000	0.000000	0.200000	1.400000
*SCWLED30	1	0.000000	0.000000	0.022000	0.022000
*PCZWLED15	53	0.000000	0.000000	0.035000	1.855000
*PCZWLED30	8	0.000000	0.000000	0.038000	0.304000
*PCZWLED75	7	0.000000	0.000000	0.087000	0.609000
*PCZWLED115	4	0.000000	0.000000	0.120000	0.480000
*SCWLED15	17	0.000000	0.000000	0.016000	0.272000
Total Standby:	0.156	Total Alarm:	5.420		

Secondary Load Requirements **5.04** Amp Hours
 Total Secondary Load from the calculation table below:
 Current Draw (Amp) Time (Hours) Total (AH)
 Secondary Standby Load 0.156 24 3.744
 Secondary Alarm Load 5.420 0.94 5.0988
 Total Secondary Load 4.20
 Derating Factor 1.2
 Secondary Load Requirement **5.04**

Battery Selection **7** Amp Hours
 *Devices added for this project.


PS1 STANDBY BATTERY CALCULATION

NOTIFIER Standby Battery Calculation HFF-PS10B Remote Power Supply					
Protected Premises: CFVH Harnett MOB 1st & 2nd Floor Fit-Up Date: 2/26/2024					
Address: 225 Brightwater Drive					
City: Lillington State: NC Zip: 27546					
Panel ID: PS2 Location: 2nd Floor, Electrical 203					
System Device	Qty	Standby Current Draw	Alarm Current Draw	Draw	Alarm
HFF-PS1010 Main Board	1	0.150000	0.150000	0.170000	0.170000
*PCZWLED10	3	0.000000	0.000000	0.030000	0.170000
*PCZWLED15	84	0.000000	0.000000	0.035000	1.140000
*SCWLED30	1	0.000000	0.000000	0.022000	0.022000
*PCZWLED15	84	0.000000	0.000000	0.035000	1.855000
*PCZWLED30	14	0.000000	0.000000	0.038000	0.532000
*PCZWLED75	4	0.000000	0.000000	0.087000	0.348000
*PCZWLED115	1	0.000000	0.000000	0.120000	0.120000
*SCWLED15	12	0.000000	0.000000	0.016000	0.216000
Total Standby:	0.156	Total Alarm:	4.468		

Secondary Load Requirements **4.94** Amp Hours
 Total Secondary Load from the calculation table below:
 Current Draw (Amp) Time (Hours) Total (AH)
 Secondary Standby Load 0.156 24 3.744
 Secondary Alarm Load 4.468 0.94 4.19992
 Total Secondary Load 4.12
 Derating Factor 1.2
 Secondary Load Requirement **4.94**

Battery Selection **7** Amp Hours
 *Devices added for this project.

PS2 STANDBY BATTERY CALCULATION



FIRE ALARM RISER

Point to Point Voltage Drop Analysis HFF-PS10B Remote Power Supply Source Voltage: 20.4 Nominal System Voltage					
Project Name: CFVH Harnett MOB Fit-Up Date: 2/26/2024					
Circuit No: 2-2 Minimum Voltage: 16					
Area Covered: 2nd Floor Wire Gauge: 14					
Ohm's per 1,000 Ft.: 3.14					
Device Number	Part Number	Current (amp)	Distance (Feet) Between	Total Distance (Feet)	Voltage at Device
1	PCZWLED15	0.035	45	45	20.18
2	PCZWLED15	0.035	30	75	20.04
3	PCZWLED15	0.035	30	105	19.91
4	PCZWLED15	0.035	25	130	19.80
5	PCZWLED15	0.035	30	160	19.68
6	PCZWLED15	0.035	30	190	19.57
7	PCZWLED15	0.035	25	215	19.48
8	PCZWLED15	0.035	35	250	19.36
9	PCZWLED15	0.035	40	290	19.23
10	PCZWLED15	0.035	25	315	19.15
11	PCZWLED15	0.035	25	340	19.08
12	PCZWLED15	0.035	25	365	19.02
13	PCZWLED15	0.035	25	390	18.96
14	PCZWLED15	0.035	25	415	18.91
15	PCZWLED15	0.035	40	455	18.83
16	PCZWLED15	0.035	25	480	18.79
17	PCZWLED15	0.035	25	505	18.76
18	PCZWLED15	0.035	30	535	18.72
19	PCZWLED15	0.035	25	560	18.70
20	SCWLED15	0.018	25	585	18.68
21	PCZWLED15	0.035	25	610	18.66
22	PCZWLED15	0.035	30	640	18.65
23	PCZWLED15	0.035	25	665	18.64
Total Power:	0.777	%Voltage Drop:	-8.62%		Go

NOTE: These calculations double the wire length indicated to account for the total wire resistance of the circuit. DC resistance at 75°C/167°F per NFPA 70, Ch. 9, Table 8.

2ND FLOOR VOLTAGE DROP CALCULATIONS

Point to Point Voltage Drop Analysis HFF-PS10B Remote Power Supply Source Voltage: 20.4 Nominal System Voltage					
Project Name: CFVH Harnett MOB Fit-Up Date: 2/26/2024					
Circuit No: 2-3 Minimum Voltage: 16					
Area Covered: 2nd Floor Wire Gauge: 14					
Ohm's per 1,000 Ft.: 3.14					
Device Number	Part Number	Current (amp)	Distance (Feet) Between	Total Distance (Feet)	Voltage at Device
1	PCZWLED10	0.038	50	50	20.15
2	PCZWLED15	0.035	35	85	19.98
3	PCZWLED15	0.035	25	110	19.87
4	PCZWLED15	0.035	35	145	19.72
5	PCZWLED10	0.038	30	175	19.59
6	PCZWLED15	0.035	40	215	19.44
7	PCZWLED15	0.035	20	235	19.36
8	PCZWLED15	0.035	25	260	19.28
9	PCZWLED15	0.035	25	285	19.20
10	PCZWLED10	0.038	20	305	19.14
11	PCZWLED15	0.035	30	335	19.05
12	PCZWLED15	0.035	25	360	18.99
13	SCWLED15	0.018	30	390	18.92
14	PCZWLED15	0.035	30	420	18.85
15	PCZWLED15	0.035	20	440	18.81
16	PCZWLED15	0.035	25	465	18.77
17	PCZWLED15	0.035	25	490	18.73
18	PCZWLED15	0.035	25	515	18.70
19	PCZWLED15	0.035	20	535	18.67
20	PCZWLED10	0.038	35	570	18.64
21	PCZWLED15	0.035	25	595	18.62
22	PCZWLED15	0.035	20	615	18.62
23	PCZWLED15	0.035	20	635	18.61
Total Power:	0.820	%Voltage Drop:	-8.78%		Go

NOTE: These calculations double the wire length indicated to account for the total wire resistance of the circuit. DC resistance at 75°C/167°F per NFPA 70, Ch. 9, Table 8.

1ST FLOOR VOLTAGE DROP CALCULATIONS

Point to Point Voltage Drop Analysis HFF-PS10B Remote Power Supply Source Voltage: 20.4 Nominal System Voltage					
Project Name: CFVH Harnett MOB Fit-Up Date: 2/26/2024					
Circuit No: 2-3 Minimum Voltage: 16					
Area Covered: 2nd Floor Wire Gauge: 14					
Ohm's per 1,000 Ft.: 3.14					
Device Number	Part Number	Current (amp)	Distance (Feet) Between	Total Distance (Feet)	Voltage at Device
1	PCZWLED10	0.038	50	50	20.15
2	PCZWLED15	0.035	35	85	19.98
3	PCZWLED15	0.035	25	110	19.87
4	PCZWLED15	0.035	35	145	19.72
5	PCZWLED10	0.038	30	175	19.59
6	PCZWLED15	0.035	40	215	19.44
7	PCZWLED15	0.035	20	235	19.36
8	PCZWLED15	0.035	25	260	19.28
9	PCZWLED15	0.035	25	285	19.20
10	PCZWLED10	0.038	20	305	19.14
11	PCZWLED15	0.035	30	335	19.05
12	PCZWLED15	0.035	25	360	18.99
13	SCWLED15	0.018	30	390	18.92
14	PCZWLED15	0.035	30	420	18.85
15	PCZWLED15	0.035	20	440	18.81
16	PCZWLED15	0.035	25	465	18.77
17	PCZWLED15	0.035	25	490	18.73
18	PCZWLED15	0.035	25	515	18.70
19	PCZWLED15	0.035	20	535	18.67
20	PCZWLED10	0.038	35	570	18.64
21	PCZWLED15	0.035	25	595	18.62
22	PCZWLED15	0.035	20	615	18.62
23	PCZWLED15	0.035	20	635	18.61
Total Power:	0.820	%Voltage Drop:	-8.78%		Go

NOTE: These calculations double the wire length indicated to account for the total wire resistance of the circuit. DC resistance at 75°C/167°F per NFPA 70, Ch. 9, Table 8.

2ND FLOOR VOLTAGE DROP CALCULATIONS

Point to Point Voltage Drop Analysis HFF-PS10B Remote Power Supply Source Voltage: 20.4 Nominal System Voltage					
Project Name: CFVH Harnett MOB Fit-Up Date: 2/26/2024					
Circuit No: 2-6 Minimum Voltage: 16					
Area Covered: 2nd Floor Wire Gauge: 14					
Ohm's per 1,000 Ft.: 3.14					
Device Number	Part Number	Current (amp)	Distance (Feet) Between	Total Distance (Feet)	Voltage at Device
1	PCZWLED15	0.120	50	50	20.08
2	PCZWLED15	0.087	55	105	19.77
3	SCWLED15	0.018	55	160	19.49
4	PCZWLED15	0.087	25	185	19.37
5	PCZWLED15	0.035	25	220	19.35
6	PCZWLED15	0.087	50	270	19.00
7	SCWLED15	0.018	25	300	18.82
8	PCZWLED10	0.038	25	325	18.84
9	PCZWLED15	0.035	25	350	18.83
10	PCZWLED15	0.035	45	395	18.64
11	PCZWLED15	0.035	30	425	18.59
12	PCZWLED15	0.035	25	450	18.57
13	PCZWLED15	0.035	25	475	18.56
14	PCZWLED15	0.035	30	505	18.51
15	PCZWLED15	0.035	25	530	18.47
16	PCZWLED15	0.035	25	555	18.43
17	PCZWLED15	0.035	25	580	18.40
18	PCZWLED15	0.035	25	605	18.37
19	PCZWLED15	0.035	30	635	18.35
20	PCZWLED15	0.035	25	660	18.32
21	PCZWLED15	0.035	30	690	18.30
22	PCZWLED15	0.035	25	720	18.30
Total Power:	0.798	%Voltage Drop:	-8.86%		Go

NOTE: These calculations double the wire length indicated to account for the total wire resistance of the circuit. DC resistance at 75°C/167°F per NFPA 70, Ch. 9, Table 8.

1ST FLOOR VOLTAGE DROP CALCULATIONS

Point to Point Voltage Drop Analysis HFF-PS10B Remote Power Supply Source Voltage: 20.4 Nominal System Voltage					
Project Name: CFVH Harnett MOB Fit-Up Date:					