



# Permit Inspections

## Harnett County

Permit Number: **BCOM2401-0004**

Description: **9000 sf Airplane Hangar**

Applied: **1/12/2024**

Approved: **2/16/2024**

Site Address: **497 AIRPORT RD**

Issued: **2/16/2024**

Finalized:

City, State Zip Code: **ERWIN, NC 28339**

Status: **ISSUED**

Applicant: **Harnett Air, LLC**

Parent Permit:

Owner: **HARNETT COUNTY**

Parent Project: **SITE2305-0003**

Contractor: **Highland Paving Co., LLC**

Details:

### LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			SLAB	Brad Sutton		

Notes:

			ROUGH IN	Brad Sutton		
--	--	--	----------	-------------	--	--

Notes:

	1/16/2024	1/19/2024	ADDRESS	GIS Bucket	APPROVED	
--	-----------	-----------	---------	------------	----------	--

Notes:

497 AIRPORT RD ERWIN 28339.

	3/8/2024	3/8/2024	FOOTING	Brad Sutton	APPROVED	eTRAKiT Inspection Request
--	----------	----------	---------	-------------	----------	----------------------------

Notes:

3/4/2024 11:32 AM Highland Paving Co., LLC

door footing inspection requested at 1:00 pm so concrete can be poured at 3:00 pm same day

Contact Name: Highland Paving Co., LLC

Site Address: 497 AIRPORT RD

Phone: 9105962161

e-Mail: rostendorf@highlandpaving.com

First pour, footing under door only

	3/14/2024	3/14/2024	MONO SLAB	Brad Sutton	APPROVED	eTRAKiT Inspection Request
--	-----------	-----------	-----------	-------------	----------	----------------------------

Notes:

3/13/2024 7:56 AM Highland Paving Co., LLC

1:00 requested for mono slab inspection.

Contact Name: Highland Paving Co., LLC

Site Address: 497 AIRPORT RD

Phone: 9105962161

e-Mail: rostendorf@highlandpaving.com

	10/10/2024 AM	10/10/2024 AM	FM FINAL	Roger Sullivan	APPROVED	passed
--	---------------	---------------	----------	----------------	----------	--------

Notes:

The gate code is 1238.

Final inspection, passed.



# Permit Inspections

## Harnett County

40			ZONING	Planning Bucket		
Notes:						
40	10/1/2024	AM	10/1/2024	AM	FM FINAL	Roger Sullivan
DISAPPROVED						
see notes						
Notes:						
Gate code is 1238						
Need to install & mount fire extinguishers.						
50			FINAL**	Brad Sutton		
Notes:						