

Permit Inspections Harnett County

Permit Number: BCOM2402-0008

Description: The Bogey Brothers Golf simulator and beer on tap

| Applied: 2/16/2024 | Approved: 7/1/2024 | Site Address: 2646 NC 24-87 |
|--------------------|---------------------------|--|
| Issued: 3/26/2024 | Finaled: 9/27/2024 | City, State Zip Code: CAMERON, NC 28326 |
| Status: FINALED | | Applicant: Farrell Robert and John |
| Parent Permit: | | Owner: 33418 EGYPT CROSSING LLC |
| Parent Project: | | Contractor: Farrell Robert Brandon/Farrell's Custom Const. |

Details:

| LIST OF INSPECTIONS | | | | | | | | |
|--|----------------|-----------------------|------------------------|----------------------|-------------|----------------|--|--|
| SEQ ID | SCHEDULED DATE | COMPLETED DATE | ТҮРЕ | INSPECTOR | RESULT | REMARKS | | |
| | 6/14/2024 | 6/14/2024 | SLAB | Steven Gazlay | APPROVED | | | |
| Notes: | | | | | | | | |
| | 7/1/2024 | 7/1/2024 | ROUGH IN | Steven Gazlay | APPROVED | | | |
| Notes: | | | | | | | | |
| | 9/24/2024 | 9/24/2024 10:30 AM | ZONING | Randy Baker | APPROVED | | | |
| Notes: | | | | | | | | |
| | 9/24/2024 | 9/24/2024 | FM FINAL | Sean M Sinor | DISAPPROVED | See Notes | | |
| Notes: This is for the ABC inspection permit Exit and emergency light not working and fire extinguishers not up. | | | | | | | | |
| | 9/26/2024 AM | 9/26/2024 AM | FM FINAL | Roger Sullivan | APPROVED | ABC Inspection | | |
| Notes: This is for an ABC inspection Passed inspection. | | | | | | | | |
| | 9/26/2024 AM | 9/26/2024 AM | FM FINAL | Roger Sullivan | APPROVED | passed | | |
| Notes: Passed i | nspection. | | | - | | | | |
| | 9/27/2024 | 9/27/2024 | ABC LICENSE | Ricardo D Honrada | APPROVED | | | |
| Notes: ABC fina | l | | | | | | | |
| 40 | 9/12/2024 | 9/12/2024 | EH SANITATION FINAL | EH Bucket | APPROVED | | | |
| Notes: Permit issued | | | | | | | | |
| | | | | | | | | |





Permit Inspections Harnett County

| 40 | 9/24/2024 | 9/24/2024 | FM FINAL | Sean M Sinor | DISAPPROVED | See Notes | | | |
|---|-----------|-----------|----------|----------------------|-------------|-----------|--|--|--|
| Notes: | | | | | | | | | |
| Please call John Farrell at 919-721-8175 about 45 minutes before you get there so he can be there to open door. | | | | | | | | | |
| Exit and emergency lights not working and fire extinguishers not up. | | | | | | | | | |
| 40 | 9/27/2024 | 9/27/2024 | FINAL** | Ricardo D Honrada | APPROVED | | | | |
| Notes: | | | | | | | | | |
| | | | | | | | | | |