

Automatic Fire Sprinkler Systems



3101-310 Poplarwood Court - Raleigh, NC 27604

Ph: 919-212-2722 Fax: 919-212-2720

www.regionalfirenc.com

Ajith Zacharias, CET[®]

Certified Engineering Tech.

NICET #120860

Water-Based Systems Layout, Level III



HYDRAULIC CALCULATIONS

For:

HARBOR FREIGHT TOOLS

129 W. Cornelius Harnett Blvd.

Lillington, NC 27546

Submitted by:

Jack Harlow

Automatic Fire Sprinkler Systems



Hydraulic Calculations by HydraCALC

REGIONAL FIRE SERVICES OF NC
3101 POPLARWOOD CT.
SUITE - 310
RALEIGH, NC 27604
919-212-2722

Job Name : Harbor Freight Tools
Drawing : FP-2
Location : 129 W. Cornelius Harnett Blvd., Lillington, NC 27546
Remote Area : 1
Contract : 24026
Data File : REMOTE AREA #1 _ SALES_ Harbor Freight.WXF
Date/Time : 05/29/2024 - 03:46 PM

HYDRAULIC CALCULATIONS
for

JOB NAME Harbor Freight Tools
Location 129 W. Cornelius Harnett Blvd., Lillington, NC 27546
Drawing # FP-2
Contract # 24026
Date 05-29-24

DESIGN

Remote area # 1
Remote area location Sales Area 101
Occupancy classification Mercantile
Density 0.20 - Gpm/SqFt
Area of application 1500 - SqFt
Coverage/sprinkler 256 Max. - SqFt
Type of sprinkler calculated 14.0K Extended Coverage Upright
Sprinklers calculated 8
In-rack demand N/A - GPM
Hose streams 250 - GPM
Total water required (including hose streams) 665.073 - GPM @ 43.6443 - Psi
Type of system EXISTING WET SYSTEM
Volume of system (dry or pre-action) N/A - Gal

WATER SUPPLY INFORMATION

Test date 05-23-24
Location 129 W. Cornelius Harnett Blvd.
Source of info Regional Fire Services of NC, LLC

CONTRACTOR INFO REGIONAL FIRE SERVICES OF NC
Address 3101 POPLARWOOD CT. / SUITE - 310 / RALEIGH, NC 27604
Phone # 919-212-2722
Name of designer Jack Harlow
Authority having jurisdiction Harnett County

NOTES:

text1(35) - invisible

Water Supply Curve

REGIONAL FIRE SERVICES OF NC
Harbor Freight Tools


Page 2
Date 05-29-24

City Water Supply:

C1 - Static Pressure : 70
C2 - Residual Pressure: 54
C2 - Residual Flow : 1088

Demand:

D1 - Elevation : 9.745
D2 - System Flow : 415.073
D2 - System Pressure : 43.644
Hose (Demand) : 250
D3 - System Demand : 665.073
Safety Margin : 19.919



Flow Diagram

REGIONAL FIRE SERVICES OF NC
Harbor Freight Tools

Page 3
Date 05-29-24

52.1
A1 ← 1
|
4
52.1
A2 ← 2

51.2
A3 ← 3
|
33.4
51.1
A4 ← 4
|
17.7
51.1
A5 ← 5

51.7
A6 ← 6
|
33.4
52.8
A7 ← 7
|
19.4
52.9
A8 ← 8

56.1 48.2
101 → 1 → 2 ← 111
| 4
30.2
84.6
102 → 3 → 4 ← 5 ← 112
| 17.7 68.8
114.8 142.8
85.1 19.4
103 → 6 → 7 ← 8 ← 113
33.4 72.3

25.9
100 ← 110

26
104 ← 114
| 174 241.1
27.1
105 ← 115
| 146.9 268.2
29.1
106 ← 116
| 117.9 297.1
32.7
107 ← 117
| 85.2 329.9
37.2
108 ← 118
| 48 367.1
48
109 ← 119

25.9 114.8 174 117.9 48
100 → 101 ← 102 ← 103 ← 104 ← 105 ← 106 ← 107 ← 108 ← 109
| 30.2 199.9 146.9 85.2
25.9 26 27.1 29 32.7 37.2 48
25.9 142.8 241.1 297.1 367.1 415.1 415.1 415.1
110 ← 111 ← 112 ← 113 ← 114 ← 115 ← 116 ← 117 ← 118 ← 119 ← TOR1 ← TOR2 ← BOR ← UG1 ← UG2 ← TEST
74.1 215.2 268.2 329.9 415.1 415.1 415.1

Fittings Used Summary

REGIONAL FIRE SERVICES OF NC
Harbor Freight Tools

Page 4
Date 05-29-24

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zic	Wilkins 350ADA	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA. The diameter modification was turned off by the operator when the job was calculated.

SUPPLY ANALYSIS

Node at Source	Static Pressure	Residual Pressure	Flow	Available Pressure	Total Demand	Required Pressure
TEST	70.0	54	1088.0	63.563	665.07	43.644

NODE ANALYSIS

Node Tag	Elevation	Node Type	Pressure at Node	Discharge at Node	Notes
A1	19.75	14	13.86	52.13	0.2 139
A2	19.75	14	13.86	52.12	0.2 139
A3	19.5	14	13.39	51.22	0.2 222
A4	19.5	14	13.3	51.06	0.2 222
A5	19.5	14	13.33	51.11	0.2 253
A6	19.167	14	13.65	51.73	0.2 224
A7	19.167	14	14.23	52.81	0.2 256
A8	19.167	14	14.27	52.89	0.2 256
101	12.5		27.32		
1	12.5		26.38		
2	12.5		26.38		
102	12.5		27.32		
3	12.5		25.31		
4	12.5		25.17		
5	12.5		25.22		
103	12.5		27.38		
6	12.5		25.35		
7	14.0		24.45		
8	14.0		24.5		
100	12.5		27.32		
104	12.5		27.54		
105	12.5		27.63		
106	12.5		27.7		
107	12.5		27.75		
108	12.5		27.78		
109	12.5		27.79		
110	15.667		26.85		
111	15.667		26.85		
112	15.667		26.86		
113	15.667		26.95		
114	15.667		27.13		
115	15.667		27.3		
116	15.667		27.51		
117	15.667		27.76		
118	15.667		28.16		
119	15.667		29.32		
TOR1	15.667		29.93		
TOR2	12.5		31.43		
BOR	1.0		39.83		
UG1	-3.0		41.67		

Flow Summary - NFPA

REGIONAL FIRE SERVICES OF NC
Harbor Freight Tools

Page 6
Date 05-29-24

NODE ANALYSIS (cont.)

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
UG2	-3.0		42.67		
TEST	-3.0		43.64	250.0	

Final Calculations : Hazen-Williams

REGIONAL FIRE SERVICES OF NC
Harbor Freight Tools

Page 7
Date 05-29-24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
*HEADS & SPRIGS											
A1 to 1	19.750 12.500	14.00	52.13 52.13	1 1.049	T 5.0	7.250 5.000 12.250	120 0.7656	13.863 3.140 9.379		Vel = 19.35	
1			0.0 52.13					26.382		K Factor = 10.15	
A2 to 2	19.750 12.500	14.00	52.12 52.12	1 1.049	T 5.0	7.250 5.000 12.250	120 0.7656	13.861 3.140 9.378		Vel = 19.35	
2			0.0 52.12					26.379		K Factor = 10.15	
A3 to 3	19.500 12.500	14.00	51.22 51.22	1 1.049	T 5.0	7.000 5.000 12.000	120 0.7412	13.387 3.032 8.895		Vel = 19.01	
3			0.0 51.22					25.314		K Factor = 10.18	
A4 to 4	19.500 12.500	14.00	51.06 51.06	1 1.049	T 5.0	7.000 5.000 12.000	120 0.7368	13.300 3.032 8.842		Vel = 18.95	
4			0.0 51.06					25.174		K Factor = 10.18	
A5 to 5	19.500 12.500	14.00	51.11 51.11	1 1.049	T 5.0	7.000 5.000 12.000	120 0.7382	13.327 3.032 8.858		Vel = 18.97	
5			0.0 51.11					25.217		K Factor = 10.18	
A6 to 6	19.167 12.500	14.00	51.73 51.73	1 1.049	T 5.0	6.667 5.000 11.667	120 0.7550	13.655 2.887 8.809		Vel = 19.20	
6			0.0 51.73					25.351		K Factor = 10.27	
A7 to 7	19.167 14	14.00	52.82 52.82	1 1.049	T 5.0	5.167 5.000 10.167	120 0.7844	14.232 2.238 7.975		Vel = 19.61	
7			0.0 52.82					24.445		K Factor = 10.68	
A8 to 8	19.167 14	14.00	52.89 52.89	1 1.049	T 5.0	5.167 5.000 10.167	120 0.7864	14.271 2.238 7.995		Vel = 19.63	
8			0.0 52.89					24.504		K Factor = 10.68	
*REMOTE GRID LINE 1											
101 to 1	12.500 12.500		-56.08 -56.08	2 2.157	T 10.0	25.833 10.000 35.833	120 -0.0262	27.320 0.0 -0.938		Vel = 4.92	
1 to 2	12.500 12.500		52.13 -3.95	2 2.157		14.000 14.000	120 -0.0002	26.382 0.0 -0.003		Vel = 0.35	

Final Calculations : Hazen-Williams

REGIONAL FIRE SERVICES OF NC
Harbor Freight Tools

Page 8
Date 05-29-24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
2 to 111	12.500 15.667		52.12 48.17	2 2.157	2E T 10.0 10.0	73.000 20.000 93.000	120 0.0198	26.379 -1.372 1.839		Vel = 4.23	
111			0.0 48.17					26.846		K Factor = 9.30	
*REMOTE GRID LINE 2											
102 to 3	12.500 12.500		-84.63 -84.63	2 2.157	T 10.0	25.833 10.000 35.833	120 -0.0561	27.323 0.0 -2.009		Vel = 7.43	
3 to 4	12.500 12.500		51.23 -33.4	2 2.157		14.000 14.000	120 -0.0100	25.314 0.0 -0.140		Vel = 2.93	
4 to 5	12.500 12.500		51.05 17.65	2 2.157		14.000 14.000	120 0.0031	25.174 0.0 0.043		Vel = 1.55	
5 to 112	12.500 15.667		51.11 68.76	2 2.157	2E T 10.0 10.0	59.000 20.000 79.000	120 0.0382	25.217 -1.372 3.017		Vel = 6.04	
112			0.0 68.76					26.862		K Factor = 13.27	
*REMOTE GRID LINE 3											
103 to 6	12.500 12.500		-85.11 -85.11	2 2.157	T 10.0	25.833 10.000 35.833	120 -0.0567	27.381 0.0 -2.030		Vel = 7.47	
6 to 7	12.500 14		51.74 -33.37	2 2.157	2E 10.0	15.500 10.000 25.500	120 -0.0100	25.351 -0.650 -0.256		Vel = 2.93	
7 to 8	14 14		52.81 19.44	2 2.157		16.000 16.000	120 0.0037	24.445 0.0 0.059		Vel = 1.71	
8 to 113	14 15.667		52.89 72.33	2 2.157	2E T 10.0 10.0	55.500 20.000 75.500	120 0.0419	24.504 -0.722 3.166		Vel = 6.35	
113			0.0 72.33					26.948		K Factor = 13.93	
*GRID LINES											
100 to 110	12.500 15.667		25.90 25.9	2 2.157	2T 2E 20.0 10.0	112.833 30.000 142.833	120 0.0063	27.321 -1.372 0.896		Vel = 2.27	
110			0.0 25.90					26.845		K Factor = 5.00	
104 to 114	12.500 15.667		25.95 25.95	2 2.157	2T 4E 20.0 20.0	112.833 40.000 152.833	120 0.0063	27.541 -1.372 0.962		Vel = 2.28	
114			0.0 25.95					27.131		K Factor = 4.98	

Final Calculations : Hazen-Williams

REGIONAL FIRE SERVICES OF NC
Harbor Freight Tools

Page 9
Date 05-29-24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
105 to 115	12.500 15.667		27.06 27.06	2 2.157	2T 4E 20.0 20.0	112.833 40.000 152.833	120 0.0068	27.634 -1.372 1.039		Vel = 2.38	
115			0.0 27.06					27.301		K Factor = 5.18	
106 to 116	12.500 15.667		28.95 28.95	2 2.157	2T 4E 20.0 20.0	112.833 40.000 152.833	120 0.0077	27.701 -1.372 1.179		Vel = 2.54	
116			0.0 28.95					27.508		K Factor = 5.52	
107 to 117	12.500 15.667		32.75 32.75	2 2.157	2T 2E 20.0 10.0	112.833 30.000 142.833	120 0.0097	27.746 -1.372 1.383		Vel = 2.88	
117			0.0 32.75					27.757		K Factor = 6.22	
108 to 118	12.500 15.667		37.24 37.24	2 2.157	2T 2E 20.0 10.0	112.833 30.000 142.833	120 0.0123	27.780 -1.372 1.754		Vel = 3.27	
118			0.0 37.24					28.162		K Factor = 7.02	
109 to 119	12.500 15.667		47.97 47.97	2 2.157	2T 2E 20.0 10.0	118.083 30.000 148.083	120 0.0196	27.788 -1.372 2.905		Vel = 4.21	
119			0.0 47.97					29.321		K Factor = 8.86	
*FLOAT MAIN											
100 to 101	12.500 12.500		-25.90 -25.9	4 4.26		3.750 3.750	120 -0.0003	27.321 0.0 -0.001		Vel = 0.58	
101 to 102	12.500 12.500		56.08 30.18	4 4.26		10.000 10.000	120 0.0003	27.320 0.0 0.003		Vel = 0.68	
102 to 103	12.500 12.500		84.62 114.8	4 4.26		16.000 16.000	120 0.0036	27.323 0.0 0.058		Vel = 2.58	
103 to 104	12.500 12.500		85.11 199.91	4 4.26		16.000 16.000	120 0.0100	27.381 0.0 0.160		Vel = 4.50	
104 to 105	12.500 12.500		-25.95 173.96	4 4.26		12.000 12.000	120 0.0078	27.541 0.0 0.093		Vel = 3.92	
105 to 106	12.500 12.500		-27.06 146.9	4 4.26		12.000 12.000	120 0.0056	27.634 0.0 0.067		Vel = 3.31	
106 to 107	12.500 12.500		-28.95 117.95	4 4.26		12.000 12.000	120 0.0038	27.701 0.0 0.045		Vel = 2.66	

Final Calculations : Hazen-Williams

REGIONAL FIRE SERVICES OF NC
Harbor Freight Tools

Page 10
Date 05-29-24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
107 to 108	12.500 12.500		-32.75 85.2	4 4.26		16.000 16.000	120 0.0021	27.746 0.0 0.034			Vel = 1.92
108 to 109	12.500 12.500		-37.23 47.97	4 4.26		12.333 12.333	120 0.0006	27.780 0.0 0.008			Vel = 1.08
109			0.0 47.97					27.788			K Factor = 9.10
*MAIN											
110 to 111	15.667 15.667		25.90 25.9	4 4.26		3.750 3.750	120 0.0003	26.845 0.0 0.001			Vel = 0.58
111 to 112	15.667 15.667		48.17 74.07	4 4.26		10.000 10.000	120 0.0016	26.846 0.0 0.016			Vel = 1.67
112 to 113	15.667 15.667		68.76 142.83	4 4.26		16.000 16.000	120 0.0054	26.862 0.0 0.086			Vel = 3.22
113 to 114	15.667 15.667		72.33 215.16	4 4.26		16.000 16.000	120 0.0114	26.948 0.0 0.183			Vel = 4.84
114 to 115	15.667 15.667		25.96 241.12	4 4.26		12.000 12.000	120 0.0142	27.131 0.0 0.170			Vel = 5.43
115 to 116	15.667 15.667		27.05 268.17	4 4.26		12.000 12.000	120 0.0172	27.301 0.0 0.207			Vel = 6.04
116 to 117	15.667 15.667		28.95 297.12	4 4.26		12.000 12.000	120 0.0208	27.508 0.0 0.249			Vel = 6.69
117 to 118	15.667 15.667		32.75 329.87	4 4.26		16.000 16.000	120 0.0253	27.757 0.0 0.405			Vel = 7.43
118 to 119	15.667 15.667		37.24 367.11	4 4.26	2E 20.0	17.667 20.000 37.667	120 0.0308	28.162 0.0 1.159			Vel = 8.26
119 to TOR1	15.667 15.667		47.96 415.07	4 4.26	E 10.0	5.833 10.000 15.833	120 0.0387	29.321 0.0 0.612			Vel = 9.34
TOR1			0.0 415.07					29.933			K Factor = 75.87
*RISER											
TOR1 to TOR2	15.667 12.500		415.07 415.07	4 4.26		3.167 3.167	120 0.0385	29.933 1.372 0.122			Vel = 9.34
TOR2 to BOR	12.500 1		0.0 415.07	6 6.357	Zic B 10.0	11.500 10.000 21.500	120 0.0054	31.427 8.281 0.117		** Fixed Loss = 3.3	Vel = 4.20

Final Calculations : Hazen-Williams

REGIONAL FIRE SERVICES OF NC
Harbor Freight Tools

Page 11
Date 05-29-24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****	
			0.0										
BOR			415.07						39.825	K Factor = 65.77			
*SUPPLY													
BOR	1		415.07	6	E	18.62	4.000	140	39.825				
to							18.620		1.732				
UG1	-3		415.07	6.16			22.620	0.0049	0.110	Vel = 4.47			
UG1	-3		0.0	6	2E	37.24	167.000	140	41.667				
to					G	3.99	41.230		0.0				
UG2	-3		415.07	6.16			208.230	0.0048	1.004	Vel = 4.47			
UG2	-3		0.0	6			202.000	140	42.671				
to									0.0				
TEST	-3		415.07	6.16			202.000	0.0048	0.973	Vel = 4.47			
			250.00										
TEST			665.07						43.644	Qa = 250.00 K Factor = 100.67			

Hydrant Flow Test Report

Test Date 5/23/2024

Test Time 9:30 am

Location

129 W. Cornelius Harnett Blvd.
Lillington, NC 27546

Tested by

Jack Harlow & Thomas Crowder
Regional Fire Services of NC, LLC

Notes

Residual hydrant (4311166)
Flow hydrant (4311166A)


Read Hydrant

70 psi **static pressure**
54 psi **residual pressure**
180 ft **hydrant elevation**

Flow Hydrant(s)

Outlet	Elev	Size	C	Pitot Pressure	Flow
#1	180	2.5	.9	42	1088 gpm

Flow Graph





HYDRANT #2 (FLOW)
 PITOT: 42 psi
 FLOW: 1088 gpm
 @ 20 PSI: 2014.3 gpm

HYDRANT #1 (PRESSURE)
 STATIC: 70 psi
 RESIDUAL: 54 psi



Harnett.org/GIS

May 23, 2024

County Boundary	6 - 36
City Limits	Road Centerlines
Address Numbers	US
Fire Hydrants	Parcels

