



Hydraulic Calculations by HydraCALC

CAROLINA FIRE PROTECTION
4055 HODGES CHAPEL ROAD
DUNN, NC 28334
910-892-1700

Job Name : BAUCOM BUSINESS PLAZA STORAGE
Drawing : FP-102
Location : 11132 US 401 N FUQUAY VARINA, NC 27526
Remote Area : 2
Contract :
Data File : BAUCOM BUSINESS PLAZA STORAGE Area 2.WXF

HYDRAULIC CALCULATIONS
for

JOB NAME BAUCOM BUSINESS PLAZA STORAGE
Location 11132 US 401 N FUQUAY VARINA, NC 27526
Drawing # FP-102
Contract #
Date 10-02-24

DESIGN

Remote area # 2
Remote area location UPPER LEVEL
Occupancy classification OH-2 (STORAGE)
Density 0.2 - Gpm/SqFt
Area of application 1500 - SqFt
Coverage/sprinkler 125 - SqFt
Type of sprinkler calculated VICTAULIC (V2704) 1/2" 155 QR BR UPR
Sprinklers calculated 16
In-rack demand N/A - GPM
Hose streams 250 - GPM
Total water required (including hose streams) 628.19 - GPM @ 91.25 - Psi
Type of system WET
Volume of system (dry or pre-action) - Gal

WATER SUPPLY INFORMATION

Test date 10-05-23
Location 11132 US 401 N, FUQUAY-VARINA, NC
Source of info ENGINEERING PLANNING AND MANAGEMENT

CONTRACTOR INFO CAROLINA FIRE PROTECTION
Address 4055 HODGES CHAPEL ROAD / DUNN, NC 28334
Phone # 910-892-1700
Name of designer IFPDC-GB
Authority having jurisdiction

NOTES:

SAFETY MARGIN 14.67 PSI

text1(35) - invisible


Water Supply Curve

CAROLINA FIRE PROTECTION
BAUCOM BUSINESS PLAZA STORAGE

Page 2
Date

City Water Supply:
C1 - Static Pressure : 109.8
C2 - Residual Pressure: 88
C2 - Residual Flow : 1597

Demand:
D1 - Elevation : 20.455
D2 - System Flow : 378.186
D2 - System Pressure : 91.252
Hose (Demand) : 250
D3 - System Demand : 628.186
Safety Margin : 14.668



Fittings Used Summary

CAROLINA FIRE PROTECTION
BAUCOM BUSINESS PLAZA STORAGE

Page 3
Date

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Bvca	B Fly Vic 705						6	6	7		8	12	14	16	18	19					
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zcj	Colt C500 Horz OSY	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

CAROLINA FIRE PROTECTION
BAUCOM BUSINESS PLAZA STORAGE

Page 4
Date

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	109.8	88	1597.0	105.92	628.19	91.252

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>	
WS	0.0		28.23			
200	22.9	5.6	16.95	23.05	0.2	115
201	24.16		17.41			
202	23.17		19.87			
203	23.17		20.14			
204	23.17		21.24			
205	23.17		23.68			
206	23.17		25.94			
207	23.17		27.8			
208	23.17		29.44			
209	23.17		30.94			
210	23.17		32.4			
211	23.17		33.83			
212	23.17		35.26			
213	23.17		36.69			
214	23.17		38.12			
215	23.17		39.53			
216	23.17		40.89			
217	23.17		42.15			
218	23.17		43.22			
219	23.17		44.03			
220	23.17		44.53			
221	24.17		47.48			
222	23.17		48.29			
223	23.17		50.96			
110	23.17		55.98			
TSR	23.17		56.18			
BSR	11.0		63.14			
RE	7.0		64.98			
UG1	-1.0		68.94	250.0		
PIT	-1.0		72.41			
CON	-1.0		82.34			
TEST	-21.0		91.25			
224	19.6	5.6	17.57	23.47	0.2	115
225	21.23	5.6	17.04	23.11	0.2	115
226	19.58	5.6	17.77	23.6	0.2	115
227	21.22	5.6	17.23	23.25	0.2	115
228	22.88	5.6	17.15	23.19	0.2	115
229	24.14		17.62			
230	19.59	5.6	18.5	24.09	0.2	115
231	21.24	5.6	17.97	23.74	0.2	115
232	22.9	5.6	17.92	23.7	0.2	115

Flow Summary - NFPA

CAROLINA FIRE PROTECTION
 BAUCOM BUSINESS PLAZA STORAGE

Page 5
 Date

NODE ANALYSIS (cont.)

Node Tag	Elevation	Node Type	Pressure at Node	Discharge at Node		Notes
233	24.16		18.42			
234	24.56	5.6	17.25	23.26	0.2	115
235	26.23	5.6	16.87	23.0	0.2	115
236	24.16		23.42			
237	23.17		24.83			
238	23.17		24.92			
239	23.17		25.29			
240	23.17		26.06			
241	23.17		27.08			
242	23.17		28.28			
243	23.17		29.6			
244	23.17		30.98			
245	23.17		32.4			
246	23.17		33.83			
247	23.17		35.26			
248	23.17		36.69			
249	23.17		38.12			
250	23.17		39.56			
251	23.17		41.04			
252	23.17		42.57			
253	23.17		44.23			
254	23.17		46.1			
255	24.55	5.6	17.45	23.39	0.2	115
256	26.22	5.6	17.06	23.13	0.2	115
257	24.14		23.54			
258	24.56	5.6	18.25	23.93	0.2	115
259	26.24	5.6	17.82	23.64	0.2	115
260	24.16		23.96			
261	25.72	5.6	22.61	26.63	0.2	115
262	24.15		25.3			
263	24.17		26.53			
264	24.14		27.81			
265	24.14		29.16			
266	24.17		30.55			
267	24.15		31.98			
268	24.15		33.41			
269	24.15		34.84			
270	24.14		36.27			
271	24.15		37.7			
272	24.15		39.14			
273	24.15		40.6			
274	24.14		42.11			
275	24.14		43.71			
276	24.15		45.46			
277	23.17		44.7			
278	24.16		49.9			

Final Calculations : Hazen-Williams

CAROLINA FIRE PROTECTION
BAUCOM BUSINESS PLAZA STORAGE

Page 6
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
200 to 201	22.9 24.16	5.60	69.64	1.5			7.680	120	16.947 -0.546			
			69.64	1.682			7.680	0.1312	1.008	Vel =	10.06	
201 to 202	24.16 23.17		-10.30	1.5	2T	19.799	1.010 19.799	120	17.409 0.429			
			59.34	1.682			20.809	0.0976	2.031	Vel =	8.57	
202 to 203	23.17 23.17		0.0	2			9.370	120	19.869 0.0			
			59.34	2.157			9.370	0.0291	0.273	Vel =	5.21	
203 to 204	23.17 23.17		60.45	2			10.330	120	20.142 0.0			
			119.79	2.157			10.330	0.1066	1.101	Vel =	10.52	
204 to 205	23.17 23.17		64.82	2			10.270	120	21.243 0.0			
			184.61	2.157			10.270	0.2374	2.438	Vel =	16.21	
205 to 206	23.17 23.17		-4.90	2			10.020	120	23.681 0.0			
			179.71	2.157			10.020	0.2258	2.263	Vel =	15.78	
206 to 207	23.17 23.17		-17.84	2			10.000	120	25.944 0.0			
			161.87	2.157			10.000	0.1861	1.861	Vel =	14.21	
207 to 208	23.17 23.17		-11.15	2			10.000	120	27.805 0.0			
			150.72	2.157			10.000	0.1631	1.631	Vel =	13.23	
208 to 209	23.17 23.17		-6.24	2			10.000	120	29.436 0.0			
			144.48	2.157			10.000	0.1508	1.508	Vel =	12.69	
209 to 210	23.17 23.17		-2.92	2			10.000	120	30.944 0.0			
			141.56	2.157			10.000	0.1452	1.452	Vel =	12.43	
210 to 211	23.17 23.17		-0.99	2			10.000	120	32.396 0.0			
			140.57	2.157			10.000	0.1434	1.434	Vel =	12.34	
211 to 212	23.17 23.17		-0.17	2			10.000	120	33.830 0.0			
			140.4	2.157			10.000	0.1430	1.430	Vel =	12.33	
212 to 213	23.17 23.17		-0.01	2			10.000	120	35.260 0.0			
			140.39	2.157			10.000	0.1430	1.430	Vel =	12.33	
213 to 214	23.17 23.17		-0.13	2			10.000	120	36.690 0.0			
			140.26	2.157			10.000	0.1428	1.428	Vel =	12.31	
214 to 215	23.17 23.17		-0.87	2			10.000	120	38.118 0.0			
			139.39	2.157			10.000	0.1411	1.411	Vel =	12.24	
215 to 216	23.17 23.17		-2.70	2			10.000	120	39.529 0.0			
			136.69	2.157			10.000	0.1361	1.361	Vel =	12.00	

Final Calculations : Hazen-Williams

CAROLINA FIRE PROTECTION
BAUCOM BUSINESS PLAZA STORAGE

Page 7
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
216 to 217	23.17 23.17		-5.86 130.83	2 2.157			10.000 10.000	120 0.1255	40.890 0.0 1.255			Vel = 11.49
217 to 218	23.17 23.17		-10.52 120.31	2 2.157			9.990 9.990	120 0.1075	42.145 0.0 1.074			Vel = 10.56
218 to 219	23.17 23.17		-16.77 103.54	2 2.157			9.980 9.980	120 0.0815	43.219 0.0 0.813			Vel = 9.09
219 to 220	23.17 23.17		-24.63 78.91	2 2.157			10.020 10.020	120 0.0492	44.032 0.0 0.493			Vel = 6.93
220 to 221	23.17 24.17		-44.85 34.06	1.5 1.682	3T 2E	29.699 9.9	57.180 39.599 96.779	120 0.0350	44.525 -0.433 3.384			Vel = 4.92
221 to 222	24.17 23.17		0.0 34.06	1.5 1.682	T	9.9	1.010 9.900 10.910	120 0.0349	47.476 0.433 0.381			Vel = 4.92
222 to 223	23.17 23.17		299.28 333.34	2.5 2.635			10.000 10.000	120 0.2672	48.290 0.0 2.672			Vel = 19.61
223 to 110	23.17 23.17		44.85 378.19	2.5 2.635	E	8.237	6.630 8.237 14.867	120 0.3375	50.962 0.0 5.017			Vel = 22.25
110 to TSR	23.17 23.17		0.0 378.19	3 3.26			1.670 1.670	120 0.1198	55.979 0.0 0.200			Vel = 14.54
TSR to BSR	23.17 11		0.0 378.19	4 4.26	Bvca S	10.534 28.968	12.625 39.502 52.127	120 0.0325	56.179 5.271 1.695			Vel = 8.51
BSR to RE	11 7		0.0 378.19	6 6.357	E	17.603	4.000 17.603 21.603	120 0.0046	63.145 1.732 0.100			Vel = 3.82
RE to UG1	7 -1		0.0 378.19	6 6.28	E T G	22.063 47.277 4.728	60.000 74.068 134.068	140 0.0037	64.977 3.465 0.495			Vel = 3.92
UG1 to PIT	-1 -1	H250	250.00 628.19	6 6.09	E 2F	21.583 21.583	317.000 43.166 360.166	150 0.0097	68.937 0.0 3.478			Vel = 6.92
PIT to CON	-1 -1		0.0 628.19	6 6.28	2E T 2G Zcj	44.125 47.277 9.455 0.0	100.000 100.857 200.857	140 0.0094	72.415 8.030 1.896		** Fixed Loss = 8.03	Vel = 6.51
CON to TEST	-1 -21		0.0 628.19	12 12.46	T 3F	98.292 63.89	580.000 162.182 742.182	140 0.0003	82.341 8.662 0.249			Vel = 1.65
TEST			0.0 628.19						91.252			K Factor = 65.76

Final Calculations : Hazen-Williams

CAROLINA FIRE PROTECTION
BAUCOM BUSINESS PLAZA STORAGE

Page 8
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
224 to 225	19.6 21.23	5.60	23.47	1.5			9.960	120	17.568 -0.706			
							9.960	0.0176	0.175	Vel =	3.39	
225 to 200	21.23 22.9	5.60	23.12	1.5			10.150	120	17.037 -0.723			
							10.150	0.0624	0.633	Vel =	6.73	
200			0.0 46.59						16.947	K Factor =	11.32	
226 to 227	19.58 21.22	5.60	23.60	1.5			9.980	120	17.767 -0.710			
							9.980	0.0177	0.177	Vel =	3.41	
227 to 228	21.22 22.88	5.60	23.25	1.5			10.140	120	17.234 -0.719			
							10.140	0.0630	0.639	Vel =	6.76	
228 to 229	22.88 24.14	5.60	23.20	1.5			7.640	120	17.154 -0.546			
							7.640	0.1327	1.014	Vel =	10.11	
229 to 203	24.14 23.17		-9.60	1.5	2T	19.799	0.980 19.799 20.779	120	17.622 0.420			
							20.779	0.1011	2.100	Vel =	8.73	
203			0.0 60.45						20.142	K Factor =	13.47	
230 to 231	19.59 21.24	5.60	24.09	1.5			9.960	120	18.500 -0.715			
							9.960	0.0185	0.184	Vel =	3.48	
231 to 232	21.24 22.9	5.60	23.74	1.5			10.150	120	17.969 -0.719			
							10.150	0.0655	0.665	Vel =	6.91	
232 to 233	22.9 24.16	5.60	23.70	1.5			7.640	120	17.915 -0.546			
							7.640	0.1380	1.054	Vel =	10.33	
233 to 204	24.16 23.17		-6.71	1.5	2T	19.799	1.000 19.799 20.799	120	18.423 0.429			
							20.799	0.1150	2.391	Vel =	9.36	
204			0.0 64.82						21.243	K Factor =	14.06	
201 to 234	24.16 24.56		10.30	1.5			2.440	120	17.409 -0.173			
							2.440	0.0037	0.009	Vel =	1.49	
234 to 235	24.56 26.23	5.60	23.26	1.5			10.190	120	17.245 -0.723			
							10.190	0.0341	0.347	Vel =	4.85	
235 to 236	26.23 24.16	5.60	23.00	1.5	2E T	9.9 9.9	43.540 19.800 63.340	120	16.869 0.897			
							63.340	0.0893	5.657	Vel =	8.17	
236 to 237	24.16 23.17		0.0	1.5	T	9.9	1.010 9.900 10.910	120	23.423 0.429			
							10.910	0.0893	0.974	Vel =	8.17	

Final Calculations : Hazen-Williams

CAROLINA FIRE PROTECTION
BAUCOM BUSINESS PLAZA STORAGE

Page 9
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
237 to 238	23.17 23.17		0.0 56.56	2.5 2.635		9.370 9.370	120 0.0101	24.826 0.0 0.095		Vel = 3.33	
238 to 239	23.17 23.17		56.12 112.68	2.5 2.635		10.330 10.330	120 0.0359	24.921 0.0 0.371		Vel = 6.63	
239 to 240	23.17 23.17		54.27 166.95	2.5 2.635		10.270 10.270	120 0.0743	25.292 0.0 0.763		Vel = 9.82	
240 to 241	23.17 23.17		31.53 198.48	2.5 2.635		10.020 10.020	120 0.1024	26.055 0.0 1.026		Vel = 11.68	
241 to 242	23.17 23.17		17.83 216.31	2.5 2.635		10.000 10.000	120 0.1200	27.081 0.0 1.200		Vel = 12.73	
242 to 243	23.17 23.17		11.15 227.46	2.5 2.635		10.000 10.000	120 0.1318	28.281 0.0 1.318		Vel = 13.38	
243 to 244	23.17 23.17		6.25 233.71	2.5 2.635		10.000 10.000	120 0.1385	29.599 0.0 1.385		Vel = 13.75	
244 to 245	23.17 23.17		2.92 236.63	2.5 2.635		10.000 10.000	120 0.1417	30.984 0.0 1.417		Vel = 13.92	
245 to 246	23.17 23.17		0.99 237.62	2.5 2.635		10.000 10.000	120 0.1429	32.401 0.0 1.429		Vel = 13.98	
246 to 247	23.17 23.17		0.16 237.78	2.5 2.635		10.000 10.000	120 0.1430	33.830 0.0 1.430		Vel = 13.99	
247 to 248	23.17 23.17		0.01 237.79	2.5 2.635		10.000 10.000	120 0.1430	35.260 0.0 1.430		Vel = 13.99	
248 to 249	23.17 23.17		0.14 237.93	2.5 2.635		10.000 10.000	120 0.1432	36.690 0.0 1.432		Vel = 14.00	
249 to 250	23.17 23.17		0.87 238.8	2.5 2.635		10.000 10.000	120 0.1441	38.122 0.0 1.441		Vel = 14.05	
250 to 251	23.17 23.17		2.70 241.5	2.5 2.635		10.000 10.000	120 0.1472	39.563 0.0 1.472		Vel = 14.21	
251 to 252	23.17 23.17		5.86 247.36	2.5 2.635		10.000 10.000	120 0.1539	41.035 0.0 1.539		Vel = 14.55	
252 to 253	23.17 23.17		10.52 257.88	2.5 2.635		9.990 9.990	120 0.1662	42.574 0.0 1.660		Vel = 15.17	

Final Calculations : Hazen-Williams

CAROLINA FIRE PROTECTION
BAUCOM BUSINESS PLAZA STORAGE

Page 10
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
253 to 254	23.17 23.17		16.77 274.65	2.5 2.635			9.980 9.980	120 0.1867	44.234 0.0 1.863		Vel = 16.16	
254 to 222	23.17 23.17		24.62 299.27	2.5 2.635			10.020 10.020	120 0.2189	46.097 0.0 2.193		Vel = 17.61	
222			0.0 299.27						48.290		K Factor = 43.07	
229 to 255	24.14 24.55		9.59 9.59	1.5 1.682			2.490 2.490	120 0.0036	17.622 -0.178 0.009		Vel = 1.38	
255 to 256	24.55 26.22	5.60	23.40 32.99	1.5 1.682			10.130 10.130	120 0.0329	17.453 -0.723 0.333		Vel = 4.76	
256 to 257	26.22 24.14	5.60	23.13 56.12	1.5 1.682	2E T	9.9 9.9	43.540 19.800 63.340	120 0.0881	17.063 0.901 5.578		Vel = 8.10	
257 to 238	24.14 23.17		0.0 56.12	1.5 1.682	T	9.9	0.990 9.900 10.890	120 0.0881	23.542 0.420 0.959		Vel = 8.10	
238			0.0 56.12						24.921		K Factor = 11.24	
233 to 258	24.16 24.56		6.70 6.7	1.5 1.682			2.480 2.480	120 0.0016	18.423 -0.173 0.004		Vel = 0.97	
258 to 259	24.56 26.24	5.60	23.93 30.63	1.5 1.682			10.150 10.150	120 0.0288	18.254 -0.728 0.292		Vel = 4.42	
259 to 260	26.24 24.16	5.60	23.64 54.27	1.5 1.682	2E T	9.9 9.9	43.530 19.800 63.330	120 0.0828	17.818 0.901 5.241		Vel = 7.84	
260 to 239	24.16 23.17		0.0 54.27	1.5 1.682	T	9.9	1.010 9.900 10.910	120 0.0828	23.960 0.429 0.903		Vel = 7.84	
239			0.0 54.27						25.292		K Factor = 10.79	
205 to 261	23.17 25.72		4.91 4.91	1.5 1.682	2T	19.799	10.510 19.799 30.309	120 0.0010	23.681 -1.104 0.029		Vel = 0.71	
261 to 262	25.72 24.15	5.60	26.62 31.53	1.5 1.682	2E T	9.9 9.9	46.670 19.800 66.470	120 0.0303	22.606 0.680 2.014		Vel = 4.55	
262 to 240	24.15 23.17		0.0 31.53	1.5 1.682	T	9.9	1.000 9.900 10.900	120 0.0304	25.300 0.424 0.331		Vel = 4.55	
240			0.0 31.53						26.055		K Factor = 6.18	

Final Calculations : Hazen-Williams

CAROLINA FIRE PROTECTION
BAUCOM BUSINESS PLAZA STORAGE

Page 11
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
206 to 263	23.17 24.17		17.83 17.83	1.5 1.682	3T 2E	29.699 9.9	57.190 39.599 96.789	120 0.0106	25.944 -0.433 1.022		Vel = 2.57	
263 to 241	24.17 23.17		0.0 17.83	1.5	T	9.9	1.010 9.900 10.910	120 0.0105	26.533 0.433 0.115		Vel = 2.57	
241			0.0 17.83						27.081		K Factor = 3.43	
207 to 264	23.17 24.14		11.15 11.15	1.5 1.682	3T 2E	29.699 9.9	57.160 39.599 96.759	120 0.0044	27.805 -0.420 0.428		Vel = 1.61	
264 to 242	24.14 23.17		0.0 11.15	1.5	T	9.9	0.990 9.900 10.890	120 0.0044	27.813 0.420 0.048		Vel = 1.61	
242			0.0 11.15						28.281		K Factor = 2.10	
208 to 265	23.17 24.14		6.25 6.25	1.5 1.682	3T 2E	29.699 9.9	57.160 39.599 96.759	120 0.0015	29.436 -0.420 0.146		Vel = 0.90	
265 to 243	24.14 23.17		0.0 6.25	1.5	T	9.9	0.990 9.900 10.890	120 0.0016	29.162 0.420 0.017		Vel = 0.90	
243			0.0 6.25						29.599		K Factor = 1.15	
209 to 266	23.17 24.17		2.93 2.93	1.5 1.682	3T 2E	29.699 9.9	57.180 39.599 96.779	120 0.0004	30.944 -0.433 0.036		Vel = 0.42	
266 to 244	24.17 23.17		0.0 2.93	1.5	T	9.9	1.010 9.900 10.910	120 0.0004	30.547 0.433 0.004		Vel = 0.42	
244			0.0 2.93						30.984		K Factor = 0.53	
210 to 267	23.17 24.15		0.99 0.99	1.5 1.682	3T 2E	29.699 9.9	57.150 39.599 96.749	120 0	32.396 -0.424 0.004		Vel = 0.14	
267 to 245	24.15 23.17		0.0 0.99	1.5	T	9.9	0.990 9.900 10.890	120 0.0001	31.976 0.424 0.001		Vel = 0.14	
245			0.0 0.99						32.401		K Factor = 0.17	
211 to 268	23.17 24.15		0.17 0.17	1.5 1.682	3T 2E	29.699 9.9	57.160 39.599 96.759	120 0	33.830 -0.424 -0.001		Vel = 0.02	
268 to 246	24.15 23.17		0.0 0.17	1.5	T	9.9	0.990 9.900 10.890	120 0.0001	33.405 0.424 0.001		Vel = 0.02	
246			0.0 0.17						33.830		K Factor = 0.03	

Final Calculations : Hazen-Williams

CAROLINA FIRE PROTECTION
BAUCOM BUSINESS PLAZA STORAGE

Page 12
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
212 to 269	23.17 24.15		0.01	1.5	3T 2E	29.699 9.9	57.140 39.599 96.739	120 0	35.260 -0.424 -0.001			Vel = 0
269 to 247	24.15 23.17		0.0	1.5	T	9.9	1.000 9.900 10.900	120 0.0001	34.835 0.424 0.001			Vel = 0
247			0.0 0.01						35.260			K Factor = 0
213 to 270	23.17 24.14		0.13	1.5	3T 2E	29.699 9.9	57.140 39.599 96.739	120 0	36.690 -0.420 0.0			Vel = 0.02
270 to 248	24.14 23.17		0.0	1.5	T	9.9	0.980 9.900 10.880	120 0	36.270 0.420 0.0			Vel = 0.02
248			0.0 0.13						36.690			K Factor = 0.02
214 to 271	23.17 24.15		0.87	1.5	3T 2E	29.699 9.9	57.170 39.599 96.769	120 0	38.118 -0.424 0.003			Vel = 0.13
271 to 249	24.15 23.17		0.0	1.5	T	9.9	1.000 9.900 10.900	120 0.0001	37.697 0.424 0.001			Vel = 0.13
249			0.0 0.87						38.122			K Factor = 0.14
215 to 272	23.17 24.15		2.70	1.5	3T 2E	29.699 9.9	57.150 39.599 96.749	120 0.0003	39.529 -0.424 0.031			Vel = 0.39
272 to 250	24.15 23.17		0.0	1.5	T	9.9	0.990 9.900 10.890	120 0.0003	39.136 0.424 0.003			Vel = 0.39
250			0.0 2.70						39.563			K Factor = 0.43
216 to 273	23.17 24.15		5.86	1.5	3T 2E	29.699 9.9	57.160 39.599 96.759	120 0.0013	40.890 -0.424 0.130			Vel = 0.85
273 to 251	24.15 23.17		0.0	1.5	T	9.9	1.000 9.900 10.900	120 0.0014	40.596 0.424 0.015			Vel = 0.85
251			0.0 5.86						41.035			K Factor = 0.91
217 to 274	23.17 24.14		10.52	1.5	3T 2E	29.699 9.9	57.150 39.599 96.749	120 0.0040	42.145 -0.420 0.385			Vel = 1.52
274 to 252	24.14 23.17		0.0	1.5	T	9.9	0.990 9.900 10.890	120 0.0040	42.110 0.420 0.044			Vel = 1.52
252			0.0									

Final Calculations : Hazen-Williams

CAROLINA FIRE PROTECTION
BAUCOM BUSINESS PLAZA STORAGE

Page 13
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
252			10.52						42.574		K Factor = 1.61	
218 to 275	23.17 24.14		16.77	1.5	3T 2E	29.699 9.9	57.150 39.599	120	43.219 -0.420		Vel = 2.42	
275 to 253	24.14 23.17		16.77	1.682			96.749	0.0094	0.912			
275 to 253	24.14 23.17		0.0	1.5	T	9.9	0.990 9.900	120	43.711 0.420		Vel = 2.42	
253			0.0 16.77						44.234		K Factor = 2.52	
219 to 276	23.17 24.15		24.63	1.5	3T 2E	29.699 9.9	57.160 39.599	120	44.032 -0.424		Vel = 3.56	
276 to 254	24.15 23.17		24.63	1.682			96.759	0.0192	1.856			
276 to 254	24.15 23.17		0.0	1.5	T	9.9	1.000 9.900	120	45.464 0.424		Vel = 3.56	
254			0.0 24.63						46.097		K Factor = 3.63	
220 to 277	23.17 23.17		44.85	2			10.000	120	44.525 0.0		Vel = 3.94	
277 to 278	23.17 24.16		44.85	2.157			10.000	0.0173	0.173			
277 to 278	23.17 24.16		0.0	1.5	3T 2E	29.699 9.9	57.190 39.599	120	44.698 -0.429		Vel = 6.48	
278 to 223	24.16 23.17		44.85	1.682			96.789	0.0582	5.630			
278 to 223	24.16 23.17		0.0	1.5	T	9.9	1.000 9.900	120	49.899 0.429		Vel = 6.48	
223			0.0 44.85						50.962		K Factor = 6.28	