


MEMORANDUM

TO: To Whom it May Concern

FROM: C.H. Moss, P.E.

DATE: November 21, 2024

RE: Foundation Plan Drawing No. 3843 S-1
Baucom Business Plaza
Fuquay Varina, NC



A vertical control joint in the basement wall of the referenced project is acceptable. The wall's structural integrity is not affected by the construction joint. A key way and dowels are placed in the joint to prevent any uneven movements in the two concrete pours.

If you have further questions please feel free to call