

APPENDIX G

DESIGN PROFESSIONAL INSPECTION FORM

RECORD OF THE INSPECTION OF A COMPONENT OR ELEMENT BY A NC LICENSED ARCHITECT OR ENGINEER

Project Information:

Residential Single-Family Project: No	Commercial Project: Yes
Code Enforcement Project No:	Permit No: BCOM2404-0010
Project Name: BAUCOM Business Park	Owner: Jim Moore
Project Address: 11132 US 401 Fuquay Varina	Suite No:
Date Inspected: 11-06-2024	Contractor Name: Cornerstone Builders of NC
Component Inspected: Rear and side footers. Detail Section 1/S-1 was inspected	

Responsible Licensed NC Architect or NC Engineer

Name:	Britt McCurry		
Firm Name:	B.A. McCurry Engineering		
Phone Numbers:	Office: 336.223.4604	Mobile:	
Email Address:	britt.mccurry@bamccurryengineering.com 329		
Mailing Address:	Brinkley Cir, Mebane, NC 27302		

APPLICABLE CODE:

2018 NC Residential Code

2018 NCBC = 2018 NC Building Code; 2018 NCRC = 2018 NC Residential Code

Describe Element/Component/Type of Inspection: *

The 1/S-1 footings were inspected and the subgrade compaction was tested and both items are acceptable per the plans dated 4/15/24

*(subgrade form/letter may also be required)


Attestation/Signature:

By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per G.S. 160D-11-6 and is in compliance with the Code or other proposal of the architect or engineer for the project. This inspection is in compliance with all of the requirements of the above referenced code. Attach any additional documents if needed.

Britt McCurry, PE

Licensed Architect or Engineer 11-06-2024

Britt McCurry



Inspection Department disclaimer:

Upon the receipt of a signed written document as required under subsection (a) of G.S. 160D-11-1, Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.