



Harnett County Fire Marshals Office

Occupancy: **365 Stores of Coats**
 Occupancy ID: **4300SHOR000003**
 Address: **337 N MCKINLEY ST COATS NC 27521**

Inspection Type: **108 - ALE/ABC Inspection**
 Inspection Date: **4/30/2024** By: **Sullivan, Roger (2312)**
 Time In: **10:00** Time Out: **11:00**
 Authorized Date: **04/30/2024** By: **Sullivan, Roger (2312)**

Form: Harnett County
 General Fire Inspection

Next Inspection Date: **05/30/2024 101 - Fire Protection, 1st Reinspection**

Inspection Description:

Harnett County Fire Inspection

Inspection Topics:

Building Services and Systems

Electrical Equipment, Wiring and Hazards
 Section 605

Status: FAIL

Notes: 605.5 Remove extension cords supplying pepsi cooler next to front door and to old cigarette rack over front sales counter, extension cords can not be used as a substitute for permanent wiring. Recommend use surge protector plugged directly into an outlet or install more electrical outlets where needed.

Other Hazards/Violations

Other Violation

See Notes

Status: FAIL

Notes: 605.4.2 Surge protectors must be plugged directly into an electrical outlet, not into another surge protector in rear stockroom at electrical panels.

Other Violation

See Notes

Status: FAIL

Notes: 5303.5.3 Secure helium tank with rope or chain to the wall to prevent from falling over in old office.

Additional Time Spent on Inspection:

Category	Start Date / Time	End Date / Time
----------	-------------------	-----------------

Notes: No Additional time recorded

Total Additional Time: 0 minutes

Inspection Time: 60 minutes

Total Time: 60 minutes

Summary:

Overall Result: Violation Notice Issued

Inspector Notes:

Closing Notes:

Harnett County has adopted The Compliance Engine as the prescribed method for record keeping in accordance with Section 107, of the North Carolina Fire Prevention Code. Records of periodic inspections, tests, servicing, and other operations and maintenance for all life safety systems shall be submitted to The Compliance Engine.

Inspector:

Name: Sullivan, Roger
Rank: Deputy Fire Marshal
Work Phone(s): None on file
Email(s): rsullivan@harnett.org
Sullivan, Roger:



Signed on: 04/30/2024 14:03

Signature _____

Date _____

Representative Signature:

Signature _____

Date _____