



**Burke Design Group, pa**  
**Consulting Engineers**

bdgengineers.com  
(919) 771-1916 (919) 779--0826 fax  
3305-109 Durham Dr.  
Raleigh, NC 27603

Date: August 19, 2024  
Project: Grain Dealers Brewery  
100 N 13th St, Bay K  
Erwin, North Carolina

Comment Response:

Electrical:

1. Need egress lighting at exterior side of egress doors (battery Backup)  
**BDG Response: Sheet E2 updated to show 'E' fixtures shifted for clarity. 'E' fixtures are emergency/normal.**
2. Lights in podcast booth shown as wall packs on ceiling? Also need emergency lighting in podcast area  
**BDG Response: Sheet E2 updated to specify 'G' fixtures in mezzanine and to show emergency lighting in podcast area.**
3. Panel A schedule shows 100A main for 400 A panel.  
**BDG Response: Sheet E4 updated to show 400A main in panel 'A'**
4. Circuit 2 from main disconnect to first panel "m" does not show a neutral.  
**BDG Response: Sheet E4 updated to revise riser wiring**



**Burke Design Group, pa**  
**Consulting Engineers**

---

bdgengineers.com  
(919) 771-1916 (919) 779--0826 fax  
3305-109 Durham Dr.  
Raleigh, NC 27603

Mechanical:

1. Provide specifications on under counter ware washer.

**BDG Response: See Arch Response**

Please feel free to contact me on my cell phone at (919) 618-0717 with any questions or concerns.

Sincerely,

Ben E. Burke, PE

ben@bdg-nc.com