



Phone: (252) 438-8778

P.O. Box 3301 • 115 Young Street, Suite C
Henderson, NC 27536

www.kilianengineering.com

Blue Sprig, Cameron NC

October 11, 2024

To Whom It May Concern:,

We offer no objection to locating the heat pump on the ground instead of the roof. The mechanical contractor shall verify that the new location does not exceed the manufacturer's maximum line set requirements for the refrigerant lines.

Respectfully,

John B. Tyler

Senior Design Manager

KILIAN ENGINEERING, INC.

Company: (252) 438-8778 | tyler@kilianengineering.com

Jacob Hamilton, PE

Senior Engineer

KILIAN ENGINEERING, INC.

Company: (252) 438-8778 | jhamilton@kilianengineering.com

