

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550
fax: 910-893-9429

September 10, 2024

Jose Perez
21 Mosswood Ct.
Clayton, NC 27527

RE: Blue Agave Mexican Grill

Dear Mr. Perez,

A plan review application was received by this office concerning the construction of the above referenced facility. The application is not approved at this time. Additional information is needed and is detailed below:

- A complete set of equipment specification sheets to correspond to items listed in the equipment schedule on page F2 of the plans was not submitted.
- A proposed menu was not included.

Please clarify the following:


- Will a prerinse sink/sprayer be provided at the dish machine?
- Will kegs be stored in the walk-in cooler? Where will empty kegs be stored?
- Please describe use of #72, power drive unit.

The can wash is located in close proximity to a clean utensil shelf and three compartment sink. Ideally, the can wash would be located outside the back door. This would minimize potential cross contamination and open up area for additional shelving. If this is not feasible, then perhaps it could be moved to the back corner of the room beside the water heater. Please indicate if you would consider moving the can wash to a more appropriate location.

Any item not shown on the plans or referenced above will be required to comply with 15A NCAC 18A .2600, **“Rules Governing the Sanitation of Food Service Establishments”** and the **2017 NC Food Code**. This review does not cover any other aspects of construction regulated by other jurisdictions.

If you require further assistance, please call 910-893-7547.

Sincerely,



Cindy Pierce, REHS
Environmental Health Section
Harnett County Health Department