

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550

fax: 910-893-9429

September 27, 2024

D. Clugston, Inc
Joey Davis
2506 Reliance Ave.
Apex, NC 27539

Re: Powell Amenity Center and Pool

To Whom It May Concern:

This department has reviewed the revised plans you submitted for the Powell swimming pool to be constructed at 212 Perseus St., Lillington. This plan review was conducted in accordance with the current North Carolina Rules Governing Public Swimming Pools (15A NCAC 18A .2500).

The plans are not approved as drawn. The following items need to be addressed:

- The main drain line as drawn is specified as a 2" line. The main drain line shall be a 4" minimum line.
- The Circulation and Feature SOFAs have not been revised on the plans to show items indicated in a letter dated August 27. The Circulation SOFA cannot be approved as drawn.

If you have any questions regarding this matter or if I can provide any additional assistance, please call me at 910-893-7547

Sincerely,



Cindy Pierce, REHS
Environmental Health Specialist