

Professional Engineers Specializing in Civil Engineering & Land Development 312 W. Millbrook Road, Suite 237 Raleigh, NC 27609 Phone: 919-602-1894 Fax: 919-676-0301

March 17, 2025

Re: Providence Creek Subdivision

1370 Ballard Road Harnett County, NC Permit #BCOM2410-002 Segmental Retaining Wall Certification

To Whom It May Concern:

Pursuant to the approved bearing capacity for the footings and compaction testing in the reinforced zones for the above referenced location, per the onsite geotechnical engineer NV5, and that the walls appear to be constructed per Segmental Retaining Wall Specifications and Requirements and per the profile designs prepared by Venture Engineering, PA, the wall installations, thru inspections, have met all the criteria and it is in my opinion shall function as designed.

The wall design in which two (2) Ridge Rock Segmental block retaining walls, with a near vertical batter (1/8" setback per 8" height) were installed. One foot of #57 washed stone was installed behind the retaining walls to prevent hydrostatic pressure build-up behind the walls. A combination of Import structural and onsite fill was used for backfilling the retaining walls in the reinforced zone.

Thanks, and let me know if you have any questions.

VENTURE ENGINEERING, P.A.

Mark J. Magrath, PE

Principal

SEAL PARK MAGRAMARK MAGRAMAR MAGRAMA