



# Permit Reviews

## Harnett County

**Permit Number: BCOM2411-0001**

Description: **40 x 65 pad for fuel tank storage/(3) 4000 gal, (1) 550 gal/**

Applied: **11/4/2024**

Approved:

Site Address: **742 CLAUDE WHITE RD**

Issued:

Finalized:

City, State Zip Code: **CAMERON, NC 28326**

Status: **RECEIVED**

Applicant: **GS Materials, INC**

Parent Permit:

Owner: **KIRKPATRICK ASSOCIATES**

Parent Project:

Contractor: **GS Materials, INC**

Details:

### LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: ALL						
11/18/2024	11/27/2024	12/4/2024	FIRE MARSHAL	Roger Sullivan	DISAPPROVED	see attached letter
Notes: See attached letter.						
Review Group: AUTO						
11/4/2024	11/4/2024		COMMERCIAL INTAKE	CP Bucket	APPROVED	
Notes:						
11/4/2024	11/5/2024	11/19/2024	COMMERCIAL BUILDING REVIEW	Brad Sutton	DISAPPROVED	
Notes: Need more information. Are the tanks going on a concrete pad? On the dirt? Do you have compaction information for the site if installed on grade? Do you have a design for the concrete support slab if on concrete?						
11/4/2024	11/13/2024	11/19/2024	FIRE MARSHAL	Fire Bucket	DISAPPROVED	see notes
Notes: Need specification & data sheets on tanks, fuel dispensers, emergency controls, secondary containment dimensions around tanks, tank emergency venting & overfill protection and impact protection around tanks.						
11/5/2024	11/6/2024	11/19/2024	COMMERCIAL BUILDING REVIEW	Brad Sutton	DISAPPROVED	
Notes: Plan shows concrete pad with roof and building (enclosed). These structures require permits. Provide a full set of construction drawings from footing and slab through roof.						
11/18/2024	11/18/2024	12/4/2024	COMMERCIAL BUILDING REVIEW	Brad Sutton	DISAPPROVED	
Notes: Still no building plans in attachments						





# Permit Reviews

## Harnett County

11/18/2024			COMMERCIAL BUILDING REVIEW	Building Bucket		
------------	--	--	-------------------------------	-----------------	--	--

Notes:

