



Permit Inspections

Harnett County

Permit Number: **BCOM2501-0004**

Description: **(2) Walk in cabinets on 9 x 15 concrete slab w/in cmpd Dish**

Applied: **1/14/2025**

Approved: **1/24/2025**

Site Address: **538 SMITH PRINCE RD**

Issued: **1/30/2025**

Finaled: **9/16/2025**

City, State Zip Code: **FUQUAY-VARINA, NC 27526**

Status: **FINALED**

Applicant: **Katie Caummisar on behalf of TMobile**

Parent Permit:

Owner: **SEARS LINDA L**

Parent Project:

Contractor: **Qwiksite Ink.**

Details:

Land Use paid for on LUP permit. LUP2412-0003

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			FOOTING	Justin Ryan McLeod		
Notes:						
			ROUGH IN	Justin Ryan McLeod		
Notes:						
			MONO SLAB	Justin Ryan McLeod		
Notes:						
	4/22/2025	4/22/2025	SLAB	Justin Ryan McLeod	APPROVED	
Notes:						
GATE CODE 1760						
	4/22/2025	4/22/2025	UNDERGROUND	Justin Ryan McLeod	DISAPPROVED	
Notes:						
Need all bonds completed at front side of slab and same on back side where equipment grounds meet at the grid. Can cover all but these areas. Crew stated there Cadweld mold was broke and they are trying to find another one.						
	4/25/2025	4/25/2025	UNDERGROUND	Justin Ryan McLeod	APPROVED	
Notes:						
	4/30/2025	4/30/2025	TEMP POWER CERTIFICATION	Justin Ryan McLeod	APPROVED	
Notes:						



Permit Inspections

Harnett County

	9/16/2025	9/16/2025	FINAL**	Daniel L Floyd	APPROVED	
Notes:						

