

Automatic Fire Sprinkler Systems



3101-310 Poplarwood Court - Raleigh, NC 27604

Ph: 919-212-2722 Fax: 919-212-2720

www.regionalfirenc.com

Ajith Zacharias, CET^a

Certified Engineering Tech.

NICET #120860

Water-Based Systems Layout, Level III



HYDRAULIC CALCULATIONS

For:

**CFVHS Harnett Health Dorothea Dix Adolescent
Psychiatric Unit
Crested Iris Drive
Lillington, NC 27546**

Submitted by:

Thomas Crowder

Automatic Fire Sprinkler Systems



Hydraulic Overview

Job Number: 25011 - CFVH Dorothea Dix


Report Description: Light Hazard (1)

Job		
Job Number	25011	
Designer	THOMAS CROWDER	
Job Name:	CFVHS - DOROTHEA DIX ADOLESCENT PSYCHIATRIC UNIT	Phone 919-212-2722
Address 1	CRESTED IRIS DRIVE	FAX
Address 2	LILLINGTON, NC 27546	State Certification/License Number
Address 3		AHJ
		Job Site/Building

System		
Density	0.10gpm/ft ²	
Area of Application	1500.00ft ² (Actual 972.09ft ²)	
Most Demanding Sprinkler Data	5.6K K-Factor 14.82gpm at 7.000psi	
Hose Streams	100.00gpm	
Coverage Per Sprinkler	225.00ft ²	Number Of Sprinklers Calculated 10
		Number Of Nozzles Calculated 0
System Pressure Demand	61.195psi	
System Flow Demand	159.98gpm	
Total Demand	259.98gpm @ 61.195psi	
Pressure Result	+77.755psi (56.0%)	

Supplies						Check Point Gauges			
<u>Node</u>	<u>Name</u>	<u>Flow(gpm)</u>	<u>Hose Flow(gpm)</u>	<u>Static(psi)</u>	<u>Residual(psi)</u>	<u>Identifier</u>	<u>Pressure(psi)</u>	<u>K-Factor(K)</u>	<u>Flow(gpm)</u>
1	Water Supply	1592.00gpm	100.00gpm	140.000psi	110.000psi	BOR (16)	49.194psi	22.81K	159.98gpm

25011_CPVHS HARNETT DOROTHEA DIX BH.cad	Water Supply at Node 1 (1592.00gpm, 0.00gpm, 140.000psi, 110.000psi)
---	--





Hydraulic Summary


Job Number: 25011 - CFVH Dorothea Dix

Report Description: Light Hazard (1)

Job												
Job Number 25011					Designer THOMAS CROWDER							
Job Name: CFVHS - DOROTHEA DIX ADOLESCENT PSYCHIATRIC UNIT					State Certification/License Number							
Address 1 CRESTED IRIS DRIVE					AHJ							
Address 2 LILLINGTON, NC 27546					Job Site/Building							
Address 3					Drawing Name 25011_CPVHS HARNETT DOROTHEA DIX BH.cad							
System					Remote Area(s)							
Most Demanding Sprinkler Data 5.6K K-Factor 14.82gpm at 7.000psi					Occupancy Light Hazard			Job Suffix CFVH Dorothea Dix				
Hose Allowance At Source 100.00gpm					Density 0.10gpm/ft ²			Area of Application 1500.00ft ² (Actual 972.09ft ²)				
Additional Hose Supplies <table><thead><tr><th>Node</th><th>Flow(gpm)</th></tr></thead><tbody></tbody></table>					Node	Flow(gpm)	Number Of Sprinklers Calculated 10			Number Of Nozzles Calculated 0		Coverage Per Sprinkler 225.00ft ²
					Node	Flow(gpm)						
AutoPeak Results: Pressure For Remote Area(s) Adjacent To Most Remote Area												
Total Hose Streams 100.00gpm												
System Flow Demand 159.98gpm			Total Water Required (Including Hose Allowance) 259.98gpm									
Maximum Pressure Unbalance In Loops 0.000psi												
Maximum Velocity Above Ground 14.05fps between nodes 13 and 10												
Maximum Velocity Under Ground 1.66fps between nodes 9 and 16												
Volume capacity of Wet Pipes 4690.10gal			Volume capacity of Dry Pipes									
Supplies												
Node	Name	Hose Flow (gpm)	Static (psi)	Residual (psi)	@	Flow (gpm)	Available (psi)	@	Total Demand (gpm)	Required (psi)	Safety Margin (psi)	
1	Water Supply	100.00gpm	140.000psi	110.000psi		1592.00gpm	138.950psi		259.98gpm	61.195psi	77.755psi	
Contractor												
Contractor Number 21		Contact Name THOMAS CROWDER					Contact Title PM					
Name of Contractor: REGIONAL FIRE SERVICES OF NC, LLC						Phone 919-212-2722			Extension			
Address 1 3101-310 POPLARWOOD COURT						FAX						
Address 2 RALEIGH, NC 27604						E-mail THOMAS@REGIONALFIRENC.COM						
Address 3						Web-Site						



Water Supply at Node 1




System Demand
Available Water Supply

Job Name: CFVHS - DOROTHEA DIX ADOLESCENT PSYCHIATRIC UNIT

Job Number: 25011 - CFVH Dorothea Dix

Report Description: Light Hazard (1)

Remote Area Number: 1



Curve	Data Point	Hydraulic Calculation Results	Additional Data
1	1B 1C	Required Pressure at System Demand: 61.195psi @ 159.98gpm Required Pressure at System Demand (Including Hose Allowance at Source): 61.195psi @ 259.98gpm	Available Flow @ 20 PSI: 3365.55gpm
3	3A 3B 3C	Available Static Pressure at Water Supply at Node 1: 140.000psi Available Residual Pressure at System Demand: 110.000psi @ 1592.00gpm Available Residual Pressure & Flow at Water Supply at Node 1: 110.000psi @ 1592.00gpm	



Summary Of Outflowing Devices

Job Number: 25011 - CFVH Dorothea Dix
Report Description: Light Hazard (1)

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
Sprinkler	101	17.52gpm	14.82gpm	5.6K	9.783psi			
Sprinkler	102	18.69gpm	14.82gpm	5.6K	11.138psi			
Sprinkler	103	14.94gpm	14.82gpm	5.6K	7.119psi			
Sprinkler	104	14.89gpm	14.82gpm	5.6K	7.070psi			
Sprinkler	105	15.30gpm	14.82gpm	5.6K	7.464psi			
Sprinkler	106	14.83gpm	14.82gpm	5.6K	7.016psi			
Sprinkler	107	15.25gpm	14.82gpm	5.6K	7.419psi			
➡ Sprinkler	108	14.82gpm	14.82gpm	5.6K	7.000psi			
Sprinkler	109	17.06gpm	14.82gpm	5.6K	9.285psi			
Sprinkler	110	16.68gpm	14.82gpm	5.6K	8.873psi			

➡ Most Demanding Sprinkler Data



Node Analysis

Job Number: 25011 - CFVH Dorothea Dix
Report Description: Light Hazard (1)

Node	Elevation(foot)	Fittings	Pressure(psi)	Discharge(gpm)
1	-3'-0	S	61.195psi	159.98gpm
101	9'-1½	Spr(-9.783psi)	9.783psi	17.52gpm
102	9'-0	Spr(-11.138psi)	11.138psi	18.69gpm
103	9'-0	Spr(-7.119psi)	7.119psi	14.94gpm
104	9'-0	Spr(-7.070psi)	7.070psi	14.89gpm
105	9'-0	Spr(-7.464psi)	7.464psi	15.30gpm
106	9'-0	Spr(-7.016psi)	7.016psi	14.83gpm
107	9'-0	Spr(-7.419psi)	7.419psi	15.25gpm
108	9'-0	Spr(-7.000psi)	7.000psi	14.82gpm
109	9'-0	Spr(-9.285psi)	9.285psi	17.06gpm
110	9'-0	Spr(-8.873psi)	8.873psi	16.68gpm
2	9'-8	PO(5'-0)	11.860psi	
3	9'-8	PO(5'-0)	12.113psi	
4	9'-8	E(2'-0)	7.437psi	
5	9'-8	PO(5'-0)	7.629psi	
6	9'-8	PO(5'-0)	8.048psi	
7	9'-8	E(2'-0)	7.391psi	
8	9'-8	PO(5'-0)	7.580psi	
9	-3'-0	T(47'-3½)	61.192psi	
10	9'-8	PO(6'-0)	15.216psi	
11	9'-8	PO(5'-0)	10.064psi	
12	9'-8	PO(5'-0)	7.994psi	
13	1'-2		49.122psi	
14	9'-8	PO(5'-0)	10.170psi	
15	9'-8	PO(6'-0)	14.065psi	
16	1'-0	BOR	49.194psi	
17	9'-8	PO(6'-0)	13.779psi	



Hydraulic Analysis

Job Number: 25011 - CFVH Dorothea Dix

Report Description: Light Hazard (1)

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss		Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	
Route 1								
DR	1.0490	14.82gpm	5.50fps	120		0.074703	2'-7½	Pf 0.868psi
108	9'-0	14.82gpm	5.6K	7.000psi		Sprinkler,	9'-0	Pe -0.288psi
8	9'-8			7.580psi		2E(2'-0), PO(5'-0)	11'-7½	Pv
BL	1.3800	29.65gpm	6.36fps	120		0.070906	5'-10	Pf 0.414psi
8	9'-8	14.83gpm		7.580psi		Flow (q) from Route 2		Pe
12	9'-8			7.994psi			5'-10	Pv
BL	1.3800	44.90gpm	9.63fps	120		0.152808	14'-3	Pf 2.176psi
12	9'-8	15.25gpm		7.994psi		Flow (q) from Route 5		Pe 0.000psi
14	9'-8			10.170psi			14'-3	Pv
BL	1.3800	61.58gpm	13.21fps	120		0.274129	7'-2	Pf 3.609psi
14	9'-8	16.68gpm		10.170psi		Flow (q) from Route 7	6'-0	Pe
17	9'-8			13.779psi		PO(6'-0)	13'-2	Pv
CM	2.1570	61.58gpm	5.41fps	120		0.031140	9'-2	Pf 0.286psi
17	9'-8			13.779psi				Pe
15	9'-8			14.065psi			9'-2	Pv
CM	2.1570	123.78gpm	10.87fps	120		0.113291	10'-2	Pf 1.150psi
15	9'-8	62.19gpm		14.065psi		Flow (q) from Route 3		Pe
10	9'-8			15.216psi			10'-2	Pv
CM	2.1570	159.98gpm	14.05fps	120		0.182113	89'-7	Pf 30.213psi
10	9'-8	36.20gpm		15.216psi		Flow (q) from Route 9	76'-3½	Pe 3.693psi
13	1'-2			49.122psi		2T(12'-3½), 5E(6'-2), sCV(13'-6½), BV(7'-4½)	165'-11	Pv
DY	6.2800	159.98gpm	1.66fps	140		0.000752	0'-0	Pf 0.000psi
13	1'-2			49.122psi				Pe 0.072psi
16	1'-0			49.194psi		BOR	0'-0	Pv
UG	6.2800	159.98gpm	1.66fps	140		0.000752	178'-5	Pf 10.263psi
16	1'-0			49.194psi			171'-9½	Pe 1.734psi
9	-3'-0			61.192psi		3E(22'-1), 4EE(11'-0½), 3GV(4'-8½), BFP(-10.000psi), T(47'-3½)	350'-2	Pv
UG	12.4600	159.98gpm	0.42fps	140		0.000027	139'-7½	Pf 0.004psi
9	-3'-0			61.192psi				Pe
1	-3'-0			61.195psi		S	139'-7½	Pv
		100.00gpm				Hose Allowance At Source		
1		259.98gpm						
Route 2								
DR	1.0490	14.83gpm	5.51fps	120		0.074866	2'-10	Pf 0.663psi
106	9'-0	14.83gpm	5.6K	7.016psi		Sprinkler,	6'-0	Pe -0.288psi
7	9'-8			7.391psi		3E(2'-0)	8'-10	Pv
BL	1.3800	14.83gpm	3.18fps	120		0.019690	9'-7½	Pf 0.189psi
7	9'-8			7.391psi				Pe
8	9'-8			7.580psi			9'-7½	Pv
Route 3								
DR	1.0490	14.89gpm	5.53fps	120		0.075394	2'-3	Pf 0.847psi
104	9'-0	14.89gpm	5.6K	7.070psi		Sprinkler,	9'-0	Pe -0.288psi
5	9'-8			7.629psi		2E(2'-0), PO(5'-0)	11'-3	Pv
BL	1.3800	29.83gpm	6.40fps	120		0.071710	5'-10	Pf 0.419psi
5	9'-8	14.94gpm		7.629psi		Flow (q) from Route 4		Pe
6	9'-8			8.048psi			5'-10	Pv
BL	1.3800	45.13gpm	9.68fps	120		0.154245	13'-1	Pf 2.016psi
6	9'-8	15.30gpm		8.048psi		Flow (q) from Route 6		Pe -0.000psi
11	9'-8			10.064psi			13'-1	Pv
BL	1.3800	62.19gpm	13.34fps	120		0.279179	8'-4	Pf 4.001psi
11	9'-8	17.06gpm		10.064psi		Flow (q) from Route 8	6'-0	Pe
15	9'-8			14.065psi		PO(6'-0)	14'-4	Pv
Route 4								
DR	1.0490	14.94gpm	5.55fps	120		0.075872	2'-0	Pf 0.607psi
103	9'-0	14.94gpm	5.6K	7.119psi		Sprinkler,	6'-0	Pe -0.288psi
4	9'-8			7.437psi		3E(2'-0)	8'-0	Pv
BL	1.3800	14.94gpm	3.20fps	120		0.019955	9'-7½	Pf 0.192psi
4	9'-8			7.437psi				Pe 0.000psi
5	9'-8			7.629psi			9'-7½	Pv
Route 5								
DR	1.0490	15.25gpm	5.66fps	120		0.078827	1'-11½	Pf 0.864psi
107	9'-0	15.25gpm	5.6K	7.419psi		Sprinkler,	9'-0	Pe -0.288psi
12	9'-8			7.994psi		2E(2'-0), PO(5'-0)	10'-11½	Pv
Route 6								



Hydraulic Analysis

Job Number: 25011 - CFVH Dorothea Dix

Report Description: Light Hazard (1)

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss		Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	
DR	1.0490	15.30gpm	5.68fps	120		0.079271		
105	9'-0	15.30gpm	5.6K	7.464psi		Sprinkler,		
6	9'-8			8.048psi		2E(2'-0), PO(5'-0)		
Route 7								
DR	1.0490	16.68gpm	6.19fps	120		0.093024		
110	9'-0	16.68gpm	5.6K	8.873psi		Sprinkler,		
14	9'-8			10.170psi		3E(2'-0), PO(5'-0)		
Route 8								
DR	1.0490	17.06gpm	6.33fps	120		0.097013		
109	9'-0	17.06gpm	5.6K	9.285psi		Sprinkler,		
11	9'-8			10.064psi		2E(2'-0), PO(5'-0)		
Route 9								
DR	1.0490	17.52gpm	6.50fps	120		0.101812		
101	9'-1½	17.52gpm	5.6K	9.783psi		Sprinkler,		
2	9'-8			11.860psi		4E(2'-0), PO(5'-0)		
BL	1.3800	17.52gpm	3.76fps	120		0.026777		
2	9'-8			11.860psi				
3	9'-8			12.113psi				
BL	1.3800	36.20gpm	7.77fps	120		0.102603		
3	9'-8	18.69gpm		12.113psi		Flow (q) from Route 10		
10	9'-8			15.216psi		PO(6'-0)		
Route 10								
DR	1.0490	18.69gpm	6.94fps	120		0.114798		
102	9'-0	18.69gpm	5.6K	11.138psi		Sprinkler,		
3	9'-8			12.113psi		2E(2'-0), PO(5'-0)		

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

C Value Multiplier

$$\left(\frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51



Hydraulic Analysis

Job Number: 25011 - CFVH Dorothea Dix

Report Description: Light Hazard (1)

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss		Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	

Pipe Type Legend		Units Legend		Fittings Legend	
AO	Arm-Over	Diameter	Inch	ALV	Alarm Valve
BL	Branch Line	Elevation	Foot	AngV	Angle Valve
CM	Cross Main	Flow	gpm	b	Bushing
DN	Drain	Discharge	gpm	BaV	Ball Valve
DR	Drop	Velocity	fps	BFP	Backflow Preventer
DY	Dynamic	Pressure	psi	BV	Butterfly Valve
FM	Feed Main	Length	Foot	C	Cross Flow Turn 90°
FR	Feed Riser	Friction Loss	psi/Foot	cplg	Coupling
MS	Miscellaneous	HWC	Hazen-Williams Constant	Cr	Cross Run
OR	Outrigger	Pt	Total pressure at a point in a pipe	CV	Check Valve
RN	Riser Nipple	Pn	Normal pressure at a point in a pipe	DeV	Deluge Valve
SN	Swing Nipple	Pf	Pressure loss due to friction between points	DPV	Dry Pipe Valve
SP	Sprig	Pe	Pressure due to elevation difference between indicated points	E	90° Elbow
ST	Stand Pipe	Pv	Velocity pressure at a point in a pipe	EE	45° Elbow
UG	Underground			Ee1	11¼° Elbow
				Ee2	22½° Elbow
				f	Flow Device
				fd	Flex Drop
				FDC	Fire Department Connection
				fE	90° FireLock(TM) Elbow
				fEE	45° FireLock(TM) Elbow
				flg	Flange
				FN	Floating Node
				fT	FireLock(TM) Tee
				g	Gauge
				GloV	Globe Valve
				GV	Gate Valve
				Ho	Hose
				Hose	Hose
				HV	Hose Valve
				Hyd	Hydrant
				LtE	Long Turn Elbow
				mecT	Mechanical Tee
				Noz	Nozzle
				P1	Pump In
				P2	Pump Out
				PIV	Post Indicating Valve
				PO	Pipe Outlet
				PrV	Pressure Relief Valve
				PRV	Pressure Reducing Valve
				red	Reducer/Adapter
				S	Supply
				sCV	Swing Check Valve
				SFx	Seismic Flex
				Spr	Sprinkler
				St	Strainer
				T	Tee Flow Turn 90°
				Tr	Tee Run
				U	Union
				WirF	Wirsbo
				WMV	Water Meter Valve
				Z	Cap



Report Description: Light Hazard (1)

Gauge	Available Static Pressure (psi)	Available Residual Pressure (psi)	Required Residual Pressure (nsi)	K-Factor(K)	Flow(gpm)	Elevation(Foot)
BOR (16)	128.266psi	126.949psi	49.194psi	22.81K	159.98gpm	1'-0

Hydrant Flow Test Report

Test Date 2/26/2025

Test Time 10:10 AM

Location

Crested Iris Drive

Tested by

Thomas Crowder & Ajith Zacharias
Regional Fire Services of NC, LLC
Witnessed by: Apex Fire Department

Notes

Witnessed by Harnett Regional Water Department


Read Hydrant

140 psi **static pressure**
110 psi **residual pressure**
hydrant elevation

Flow Hydrant(s)


Outlet	Elev	Size	C	Pitot Pressure	Flow
#1		2.5	.9	90	1592 gpm

Flow Graph





Crested Iris Dr



Imagery ©2025 Airbus, Maxar Technologies, Map data ©2025 100 ft

