

Appendix G

DESIGN PROFESSIONAL INSPECTION FORM

RECORD OF THE INSPECTION OF A COMPONENT OR ELEMENT BY A NC LICENSED ARCHITECT OR ENGINEER

Project Information:

Residential Single-Family Project: Y N	Commercial Project: <input checked="" type="checkbox"/> N
Code Enforcement Project No:	Permit No:
Project Name: Harmony Baptist Church	Owner: Harmony Baptist Church
Project Address: NC 210 Bunn Level, NC	Suite No:
Date Inspected: January 27, 2026	Contractor Name: Rodney Gregory
Component Inspected: Footing,	

Responsible Licensed NC Architect or NC Engineer

Name:	C. Gregory Bagley
Firm Name:	Greg Bagley Engineer
Phone Numbers:	Office: 919-609-0300 Mobile:
Email Address:	Gdb.greg@gmail.com
Mailing Address:	32 E. Depot Street Suite B Angier, NC 27501

APPLICABLE CODE: 2018 NCBC

2018 NCBC = 2018 NC Building Code; 2018 NCRC = 2018 NC Residential Code


Describe Element/Component/Type of Inspection: * **Footings**, inspected the depth and connections along with details used in connections. Mix to be dryer due to ground water. Total of 6 footings with Sona tube for pier footing provided.

Attestation/Signature:

By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per subsection (b2) of NC G.S. 153A352 and is in compliance with the Code or other proposal of the architect or engineer for the project. This inspection is in compliance with all of the requirements of the above referenced Code. Attach any additional documents if needed.

C. Gregory Bagley

C. Gregory Bagley
Licensed Architect or Engineer



Inspection Department disclaimer:

Upon the receipt of a signed written document as required under subsection (a) of Article 160A-413.5., Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.

12/2019