

PO Box 37008, Charlotte, NC 28237 • Phone: 704-334-7363 • Fax: 704-347-0093 • www.shultzeg.com • info@shultzeg.com

April 25, 2025

Re: Serenity Amenity

Dear Cindy,

Please find our responses in RED:

This department is reviewing the plan you submitted for the Serenity Amenity swimming pool to be constructed at 325 Streamside Terrace, Fuquay Varina. This plan review is being conducted in accordance with the current North Carolina Rules Governing Public Swimming Pools (15A NCAC 18A .2500).

Please provide additional information on the following items:

-Tile in restrooms is listed as ceramic and/or porcelain. Provide further information as to whether the tile is slip resistant.

RESPONSE: Tile is slip resistant.. spec sheet enclosed

-Clarify whether there are ANY doors or windows that will open directly from an occupied building onto the pool deck.

RESPONSE: There are no doors and windows open onto the pool deck. Plans should be updated to reflect the following:

-One unit of life saving equipment is specified on plans. Any pool in excess of 3000 square feet of total surface area requires 2 units of lifesaving equipment to be provided.

RESPONSE: Another set of lifesaving equipment has been added to make 2 units of lifesaving equipment.

Sincerely,

Tammy Ellis Shultz Engineering tellis@shultzeg.com