

CONCRETE FIELD REPORT


Project: Serenity Amenity Client: TriPointe Date: 02/27/26
 City: Fuquay Arrived On-Site: 12:30 pm Left Site: 2:30 pm
 Temperature: 50 Weather Conditions: Light Rain Number of Trips: 1
 Material(s) Tested: Slab Foundation Wall Masonry Other: Curb
 Personnel: Jon Cobb Notified Austin of Inland of results
 Concrete Supplier: Concrete Supply Specified Strength: 3,000 psi Specified Slump: 5.0 inches
 Concrete Strength on ticket: 3,000 psi

TEST DATA

Truck No.	Batch Time	Plant No.	Ticket No.	Size of Load	Sample	Slump (in)	Air %	Unit Wt. (pcf)	H2O Added (gallons)	Concrete Temp.	No. of Test Samples	Daily Set No.
7,124	13:00	232	232013234	3.00	14:00	4.5	1.50	145.26	0.00	60	5	1

Daily Set No.	Sample Type	Specified Strength	Detailed Location
1	Concrete	psi	Slab Curb Sections
		psi	
		psi	
		psi	
		psi	
		psi	

The above report is the field rendition of the author only and subject to review




FIELD REPORT ATTACHMENTS

Project: Serenity Amenity Client: TriPointe Date: 02/27/26



All locations should be considered approximate and were not surveyed.

LAB SHEET



Set Number: 1 City: Fuquay
Sample Type: Concrete
Project: Serenity Amenity
Date Sampled: 02/27/26
Strength and Mix Design: _____ psi
Concrete Supplier: Concrete Supply
Plant Location: 232
Truck #: 7,124
Ticket #: 232013234
Size of Load: 3.00
Time Mixed: 13:00
Time Sampled: 14:00
Air Temperature: 50
Concrete Temperature: 60
Amount of Water Added (gallons): 0.00
Unit Weight(PCF): 145.26
Slump (in.): 4.5
Air Content (%): 1.50
Location: Slab Curb Sections

Notes: Standard Breaks
