



# Permit Reviews

## Harnett County

**Permit Number: BCOM2505-0003**

**Description: 40 x 60 Multi Purpose Building**

**Applied: 5/9/2025**

**Approved:**

**Site Address: 135 DRY CREEK RD**

**Issued:**

**Finalized:**

**City, State Zip Code: LILLINGTON, NC 27546**

**Status: RECEIVED**

**Applicant: Miller Thomas Terry**

**Parent Permit:**

**Owner: GREATER VISION FELLOWSHIP INC**

**Parent Project:**

**Contractor: Miller Thomas Terry**

**Details:**

### LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: ALL						
5/16/2025	5/16/2025	5/16/2025	COMMERCIAL INTAKE	Donna Johnson	NO REVIEW NEEDED	SITE2504-0003
Notes:						
5/16/2025		6/2/2025	ENVIRONMENTAL	EH Bucket		
Notes:						
Please call Mr. Terry before going out.						
Review Group: AUTO						
5/9/2025	5/16/2025	5/16/2025	COMMERCIAL INTAKE	CP Bucket	APPROVED	
Notes:						
5/9/2025		5/23/2025	COMMERCIAL BUILDING REVIEW	Building Bucket		
Notes:						
5/9/2025	5/15/2025	5/23/2025	FIRE MARSHAL	Leslie Jackson	DISAPPROVED	See Notes
Notes:						
<ul style="list-style-type: none"><li>- Appendix B needs to be filled out completely.</li><li>- Need to submit a life safety plan.</li><li>- Need to show at least a 20' all weather access rd. capable of withstanding 75,000.</li><li>- Deed ends 150' of greater will need an approved turnaround installed.</li><li>- Fire hydrant at least 400' from farthest back corner of the building measured by driving distance.</li><li>- Needs to be 150' fire access to all outside portions of the building.</li></ul>						