

## HARNETT COUNTY



## Inspection Report - Failed

## Contact

First Name Roof

Email roufsaleh1989@gmail.com

Last Name Saleh

Work Phone 551-556-5351

## Facility Information

Occupant Name: Lucky Stop

Date 05/22/2025

Completed:

Street Number: 359

Building Class M -

Code: Mercantile

City: CAMERON

Street Name: NC 24

Postal Code: 28326

Street Type: Highway

State: NC

Occupant Suite: 2

## Inspection Information

Inspection Type: 108-ALE/ABC Inspection

## Violations

| Violation Code | Description  | Comments  | Violation Fine | Days to Correct |
|----------------|--|---|----------------|-----------------|
| 605.5          | Extension cords<br>Extension cords and flexible cords shall not be a substitute for permanent wiring. Extension cords and flexible cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. | Remove orange extension cord passing through wall from office to machine on floor in hallway next to sales counter.             | 0.00           | 30              |
| 605.6          | Unapproved conditions<br>Open junction boxes and open-wiring splices shall be prohibited. Approved covers shall be provided for all switch and electrical outlet boxes.  | 1. Replace frayed cord to outside air compressor.<br>2. Replace missing outlet cover plate next to "Rip It Energy Fuel" cooler. | 0.00           | 30              |
| 1008.3         | Emergency power for illumination.<br>The power supply for means of egress illumination shall normally be provided by the premises' electrical supply.  | Front exit/emergency light does not illuminate in emergency mode. Emergency lights must illuminate when tested.                 | 0.00           | 30              |

Violation Count: 4

Inspection Violation

Results: Notice  
Issued

## Notifications

Overview The Harnett County Fire Marshal Division conducts comprehensive Fire Code Inspections and Enforcement throughout Harnett County, adhering to the North Carolina Fire Prevention Code.

Violations of the North Carolina Fire Code may result in the following fines: First Re-inspection: \$50.00 per violation for non-compliance; Second Re-inspection: \$100.00 per violation for non-compliance; Third and Subsequent reinspection: \$200.00 per violation for non-compliance; Note: If all violations are corrected by the specified date, no charges will be imposed. The only exception is when an official appeal is properly filed with the North Carolina Department of Insurance.

Harnett County has adopted The Compliance Engine as the prescribed method for record keeping in accordance with Section 107, of the North Carolina Fire Prevention Code. Records of periodic inspections, tests, servicing, and other operations and maintenance for all life safety systems shall be submitted to The Compliance Engine.



Authority - The Harnett County Fire Marshal's Office is authorized to perform fire prevention inspections and impose fees and penalties pursuant to N.C.G.S. 160D, Article 11, and the Administrative Provisions outlined in Chapter 2 of the NC Fire Prevention Code.

Procedural Disputes - If you dispute any procedure used during the inspection or any associated fee or penalty, you may file an appeal with the Harnett County Emergency Services. Submit a written notice to: Harnett County Emergency Services, P.O. Box 370, Lillington, NC 27546. The appeal must be submitted within ten (10) days of the order. Phone calls will not be acknowledged or accepted. A written reply will be provided promptly.

Appeals Process - If you believe any technical provisions of the Fire Prevention Code have been misapplied, you may submit a written notice of appeal to the State Fire Marshal and the inspection department within ten (10) days of the order, decision, or determination.

Appeals of Stop Work Order - In accordance with G.S. 160D-1127, 153A-374, and 160A-434, appeals related to a STOP WORK ORDER must be submitted to the State Fire Marshal within five (5) days of the issuance of the order (160D-114).

**Signatures**

| Type      | First Name | Last Name | Signature Date | Signature Graphic  |
|-----------|------------|-----------|----------------|--|
| Inspector | Roger      | Sullivan  | 05/22/2025     |    |
| Inspector | Roger      | Sullivan  | 05/22/2025     |  |

**Inspection Notes**

**Inspection Documents**