

Permit Reviews Harnett County

Permit Number: BCOM2507-0003

Description: 30 x 55 Church/van metal storage building

| Applied: 7/7/2025 | Approved: | Site Address: 1480 PURFOY RD | | |
|--------------------------------------|-----------|---|--|--|
| Issued: Finaled: Status: RECEIVED | | City, State Zip Code: FUQUAY-VARINA, NC 27526 | | |
| | | Applicant: Lucas Cory | | |
| Parent Permit: | | Owner: REDEEMED APOSTOLIC CHURCH OF | | |
| Parent Project: | | Contractor: Steel Buildings and Structures | | |

Details:

Emailed Cory Lucas to send me the engineered plans for the metal building.

Customer emailed plans for review.

On 070725 at 1:01 pm, I emailed the affidavit for onsite wastewater affidavit and the building application to Cory Lucas to be completed .

| LIST OF REVIEWS | | | | | | | | |
|--|------------------|-----------|-------------------------------|-----------------|-------------|-----------|--|--|
| SENT DATE | RETURNED DATE | DUE DATE | ТҮРЕ | CONTACT | STATUS | REMARKS | | |
| Review Group: AUTO | | | | | | | | |
| 7/7/2025 | 7/8/2025 | | COMMERCIAL INTAKE | CP Bucket | APPROVED | | | |
| Notes: | | | | | | | | |
| 7/7/2025 | 7/15/2025 | 7/21/2025 | COMMERCIAL BUILDING REVIEW | Brad Sutton | DISAPPROVED | | | |
| Need an electrical plan. Floor plan must have rooms labelled for proposed use. No personnel doors shown. All areas shall have code compliant egress doors. | | | | | | | | |
| 3. No personnel do 7/7/2025 | 7/10/2025 | 7/21/2025 | FIRE MARSHAL | Leslie Jackson | DISAPPROVED | See Notes | | |
| | 7/10/2023 | //21/2025 | | | DISAFFROVED | See Notes | | |
| Notes: After reviewing the site plan a fire hydrant will need to be installed within 400ft of the furthest back corner of the building. The fire hydrant will need to be shown on the site plan. | | | | | | | | |
| 7/15/2025 | | | COMMERCIAL BUILDING REVIEW | Building Bucket | | | | |
| Notes: | | | | | | | | |