

March 6, 2026

Mastin Aquatic Group, LLC
1215 Souther Rd.
North Wilkesboro, NC 28659

Beam General Contractors
6870 Perry Creek Rd
Raleigh, NC 27616

Re: Camp Agape

To Whom It May Concern:

This department has reviewed the plans submitted for the Camp Agape swimming pool and appurtenances to be constructed at 1369 Tyler Dewar Ln, Fuquay Varina. This plan review was conducted in accordance with the current North Carolina Rules Governing Public Swimming Pools (15A NCAC 18A .2500).

The plans have been approved with the following comments:

-Items discussed with Christine Byrd per phone on March 6, 2026, shall be adhered to. The water supply for the project is indicated to be municipal, not a well. The backwash from the pool circulation system shall not be directed into the septic system or over the system drain lines. The size of the sump pit is recommended to be increased. Mirrors in restrooms shall be shatterproof. A floor drain is required in all restrooms. Fencing and gates must meet the most current standard of construction as detailed in 15A NCAC 18A .2528.

-Respecting the pool proper, details on the plans lack specificity for this project. Rules as stated on the plans include specifications that are not necessarily requirements in North Carolina. It shall be understood that all facets of construction will adhere to 15A NCAC 18A .2500 Rules Governing Public Swimming Pools.

This approval is valid for one year from the date of this letter and applies only to the pool and related appurtenances. If construction is not initiated within one year from the date of approval, the approval shall expire and plans must be re-submitted.

Under the current provisions of the North Carolina Rules Governing Public Swimming Pools (15A NCAC 18A .2500), the pool shall be constructed by swimming pool contractors licensed by the North Carolina Licensing Board for General Contractors.

Please notify me prior to placement of concrete so inspections can be made of the pool piping. The pump manifold, main drain T and circulation piping are included in this request. Upon completion of construction, the owner must apply to this department for an operation permit. A final inspection must be made, and an operation permit must be issued before bathers can use the pool.

Harnett County Government Complex

307 W. Cornelius Harnett Boulevard

Wilmington, NC 27546

ph: 910-893-7550

fax: 910-893-9429

Prior to issuance of the operation permit, the owner shall submit to this department a statement signed by a registered design professional stating that construction is complete and in accordance with approved plans and specifications and approved modifications. Observation of construction and a final inspection for design compliance by the certifying registered design professional or his representative are required for this statement.

If you have any questions regarding this matter or if I can provide any additional assistance, please call me at 910-893-7547

Sincerely,



Cindy Pierce, REHS
Environmental Health Specialist