



Permit Reviews

Harnett County

Permit Number: **BCOM2507-0006**

Description: **1800 Sq. Ft. Shop/Garage**

Applied: **7/18/2025**

Approved:

Site Address: **2981 BUD HAWKINS RD**

Issued:

Finalized:

City, State Zip Code: **DUNN, NC 28334**

Status: **ISSUED**

Applicant: **Williams Paul D.**

Parent Permit:

Owner: **WILLIAMS PAUL D**

Parent Project:

Contractor: **SteelCraft Construction, Inc.**

Details:

Processed paperwork and informed David Bailey, that I needed the building application completed and returned signed and that the electrician's license number is invalid. I need a site plan for an in-house plan review and he will have to go thru EH as well.

I have emailed Niki Boone again today to ask for a site plan, a pdf of building app and fire marshal plan review app and the existing tank fee for EH. I have sent the disapproved notes from building plan review as well.

Still receiving building app with invalid electrician listed and the forms are still not separated from each other. I emailed back the screenshot of the invalid license on the state site.

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: ALL						
7/29/2025		8/11/2025	ENVIRONMENTAL	EH Bucket		
Notes:						
7/29/2025		8/11/2025	PLANNING	Jay Sikes		
Notes:						
Review Group: AUTO						
7/18/2025	7/31/2025		COMMERCIAL INTAKE	CP Bucket	APPROVED	
Notes:						
7/18/2025	7/29/2025	8/1/2025	COMMERCIAL BUILDING REVIEW	Brad Sutton	DISAPPROVED	
Notes:						
Provide ventilation per 2018 NCMC section 404 as required by Table 403.3.1.1 Ftn d						
7/18/2025	7/22/2025	8/1/2025	FIRE MARSHAL	Leslie Jackson	APPROVED W/EXCEPTION	See Attached Letter/Notes
Notes:						
The Fire Marshal has approved the building plans but before any construction can begin there needs to be a fire hydrant installed 400ft from the furthest corner of the structure measured by driving distance.						



Permit Reviews

Harnett County

7/29/2025			COMMERCIAL BUILDING REVIEW	Building Bucket		
Notes:						

