



Permit Inspections

Harnett County

Permit Number: BCOM2508-0007

Description: 12 x 16 Bathroom Addition on hangar @ Harnett County Jetport

Applied: 8/25/2025

Approved: 9/24/2025

Site Address: 497 AIRPORT RD

Issued: 9/25/2025

Finaled: 7/2/2026

City, State Zip Code: ERWIN, NC 28339

Status: FINALED

Applicant: Harnett Air, LLC

Parent Permit:

Owner: HARNETT COUNTY

Parent Project:

Contractor: Highland Paving Co., LLC

Details:

Sent email to Jimmy Garrett to supply me with lien agent info, completed building application and to change the note on the plans on second page that say Cumberland County. Then I will forward to Brad and Leslie for review.

Emailed Jimmy Garrett asking if he had received the update plans yet.

082725 Jimmy sent me the update plans

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			SLAB	Deen Taylor		
Notes:						
			MONO SLAB	Deen Taylor		
Notes:						
			COMMERCIAL FIRE WALL	Deen Taylor		
Notes:						
	11/6/2025	11/6/2025	FOOTING	Steven Gazlay	APPROVED	
Notes:						
GATE CODE 1238						
	11/25/2025	11/25/2025	ROUGH IN	Brad Sutton	APPROVED	
Notes:						
Gate Code: 1238						
	12/2/2025	12/2/2025	INSULATION	Brad Sutton	APPROVED	
Notes:						
GATE CODE: 1238						
40	6/22/2026	6/22/2026	ZONING	Randy Baker	APPROVED	No Inspection Required
Notes:						
Gate code 1238						
No site inspection required due to previous overall site approval.						



Permit Inspections

Harnett County

40	6/22/2026 AM	6/22/2026 AM	FM FINAL	Matthew Starling	APPROVED	Approved
Notes: Gate code 1238 Approved MJS						
50	6/25/2026	6/25/2026	FINAL**	Brad Sutton	DISAPPROVED	
Notes: Gate code 1238 Plumbing final not approved . Mirror must. Be 40" max AFFSink must be max 34 " AFF. Toilet seat must be open front						
50	7/2/2026	7/2/2026	FINAL**	Brad Sutton	APPROVED	
Notes: gate code 1238						