

# William H. Clark, Jr, PE Consulting Engineer

23 February 2026

Nick Sykes  
Sykes Design  
1033 Wade Avenue, Ste 100  
Raleigh, NC 27605

Re: Review No. 2 Responses  
Camp Agape Pool  
Harnett Co Project Number: BCOM2507-0005

Based on new pool designer drawings and a review of the older plans, the following revisions were made:


P0: The Symbol Legend was updated to show the new non-freeze hose bib and to denote the ball valve abbreviation BV.

P2: The Plumbing Fixture Schedule was modified to add the Non-Freeze Hose Bib (NFHB). The new NFHB was added outside the Pool Equipment Room. Ball valves were added for clarification. The Key Notes were updated to denote the signage wording is given in the new Pool Drawings and to add the NFHB.

M2: The fire damper detail was added to M2.

E2: Key Notes 1 and 2 were modified based on the new Pool Drawings.

If you have any more questions, please contact me.

  
William H. Clark, Jr., PE  
NC PE License 010985

