



Permit Reviews

Harnett County

Permit Number: BCOM2511-0001

Description: Ex building for wholesale auto office (NO CARS)

Applied: 11/12/2025

Approved:

Site Address: 49 LANE RD

Issued:

Finalized:

City, State Zip Code: DUNN, NC 28334

Status: RECEIVED

Applicant: BAREFOOT WILLIAM G

Parent Permit:

Owner: BAREFOOT WILLIAM G

Parent Project:

Contractor: <NONE>

Details:

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: ALL						
11/12/2025	11/19/2025	11/19/2025	PLANNING	Jay Sikes	APPROVED W/EXCEPTION	
Notes: - no individual car sales or storage - wholesale dealer office only						
Review Group: AUTO						
11/12/2025	11/12/2025		COMMERCIAL INTAKE	CP Bucket	DISAPPROVED	
Notes:						
11/12/2025	11/14/2025	11/26/2025	COMMERCIAL BUILDING REVIEW	Brad Sutton	DISAPPROVED	
Notes: Group B occupancy requires a restroom						
11/12/2025	11/18/2025	11/26/2025	FIRE MARSHAL	Roger Sullivan	DISAPPROVED	see notes
Notes: - There must be a fire hydrant within 400 feet of the building, as measured by an approved road route to the farthest point of the building. The proposed building does not meet this requirement. - One 2A10:BC type fire extinguisher will be required at front exit door area. - Post 6" address numbers on front of building.						
11/14/2025			COMMERCIAL BUILDING REVIEW	Building Bucket		
Notes:						