

Permit Reviews Harnett County

Permit Number: BCOM2511-0004 Description: Erwin Church of God Daycare (Ages 3-5) M-F 7am-3pm

Applied: 11/20/2025 Approved: Site Address: 109 W C ST

Issued: Finaled: City, State Zip Code: **ERWIN, NC 28339**

Status: **RECEIVED** Applicant: **Pastor Tum Cowan**

Parent Permit: Owner: ERWIN CHURCH OF GOD

Parent Project: Contractor: <NONE>

Details:

| LIST OF REVIEWS | | | | | | |
|---|------------------|------------|-------------------------------|-----------------|---------------------|---------|
| SENT DATE | RETURNED DATE | DUE DATE | ТҮРЕ | CONTACT | STATUS | REMARKS |
| Review Group: ALL | | | | | | |
| 11/24/2025 | 11/24/2025 | 11/24/2025 | HEALTH AND SANITATION | EH Bucket | NO REVIEW NEEDED | |
| Notes: I spoke with applicant, Tim Cowan, and asked that he call Becky Jackson, DCDEE licensure consultant to make sure he does not need a license for the proposed daycare. Her contact information was given. Currently he is not pursing a license and does not need a review from Environmental. | | | | | | |
| Review Group: AUTO | | | | | | |
| 11/20/2025 | 11/20/2025 | | COMMERCIAL INTAKE | CP Bucket | DISAPPROVED | |
| Notes: | | | | | | |
| 11/20/2025 | 12/2/2025 | 12/4/2025 | COMMERCIAL BUILDING REVIEW | Brad Sutton | DISAPPROVED | |
| Notes: Need all exits shown clearly on plan. Need ages of children shown in classrooms Need all door sizes shown except closets. Need all areas labelled as to their use Must have egress windows in classrooms or sprinklered building | | | | | | |
| 11/20/2025 | | 12/8/2025 | FIRE MARSHAL | Fire Bucket | | |
| Notes: | | | | | | |
| 12/2/2025 | | | COMMERCIAL BUILDING REVIEW | Building Bucket | | |
| Notes: | | | | | | |