



Permit Inspections Harnett County

Permit Number: BCOM2602-0003

Description: **Snack Store Chap Guatc-Mex**

Applied: **2/19/2026**

Approved: **3/17/2026**

Site Address: **204 E JACKSON BLVD Suite A**

Issued: **3/18/2026**

Finalized: **4/2/2026**

City, State Zip Code: **ERWIN, NC 28339**

Status: **FINALED**

Applicant: **MORALES GUILLERMO MATEO**

Parent Permit:

Owner: **MORALES GUILLERMO MATEO**

Parent Project:

Contractor: **<NONE>**

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			FINAL**	Deen Taylor		
Notes:						
	3/31/2026	3/31/2026	FINAL**	Steven Gazlay	CANCELLED	
Notes:						
	4/2/2026	4/2/2026	FINAL**	Steven Gazlay	APPROVED	
Notes:						
40	3/20/2026 PM	3/20/2026 PM	FM FINAL	Matthew Starling	DISAPPROVED	See Comments
Notes:						
1. Exit sign not working properly. 2. Fire extinguisher is required to be a minimum 2A:10BC classification. Current extinguisher is a 1A:10BC classification.						
Applicant was made aware to call in another final once complete. MJS						
40	3/25/2026 PM	3/25/2026 PM	FM FINAL	Matthew Starling	APPROVED	Approved
Notes:						
Customer is requesting 3PM inspection. Please call 919-413-5429 with any questions.						
Approved MJS						
50			FINAL**	Deen Taylor		
Notes:						
50	3/30/2026	3/30/2026	FINAL**	Steven Gazlay	DISAPPROVED	
Notes:						
Customer is requesting 3PM inspection. Please call 919-413-5429 with any questions.						
Door locked. No answer at either phone number listed.						

