



# Permit Reviews

## Harnett County

**Permit Number: BCOM2602-0003**

Description: **Snack Store Chap Guatc-Mex**

Applied: **2/19/2026**

Approved:

Site Address: **204 E JACKSON BLVD Suite A**

Issued:

Finalled:

City, State Zip Code: **ERWIN, NC 28339**

Status: **RECEIVED**

Applicant: **MORALES GUILLERMO MATEO**

Parent Permit:

Owner: **MORALES GUILLERMO MATEO**

Parent Project:

Contractor: **<NONE>**

Details:

### LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: 1ST PLAN REVIEW						
2/19/2026	2/23/2026	3/5/2026	PUBLIC UTILITY	Public Works	APPROVED	See Notes
Notes: According to the Land Use Application, there will only be pre-packaged snacks but I wanted to include a review in case you needed to see it. As long as there is no cooking we wouldn't have to do a review. If food was to be prepared at the site a outside grease trap would need to be installed.						
2/19/2026	2/19/2026	3/5/2026	HEALTH AND SANITATION	EH Bucket	NO REVIEW NEEDED	
Notes: According to the Land Use Application, there will only be pre-packaged snacks but I wanted to include a review in case you needed to see it. All foods indicated packaged and ready to sell, no further handling. No review needed.						
2/19/2026	2/26/2026	3/5/2026	FIRE MARSHAL	Roger Sullivan	DISAPPROVED	see notes
Notes: Same comments as the Chief Building Inspector, need a to-scale life safety plan submitted for review.						
Review Group: AUTO						
2/19/2026	2/19/2026		COMMERCIAL INTAKE	CP Bucket	APPROVED	
Notes:						
2/19/2026	2/24/2026	3/5/2026	COMMERCIAL BUILDING REVIEW	Brad Sutton	DISAPPROVED	
Notes: This was previously a barber shop according to GIS. Need a floor plan/life safety plan drawn to scale for change of occupancy						





# Permit Reviews

## Harnett County

2/24/2026			COMMERCIAL BUILDING REVIEW	Building Bucket		
-----------	--	--	-------------------------------	-----------------	--	--

Notes:

