



April 08, 2026

JWR Ventures Manufacturing Building Permit Responses

Harnett County Permitting
420 McKinney Parkway
Lillington, NC 27546

Dear Harnett County Permitting,

Please find my responses to your comments below in **bold**. Please let me know if you have any additional comments and/or questions about this project.

Planning

1. Dates on Stamped Site Plan does not match Site Plan that was just submitted for Construction. **Understood, see updated sheets.**

Environmental

2. Will need a plot plan containing overall dimension of the building on the site, any parking or driveway areas, and distance from building walls to property lines. **Understood, see updated sheets.**

Building Review

1. Provide information on floor sheathing detail 6 S4.1 penetrating 2 hour wall. **Architectural plans have updated to be nonseparated mixed use, all rated walls removed. See updated set.**
2. Provide information on electrical installation of devices in 3 hour wall. 714.3.2 allows installation in 2 hour wall max. **Architectural plans have updated to be nonseparated mixed use, all rated walls removed. See updated set.**
3. Provide UL details of through penetrations to be used on 3 hour wall for all trades. **Architectural plans have updated to be nonseparated mixed use, all rated walls removed. See updated set.**

Sincerely,

Jessica Swanson, AIA, NCARB

TURPENTINE DESIGN
1007 procure street
fuquay-varina, nc 27526

919.412.9138
turpentine-design.com