

Resolved: Inspection Queries at Seminole Mart #3

7163 US 421 N, Lillington, NC 27546

Can't use drop cords in cabinets at microwave and cooler at sink

Underneath of Sink and Cooler Cabinet: All Drop cords removed, one Ice machine also disconnected as it was not in use, also unnecessary wires and 2 receptacles without plates completely removed




Need to remove gas can in office

Gas can from office Removed

Missing outlet cover in office

Outlet cover installed



Right side need correct connector at box

Connector at box on side wall of store, B/H Ice Machine fixed



Can't use drop cords at registers area right side need correct connector at box
Drop cords removed, Receptacle fixed on stud



Need un-obstructed pathway to Meter base

All obstructions removed all un-necessary stuff also removed, now no obstructions to pathway to Meter base



Needs safety label at the gas pump.

All 4 pumps now have safety labels

