



Permit Reviews Harnett County

Permit Number: BCOM2603-0007

Description: 80x100 Multi-Purpose Building at Antioch Baptist Church

Applied: **3/25/2026**

Approved:

Site Address: **6670 OLD US 421**

Issued:

Finalized:

City, State Zip Code: **LILLINGTON, NC 27546**

Status: **RECEIVED**

Applicant: **Lyle Hogue**

Parent Permit:

Owner: **ANTIOCH BAPTIST CHURCH TRUSTEE**

Parent Project:

Contractor: **CEBCO CONSTRUCTION INC**

Details:

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: 1ST PLAN REVIEW						
3/25/2026	3/27/2026	4/9/2026	PLANNING	Jay Sikes	APPROVED	
Notes: -approved as proposed						
Review Group: ALL						
3/25/2026	4/10/2026	4/9/2026	ENVIRONMENTAL	MARK OSBORNE	APPROVED	
Notes:						
Review Group: AUTO						
3/25/2026	3/25/2026		COMMERCIAL INTAKE	CP Bucket	DISAPPROVED	
Notes:						
3/25/2026	4/1/2026	4/9/2026	COMMERCIAL BUILDING REVIEW	Brad Sutton	DISAPPROVED	
Notes: 1. Need a complete set of architectural, electrical, mechanical and plumbing drawings sealed by NCPE						
3/25/2026	4/2/2026	4/9/2026	FIRE MARSHAL	Roger Sullivan	DISAPPROVED	See notes
Notes: Need complete set of plans to include life safety plans, architectural and electrical to scale sealed by engineer. Same comments as building inspector.						
4/1/2026			COMMERCIAL BUILDING REVIEW	Building Bucket		
Notes:						

