



Permit Reviews

Harnett County

Permit Number: BCOM2603-0007

Description: 80x100 Multi-Purpose Building at Antioch Baptist Church

Applied: **3/25/2026**

Approved: **5/20/2026**

Site Address: **6670 OLD US 421**

Issued: **5/20/2026**

Finalized:

City, State Zip Code: **LILLINGTON, NC 27546**

Status: **ISSUED**

Applicant: **Lyle Hogue**

Parent Permit:

Owner: **ANTIOCH BAPTIST CHURCH TRUSTEE**

Parent Project:

Contractor: **CEBCO CONSTRUCTION INC**

Details:

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: 1ST PLAN REVIEW						
3/25/2026	3/27/2026	4/9/2026	PLANNING	Jay Sikes	APPROVED	
Notes: -approved as proposed						
Review Group: 2ND PLAN REVIEW						
5/5/2026	5/19/2026	5/19/2026	FIRE MARSHAL	Roger Sullivan	APPROVED	See Notes
Notes: Same comments as building inspector Brad Sutton, shell only approval. - The site plan needs to include a fire apparatus turnaround at the end of the gravel road to the need building. - The access road needs to be 20 feet in clear width, 13' 6" in clear height, an all weather surface and capable of supporting 75,000 pounds. - The access road must extend to within 150 feet of all portions of the exterior of the building.						
Review Group: ALL						
3/25/2026	4/10/2026	4/9/2026	ENVIRONMENTAL	MARK OSBORNE	APPROVED	
Notes:						
Review Group: AUTO						
3/25/2026	5/18/2026		COMMERCIAL INTAKE	CP Bucket	APPROVED	
Notes:						
3/25/2026	4/1/2026	4/9/2026	COMMERCIAL BUILDING REVIEW	Brad Sutton	DISAPPROVED	
Notes: 1. Need a complete set of architectural, electrical, mechanical and plumbing drawings sealed by NCPE						





Permit Reviews

Harnett County

3/25/2026	4/2/2026	4/9/2026	FIRE MARSHAL	Roger Sullivan	DISAPPROVED	See notes
Notes: Need complete set of plans to include life safety plans, architectural and electrical to scale sealed by engineer. Same comments as building inspector.						
5/5/2026	5/18/2026	5/19/2026	COMMERCIAL BUILDING REVIEW	Brad Sutton	APPROVED	
Notes: THIS IS FOR A SHELL ONLY! The attached plan is to be used for plumbing under slab reference only. The upfit plan is currently not code compliant, and may not be used to upfit this shell building						

