



Need second exit somewhere around this location. Second exit must be 1/2 the total diagonal distance of the building from the front doors, and located between the wall separating the garage from the business occupancy.

- Green Primary evacuation routes (arrows) and Emergency Exits
- RED Fire Safety equipment locations (Extinguishers, Smoke Detectors)
- Yellow Secondary or alternative escapes routes
- Blue You Are Here & assembly points

Safe place to meet.

14 windows in front 3ft wide 5ft tall

Front of Building

150ft

Garage door 6ft tall 16ft wide

44ft

53ft

69ft

71ft

69ft

53ft

71ft

Garage door 12ft w. 6ft tall

44ft

Fire Extinguisher

Smoke Alarm

Smoke Alarm

Fire Extinguisher

Office 11ft x 15ft

Private Vehicle Collection 9,636 SF

Fire Extinguisher

Smoke Alarm

Kitchen

Bathroom

Smoke Alarm

Fire Extinguisher

Smoke Alarm

Fire Extinguisher

3,124 SF Vehicle Repair

Fire Extinguisher

Smoke Alarm

Exit with 6ft doors opens inward

3ft threshold door

32 inch door to garage

Exit

Private Room 15ft x 2 inches

5ft x 1/2

5ft x 1/2

5ft x 1/2

5ft x 1/2

5ft x 1/2

5ft x 1/2

5ft x 1/2

5ft x 1/2

5ft x 1/2

5ft x 1/2

5ft x 1/2

5ft x 1/2

5ft x 1/2

5ft x 1/2