



Permit Reviews

Harnett County

Permit Number: BCOM2603-0008

Description: **Auto Retail Shop & Unpermitted 12x16 Prefab Storage Building**

Applied: **3/27/2026**

Approved:

Site Address: **7541 US 421 S**

Issued:

Finalized:

City, State Zip Code: **ERWIN, NC 28339**

Status: **RECEIVED**

Applicant: **SLOAN CURTIS ANTHONY**

Parent Permit:

Owner: **SLOAN CURTIS ANTHONY**

Parent Project:

Contractor: **<NONE>**

Details:

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: 1ST PLAN REVIEW						
3/27/2026		4/13/2026	FIRE MARSHAL	Fire Bucket		
Notes:						
Review Group: AUTO						
3/27/2026	3/27/2026		COMMERCIAL INTAKE	CP Bucket	APPROVED	SITE2208-0002
Notes:						
3/27/2026	4/1/2026	4/13/2026	COMMERCIAL BUILDING REVIEW	Brad Sutton	DISAPPROVED	
Notes: Need a plan drawn to scale. Cannot count garage doors as exits. Plan must have all rooms in the building shown						
4/1/2026			COMMERCIAL BUILDING REVIEW	Building Bucket		
Notes:						

