

April 27, 2026

Afreya Munroe
4300 S. Miami Blvd.
Durham, NC 27703

RE: Afreya's Playground, Fuquay Varina


Dear Ms. Munroe,

An application for the above referenced facility was received and reviewed by this office. The following items are in need of attention:

- It is understood that the kitchen equipment is the existing home domestic equipment. Please indicate if the existing sink is one or two compartments and whether the dish machine has a sanitizing cycle.
- The application states a separate handsink is provided in the kitchen however the plumbing plans appear to only show the existing kitchen sink.
- Floor plan layout is not detailed to show age groups of children in each classroom, all diaper changing areas, and location of canwash.

Please address the above items and return to Michelle Myatt at Central Permitting in Lillington (420 McKinney Pkwy or mmyatt@harnett.org).

If you have any questions, please call 893-7547.

Sincerely,

Cindy Pierce, REHS
Environmental Health Section
Harnett County Health Department