


# VICINITY MAP



# CONTACTS

**OWNER:**  
 CAMPBELL UNIVERSITY  
 225 OAK MOUNT RD  
 LILLINGTON, NC 27546

**CONTACT:**  
 ROBBIE ADAMS  
 P: 919.880.8955  
 EMAIL: RADAMS@CAMPBELL.EDU

**MEP:**  
 DOWBERRY ENGINEERS, INC.  
 2610 VICEFY ROAD  
 SUITE 410  
 RALEIGH, NC 27607

**CONTACT:**  
 WESTON HOCKADAY, PE  
 P: 919.257.7581  
 E-MAIL: WHOCKADAY@dowberry.com



REV1



Dowberry Engineers Inc.  
 2610 VICEFY ROAD  
 SUITE 410  
 RALEIGH, NC 27607-0075  
 919.257.7581  
 NC License No. 04249



# CAMPBELL UNIVERSITY POWELL HALL HVAC AND PLUMBING RENOVATION 84 DAY DORM ROAD BUIES CREEK, NC 27506

## PROJECT SCOPE

PROVIDE FULLY FUNCTIONAL HVAC, PLUMBING, AND ELECTRICAL WORK TO SUPPORT HVAC AND PLUMBING INFRASTRUCTURE UPGRADES FOR POWELL HALL.

DEMOLISH EXISTING STEAM RADIATORS, STEAM TO DOW HEAT EXCHANGER, STEAM PIPING, CONDENSATE PIPING, AND CONDENSATE PUMPING TO FACILITATE NEW HVAC AND PLUMBING INFRASTRUCTURE INSTALLATION.

DEMOLISH EXISTING AIR CONDITIONING UNIT SPLIT SYSTEMS, LINESETS, AND DISTRIBUTION DUCTWORK.

DEMOLISH EXISTING MAIN DISTRIBUTION PANEL (MDP), AND PREPARE CONNECTIONS TO DISTRIBUTION POWER FOR RECONNECTION TO NEW MDP.

DEMOLISH TRASH CHUTE THROUGH MECHANICAL ROOMS FOR NEW DUCT RISER.

COORDINATE WITH GENERAL CONTRACTOR FOR INSTALLATION OF DUCTWORK, PIPING, AND CONDUIT TO BE CONCEALED WITHIN CEILING, CHASE, OR PAINTED.

COORDINATE WITH GENERAL CONTRACTOR FOR NEW PENETRATIONS IN INTERIOR, EXTERIOR WALL, AND FLOOR PENETRATIONS FOR CONDUIT, DUCTWORK, PIPING, AND FTAC WALL SLEEVE INSTALLATION.

COORDINATE WITH ROOF CONTRACTOR (SEPARATE VIA CAMPBELL) TO PROVIDE CURB ADAPTORS OR NEW ROOF CURB INSTALLATION FOR EXHAUST VENTILATORS.

COORDINATE WITH LIGHTING ELECTRICAL CONTRACTOR (SEPARATE VIA CAMPBELL) TO AVOID CONFLICTS WITH CIRCUITING, CONDUIT, AND CEILING SPACE.

COORDINATE WITH FIRE ALARM CONTRACTOR (SEPARATE VIA CAMPBELL) TO AVOID CONFLICTS WITH CIRCUITING, CONDUIT, AND CEILING SPACE.

COORDINATE WITH NATURAL GAS UTILITY PROVIDER TO EXTEND GAS PIPING FROM METER TO NEW PLUMBING EQUIPMENT.

PROVIDE NEW DEDICATED OUTDOOR AIR SYSTEM WITH NEW DUCTWORK THROUGH EACH FLOOR AND AIR DISTRIBUTION TO SERVE SPACES.

COORDINATE WITH GENERAL CONTRACTOR TO PROVIDE DUCT CHASE FOR DOAS RISER, PROVIDE FIRE DAMPERS AT EACH FLOOR PENETRATION FOR DUCT RISER SERVING MULTIPLE FLOORS, PROVIDE TRIM HINGED ACCESS DOOR IN WALL AND 12X12 HINGED ACCESS DOOR IN DOOR FOR FIRE DAMPER ACCESS.

PROVIDE NEW PACKAGED TERMINAL AIR CONDITIONER (TAC) HEAT PUMPS IN LOCATIONS SHOWN WITH WIRID WALL MOUNTED THERMOSTAT WITH OPTION FOR WIRELESS REMOTE MONITORING. COORDINATE WITH GENERAL CONTRACTOR FOR INSTALLATION OF WALL SLEEVE FOR FLUSH EXTERIOR ARCHITECTURAL TRIM AND INTEL INSTALL.

PROVIDE NEW BATHROOM EXHAUST FANS WITH DUCTWORK, COORDINATE WITH GENERAL CONTRACTOR TO REMOVE TRANSOM ABOVE TOILET ROOM DOOR.

PROVIDE NEW BUILDING SYSTEM NETWORK CONTROLLER FOR MONITORING DOMESTIC WATER HEATER SYSTEM PACKAGED BURNER CONTROLLER, CONDENSATE BURNER CONTROLLER, AND HEAT PUMPS. PROVIDE GRAPHICS, TRENDS, SETPOINT ADJUSTMENT, SCHEDULING, AND ALARMING TO TRIM ENTERPRISE SYSTEM FOR REMOTE ACCESS. PROVIDE NETWORK CONTROLLER FOR INTEGRATION OF NEW BACNET COMMUNICATION WIRING THROUGHOUT BUILDING. COORDINATE WITH BLESSTREAN TO PROVIDE POWER TO BUILDING SYSTEM NETWORK CONTROL PANEL. PROVIDE CAT 6 NETWORK CABLE FOR DATA DROP FROM BUILDING SERVER TO BUILDING SYSTEM NETWORK CONTROLLER WITH FINAL TERMINATIONS AT SERVER AND DATA DROP BY CAMPBELL IT GROUP.

PROVIDE NEW ELECTRICAL INFRASTRUCTURE FROM MAIN DISTRIBUTION PANEL TO NEW BRANCH DISTRIBUTION PANELS AND CIRCUITS TO SUPPORT THE HVAC AND PLUMBING INFRASTRUCTURE UPGRADES. RECONNECT TO EXISTING ELECTRICAL INFRASTRUCTURE TO REMAIN.

PROVIDE NEW PLUMBING INFRASTRUCTURE INCLUDING DOMESTIC HOT WATER HEATERS, MIXING VALVE, AND RECIRCULATION PUMP WITH PIPING TO END OF RISER ON 3RD FLOOR.

CONTRACTOR TO INCLUDE PERMITTING AND COSTS.


CONTRACTOR TO INCLUDE \$5,000 CONSTRUCTION ALLOWANCE IN BID FOR OWNER APPROVED CHANGES.

CONTRACTOR TO SOURCE MATERIALS AND SCHEDULE WORK FOR SUBSTANTIAL COMPLETION OF WORK BY AUGUST 07, 2026.


## DRAWING INDEX

Sheet Number	Sheet Title
G-001	COVER SHEET
G-202	BUILDING CODE SUMMARY
F-201	PLUMBING SYMBOLS & ABBREVIATIONS
PD101	CRAWLSPACE DOMESTIC DEMOLITION PLAN AREA A
PD102	CRAWLSPACE DOMESTIC DEMOLITION PLAN AREA B
PD111	FIRST FLOOR DOMESTIC DEMOLITION PLAN AREA A
PD121	SECOND FLOOR DOMESTIC DEMOLITION PLAN
PD131	THIRD FLOOR DOMESTIC DEMOLITION PLAN
MD101	CRAWLSPACE DOMESTIC NEW WORK PLAN AREA A
MD111	FIRST FLOOR DOMESTIC NEW WORK PLAN AREA A
MD121	SECOND FLOOR DOMESTIC NEW WORK PLAN
MD131	THIRD FLOOR DOMESTIC NEW WORK PLAN
M-201	DETAILS
M-201	SCHEDULES
M-201	MECHANICAL SYMBOLS & ABBREVIATIONS
MD101	CRAWLSPACE MECHANICAL DEMOLITION PLAN
MD111	FIRST FLOOR MECHANICAL DEMOLITION PLAN AREA A
MD121	SECOND FLOOR MECHANICAL DEMOLITION PLAN
MD131	THIRD FLOOR MECHANICAL DEMOLITION PLAN
ME101	CRAWLSPACE MECHANICAL NEW WORK PLAN
ME111	FIRST FLOOR MECHANICAL NEW WORK PLAN AREA A
ME121	SECOND FLOOR MECHANICAL NEW WORK PLAN
ME131	THIRD FLOOR MECHANICAL NEW WORK PLAN
M-201	DETAILS
M-202	DETAILS
M-201	SCHEDULES
M-201	CONTROLS
E-201	ELECTRICAL SYMBOLS & ABBREVIATIONS
ED101	CRAWLSPACE ELECTRICAL DEMOLITION PLAN
ED111	FIRST FLOOR ELECTRICAL DEMOLITION PLAN AREA A
ED112	FIRST FLOOR ELECTRICAL DEMOLITION PLAN AREA B
ED121	SECOND ELECTRICAL DEMOLITION PLAN
ED131	THIRD FLOOR ELECTRICAL DEMOLITION PLAN
E-111	FIRST FLOOR ELECTRICAL NEW WORK PLAN AREA A
E-112	FIRST FLOOR ELECTRICAL NEW WORK PLAN AREA B
E-121	SECOND ELECTRICAL NEW WORK PLAN
E-131	THIRD FLOOR ELECTRICAL NEW WORK PLAN
E-201	DETAILS
E-201	SCHEDULES
R-201	RISER DIAGRAMS

## CAMPUS MAP



CAMPBELL UNIVERSITY  
 POWELL HALL  
 HVAC AND PLUMBING RENOVATION  
 84 DAY DORM ROAD  
 BUIES CREEK, NC 27506  
 CONSTRUCTION DOCUMENTS



KEY PLAN

SCALE

REVISIONS

NO.	DESCRIPTION	DATE

NO. DESCRIPTION DATE  
 DRAWN BY:    DB  
 APPROVED BY:    JS  
 CHECKED BY:    WH  
 DATE:    05/20/2026

TITLE: COVER SHEET

PROJECT NO. 50180045


G-001

SHEET NO.

5/20/2026, 9:40:10 AM  
 P:\2026\CAMPBELL\BUIES CREEK\POWELL HALL\DWG








**1 CRAWLSPACE DOMESTIC DEMOLITION PLAN**  
 SCALE: 3/16" = 1'-0"

**GENERAL NOTES:**  
 1. REFER TO P-001 FOR PLUMBING GENERAL NOTES.

**KEYNOTES:**  
 1. DEMOLISH EXISTING ELECTRIC WATER HEATER AND ASSOCIATED PIPING BACK TO NEAREST ACTIVE MAIN AS INDICATED, CAP PIPING AT MAIN.  
 2. DEMOLISH EXISTING PIPING AS INDICATED AND PREPARE FOR RECONNECTION.



CAMPBELL UNIVERSITY  
**POWELL HALL**  
 HVAC AND PLUMBING RENOVATION  
 84 DAY DORM ROAD  
 BUJES CREEK, NC 27506  
 CONSTRUCTION DOCUMENTS



REVISIONS

NO.	DESCRIPTION	DATE

DRAWN BY: SDD  
 APPROVED BY: CCC  
 CHECKED BY: CHM  
 DATE: 09/20/2025


TITLE  
**CRAWLSPACE DOMESTIC DEMOLITION PLAN AREA A**

PROJECT NO. 50180XMS

**PD101**

SHEET NO.

09/20/2025 03:36 AM  
 P:\2025\09\20\50180XMS\0100\DWG\101\CRAWLSPACE DOMESTIC DEMOLITION PLAN.DWG



① CRAWLSPACE DOMESTIC DEMOLITION PLAN AREA B  
 SCALE: 3/16" = 1'-0"

GENERAL NOTES:

1. REFER TO P-001 FOR PLUMBING GENERAL NOTES.

KEYNOTES:

1. DEMOLISH EXISTING ELECTRIC WATER HEATER AND ASSOCIATED PIPING BACK TO NEAREST ACTIVE MAINS AS INDICATED, CAP PIPING AT MAIN.



Dowberry Engineers Inc.  
 2610 HWY 8 ROAD  
 SUITE 100  
 HARRIS, NC 27840-0075  
 919.733.3333  
 NC LICENSE #L1424208




CAMPBELL UNIVERSITY  
**POWELL HALL**  
 HVAC AND PLUMBING RENOVATION  
 84 DAY DORM ROAD  
 BUJES CREEK, NC 27506  
 CONSTRUCTION DOCUMENTS

SEAL



KEY PLAN AREA B



REVISIONS

NO.	DESCRIPTION	DATE

DRAWN BY:            SDD  
 APPROVED BY:            CCC  
 CHECKED BY:            CHN  
 DATE:            02/23/2028

TITLE:  
**CRAWLSPACE  
 DOMESTIC  
 DEMOLITION PLAN  
 AREA B**

PROJECT NO. 00180045

PD102


SHEET NO.

S:\02028\02028\14\4\PROJECTS\PLUMBING\01000211\CRAWLSPACE DOMESTIC DEMOLITION PLAN AREA B.DWG









1 CRAWLSPACE DOMESTIC NEW WORK PLAN  
 SCALE: 3/16" = 1'-0"

**GENERAL NOTES:**

1. REFER TO P-001 FOR PLUMBING GENERAL NOTES.

**KEYNOTES:**




Dowberry Engineers Inc.  
 2611 W. #104  
 Durham, NC 27607-0073  
 919.286.9928  
 NC License No. 42409




CAMPBELL UNIVERSITY  
**POWELL HALL**  
 HVAC AND PLUMBING RENOVATION  
 84 DAY DORM ROAD  
 BUJES CREEK, NC 27706  
 CONSTRUCTION DOCUMENTS

SEAL



KEY PLAN



REVISIONS

NO.	DESCRIPTION	DATE


DRAWN BY: SDD  
 APPROVED BY: GCG  
 CHECKED BY: CHM  
 DATE: 09/29/2028

TITLE  
**CRAWL SPACE  
 DOMESTIC NEW  
 WORK PLAN AREA  
 A**


PROJECT NO. 50180XMS

**P-101**

SHEET NO.



① CRAWLSPACE DOMESTIC NEW WORK PLAN AREA B  
 SCALE: 3/16" = 1'-0"



**GENERAL NOTES:**

1. REFER TO P-001 FOR PLUMBING GENERAL NOTES.

**KEYNOTES:**



Dowberry Engineers Inc.  
 2610 RAY ROAD  
 SUITE 100  
 HARRIS, NC 27836-0073  
 919.833.2025  
 NC LICENSE #L24269




CAMPBELL UNIVERSITY  
**POWELL HALL**  
 HVAC AND PLUMBING RENOVATION  
 84 DAY DORM ROAD  
 BUJES CREEK, NC 27506  
 CONSTRUCTION DOCUMENTS

SEAL



KEY PLAN



SCALE

**REVISIONS**

NO.	DESCRIPTION	DATE


DRAWN BY: SDD  
 APPROVED BY: CCC  
 CHECKED BY: CHH  
 DATE: 09/20/2008

**TITLE**  
 CRAWLSPACE  
 DOMESTIC NEW  
 WORK PLAN AREA  
 B

PROJECT NO. 50180045

**P-102**

SHEET NO.



① FIRST FLOOR DOMESTIC NEW WORK PLAN AREA A  
 SCALE: 3/16" = 1'-0"

**GENERAL NOTES:**

- REFER TO PART 1 FOR PLUMBING GENERAL NOTES.
- ALL HORIZONTAL PIPING TO BE RUN IN OPEN WEB JOIST CAVITIES IN CEILING.

**KEYNOTES:**

- PROVIDE NEW WATER HEATER, MIXING VALVE AND ASSOCIATED ACCESSORIES AS INDICATED, REFER TO SCHEDULE AND DETAIL FOR MORE INFORMATION.
- PROVIDE 1" DHWV VALVE CAPPED FOR FUTURE USE.
- PROVIDE MANUAL BALANCING VALVE AS INDICATED TO SERVE RUMBLE HALL. SET TO 2.0 PSI. REFER TO DETAIL FOR MORE INFORMATION.
- PROVIDE CONCENTRIC FLUE AND INTAKE PIPING AS INDICATED PER MANUFACTURER'S INSTRUCTIONS. TERMINATE PIPING ABOVE MECHANICAL ROOM DOOR. 10'-0" AFF PROVIDE BRIGHT SCREEN ON OUTLETS AND INLETS.
- FURNISH GAS WATER HEATER EMERGENCY STOP SWITCH TO ELECTRICAL CONTRACTOR FOR INSTALLATION. MOUNT AT 48" AFF. EMERGENCY STOP SWITCHES SHALL CLOSE SOLENOID NATURAL GAS VALVE. REFER TO SPEC FOR BASIS OF DESIGN, WIRING AND FINAL CONNECTIONS BY ELECTRICAL CONTRACTOR.

**NATURAL GAS PIPE SIZING CRITERIA**

NATURAL GAS DEMAND = 400,000 BTU/H  
 LONGEST PIPE LENGTH = 80 FT  
 PIPING SIZED IN ACCORDANCE WITH TABLE 402.4(6) OF THE NC FUEL GAS CODE. EACH PIECE OF EQUIPMENT SHALL BE PROVIDED WITH A PRESSURE REGULATOR.



Dowberry Engineers Inc.  
 2610 SVP Road  
 Suite 100  
 Raleigh, NC 27607-0075  
 919.876.2025  
 NC License No. 24249




CAMPBELL UNIVERSITY  
**POWELL HALL**  
 HVAC AND PLUMBING RENOVATION  
 84 DAY DORM ROAD  
 BUJES CREEK, NC 27506  
 CONSTRUCTION DOCUMENTS

SEAL



KEY PLAN



SCALE

REVISIONS

NO.	DESCRIPTION	DATE

DRAWN BY \_\_\_\_\_ VALUE  
 APPROVED BY \_\_\_\_\_ VALUE  
 CHECKED BY \_\_\_\_\_ VALUE  
 DATE \_\_\_\_\_ 05/23/2025


**TITLE**  
**FIRST FLOOR DOMESTIC NEW WORK PLAN AREA A**

PROJECT NO. 20180045


**P-111**

SHEET NO.

5/20/2025 10:30 AM PROJECT: C:\P\PLUMBING\20180045\1 - FIRST FLOOR DOMESTIC NEW WORK PLAN AREA A.DWG



**1 SECOND FLOOR DOMESTIC NEW WORK PLAN**  
 SCALE: 3/16" = 1'-0"



**GENERAL NOTES:**  
 1. REFER TO P-001 FOR PLUMBING GENERAL NOTES.

**KEYNOTES:**



Dowberry Engineers Inc.  
 2014 SUT ROAD  
 SUITE 100  
 RAYLEIGH, NC 27603-0073  
 919.487.9228  
 NC LICENSE NO. 42428




CAMPBELL UNIVERSITY  
**POWELL HALL**  
 HVAC AND PLUMBING RENOVATION  
 84 DAY DORM ROAD  
 BUJES CREEK, NC 27506  
 CONSTRUCTION DOCUMENTS

SEAL



KEY PLAN



REVISIONS

NO.	DESCRIPTION	DATE

DRAWN BY: SDG  
 APPROVED BY: CCG  
 CHECKED BY: CRH  
 DATE: 09/29/2020

TITLE  
**SECOND FLOOR  
 DOMESTIC NEW  
 WORK PLAN**

PROJECT NO. 50180XMS

**P-121**

SHEET NO.





PUMP SCHEDULE								
MARK	DESCRIPTION	FLOW RATE	DESIGN HEAD	ELECTRICAL DATA			COMMENTS	
				AMPS	VOLTS	PHASE		
OP-1	SHWR INLINE CIRCULATION PUMP	4 GPM	30 FT	2	115	1	60	TACO 0084-SFZ INLINE ECM STAINLESS STEEL CIRCULATION PUMP. PROVIDE WITH 3/4" CONNECTIONS AND 5" WELDED STEEL CASING FOR POTABLE WATER SYSTEMS. PROVIDE WITH TACO COMPATIBLE AQUASAT, REFER TO DETAIL A1P-031 FOR MORE INFORMATION.

MODELS LISTED ARE BASIS OF DESIGN (SEE SPECIFICATIONS FOR APPROVED MANUFACTURERS LIST).

THERMOSTATIC MIXING VALVE SCHEDULE						
MARK	DESCRIPTION	PIPE SIZES	INLET & OUTLET TEMP	DESIGN FLOW	PRESSURE DROP AT FLOW	COMMENTS
TMV-1	MASTER BATHROOM THERMOSTATIC MIXING VALVE	1 1/2" IN 1 1/4" OUT	140° IN 120° OUT	33 GPM	10 PSI	LEONARD TACO 844-PT-RT 4834-030 (BIMETALLED) THERMOSTATIC MIXING VALVE. MINIMUM 1.0 GPM FLOW RATE WITH INLINE CIRCULATION AND INLET THERMOMETERS, ASSE 1017 CERTIFIED.

GAS-FIRED WATER HEATER SCHEDULE							
MARK	DESCRIPTION	STORAGE	RECOVERY @ 100°F	INPUT ENERGY	THERMAL EFFICIENCY	ELECTRICAL	COMMENTS
GWH-1	GAS-FIRED CONDENSING WATER HEATER	100 GALLONS	266 GALLONS PER HOUR	199,000 BTU/HOUR	90%	120 VOLT 1 PHASE 20 AMPS	AO SMITH CYCLONE 674-199A. PROVIDE WITH CONDENSATE NEUTRALIZATION KIT.

NOTES:

1. FURNISH 120V, 20A DISCONNECT TO ELECTRICAL CONTRACTOR FOR INSTALLATION. REFER TO ELECTRICAL DRAWINGS FOR ADDITIONAL INFORMATION.
2. PROVIDE WITH MAGNET ASSIST CAPABILITY FOR CONNECTION TO BUILDING AUTOMATION SYSTEM. REFER TO MECHANICAL DRAWINGS FOR ADDITIONAL INFORMATION.
3. PROVIDE WITH VESSEL HEAD EXPANSION STYLE THERMAL EXPANSION TANK WITH MINIMUM 11 GALLONS ACCEPTANCE VOLUME.
4. PROVIDE WITH OPTIONAL CONDENSATE NEUTRALIZATION KIT FROM MANUFACTURER.
5. PROVIDE WITH CPVC SCHEDULE 40 CONCENTRIC FLUE AND INTAKE PIPE PER MANUFACTURERS RECOMMENDATIONS AND AS ROUTED ON PLANS.



CAMPBELL UNIVERSITY  
 POWELL HALL  
 HVAC AND PLUMBING RENOVATION  
 84 DAY DORM ROAD  
 BUIES CREEK, NC 27506  
 CONSTRUCTION DOCUMENTS

SEAL



5/21/2024

KEY PLAN

SCALE

REVISIONS

NO.	DESCRIPTION	DATE

NO. DESCRIPTION DATE  
 DRAWN BY SDJ  
 APPROVED BY CCS  
 CHECKED BY CPH  
 DATE 05/20/2024

TITLE  
**SCHEDULES**

PROJECT NO. 50180045

**P-601**

SHEET NO.

5/20/2024 2:02:10 AM  
 P:\2024\PROJECTS\PLUMBING\05180045\05180045\_SCHEDULES.DWG

ABBREVIATIONS - MECHANICAL

Table of abbreviations for mechanical systems, including terms like EXISTING, AIR CONDITIONING, ABOVE FINISHED FLOOR, etc.

ABBREVIATIONS - MECHANICAL

Table of abbreviations for mechanical systems, including terms like HEIGHT, WATER, HEAD, HORSEPOWER, etc.

MECHANICAL GENERAL NEW WORK NOTES

- 1. ALL WORK SHALL BE PERFORMED IN ACCORDANCE WITH APPLICABLE FEDERAL, STATE AND LOCAL CODES AND REGULATIONS. MECHANICAL EQUIPMENT SHALL BE SELECTED TO MEET OR EXCEED THE REQUIREMENTS OF THE ENERGY CONSERVATION CODE. MECHANICAL WORK SHALL COMPLY WITH PROJECT SPECIFICATIONS.
2. PLUMBING AND INITIAL ALL INCIDENTAL ACCESSORIES REQUIRED TO MAKE THE MECHANICAL WORK COMPLETE AND OPERATIONAL.
3. CONTRACTOR SHALL BE RESPONSIBLE FOR INSPECTING, TESTING AND VERIFYING OPERATION OF THE EQUIPMENT. ALL EQUIPMENT (GASSETS, ETC.) SHALL BE FUNCTIONAL BEFORE PROJECT COMPLETION. COORDINATE WITH ELECTRICAL AND TALE CONTRACTORS.
4. THESE DRAWINGS ARE INFORMATIONAL. EXACT EQUIPMENT LOCATIONS AND DUCT AND PIPING ROUTINGS SHALL BE COORDINATED WITH THE BUILDING AND LIFE CONDITIONS. THE ACTUAL EQUIPMENT AND MINIMUM CLEARANCE DIMENSIONS SHALL BE VERIFIED WITH THE SUPPLIERS.
5. EQUIPMENT, DUCTWORK, PIPING AND CONDUIT LAYOUT SHALL BE COORDINATED WITH BUILDING COMPONENTS AND OTHER TRADES PRIOR TO INSTALLATION. THE SYSTEM SHALL BE NEATLY ARRANGED TO MAXIMIZE SPACE ABOVE CEILING AND WITHIN CHASES. MAINTAIN MINIMUM EQUIPMENT AND DUCT MAINTENANCE CLEARANCES. GUESSES SHALL BE MADE BY MEASUREMENT. METERS AND GAUGES SHALL BE ORIENTED FOR BEST VIEW. INSTALLED MATERIALS NOT COORDINATED SHALL BE REMOVED AND REINSTALLED AT NO ADDITIONAL COST TO THE OWNER.
6. DUCT OFFSETS SHALL BE MADE AT 15 OR 30-DEGREE ANGLES WHERE POSSIBLE BUT AT NEVER MORE THAN 45-DEGREE.
7. EXACT LOCATIONS OF CEILING-MOUNTED EQUIPMENT SHALL BE COORDINATED WITH THE REFLECTORIZING PLANS AND THE EXISTING CONDITIONS. AIR OUTLETS AND SMOKE DETECTORS SHALL BE COORDINATED TO BE NO LESS THAN 36-INCHES APART.
8. WALL-MOUNTED CONTROL SENSORS SHALL BE INSTALLED AT 48-INCHES ABOVE THE FLOOR TO THE TOP OF BACK-DROP. COORDINATE EXACT LOCATIONS WITH LIGHT SWITCHES. WHEN BOTH ARE INSTALLED ADJACENT TO A DOOR, LOCATE THE SWITCH CLOSEST TO THE DOOR AND THE SENSOR WITH 12-INCHES OF THE SWITCH.
9. CONTROL AND ALARM DEVICES SHALL BE INSTALLED IN BACK-BOARDS WITH NEW AND EXISTING WALLS. SURFACE-MOUNTED CONDUIT AND RACEWAYS WILL NOT BE ACCEPTED EXCEPT FOR EXISTING SOLID CONCRETE WALLS. DEVICE BACKBOXES IN BRICK/MASS WALLS SHALL HAVE FIRST-STOP PUTTY PADS OR EQUIVALENT ULISTED INSTALLATION.
10. INITIAL PENETRATIONS OF UPSTREAM RATED ASSEMBLIES PER APPROVED UL LISTED DETAIL IN ACCORDANCE WITH THE BUILDING CODE.
11. PROVIDE A DUCT ACCESS DOOR FOR EACH DUCT AND RUN (SEE SCHEDULE) INCLUDING MAINTENANCE OR INSPECTION. REFER TO SECTION 23.33.00 FOR DOOR SEED REQUIREMENTS. COORDINATE CEILING AND WALL ACCESS DOORS WITH DUCT ACCESS DOORS.
12. HVAC PIPING SHALL BE NO LESS THAN 3/4-INCH EXCEPT REFRIGERANT PIPING.
13. ALL MOTORIZED EQUIPMENT SHALL BE CONNECTED TO DUCTWORK OR PIPING WITH FLEXIBLE CONNECTIONS.
14. EXTEND POWER CONDUIT AND WIRING FROM DEDICATED POWER SOURCES TO CONTROL EQUIPMENT AND DEVICES. COORDINATE POWER SOURCES WITH ELECTRICAL CONTRACTOR.
15. DUCT BRANCH DUCT FROM MAIN TAKEOFF TO AIR INLET OR OUTLET SHALL MATCH SCHEDULED NECK SIZE UNLESS OTHERWISE NOTED.
16. MAINTAIN MINIMUM 3/4-INCH CLEARANCE FOR 120V/240V POWER OR 60-INCH CLEARANCE FOR 277/480V POWER AS REQUIRED BY THE NATIONAL ELECTRICAL CODE FOR ELECTRICAL EQUIPMENT AND TO PROVIDE MAINTENANCE ACCESS.
17. FIELD VERIFY EXACT PIPING SIZES AND FLOW DIRECTIONS PRIOR TO CONNECTING TO PIPING SYSTEMS.
18. SCHEDULE ALL SERVICE RISERS/PIPINGS AND SHUTDOWNS WITH THE OWNER NO LESS THAN 1 WEEK IN ADVANCE.
19. AIR HANDLING UNIT INTAKES SHALL BE SEPARATED BY MINIMUM 10 FEET FROM EXHAUST FANS, EXHAUST VENTS, FLUES, PLUMBING VENTS, ETC.

MECHANICAL GENERAL DEMOLITION WORK NOTES

- 1. VERIFY PROJECT SITE EXISTING CONDITIONS PRIOR TO (BE). EXISTING CONDITIONS INDICATED IN THESE DOCUMENTS ARE APPROXIMATE AND DO NOT INCLUDE EVERY COMPONENT.
2. RECORD EXISTING CONDITIONS PRIOR TO THE START OF WORK. REPAIR DAMAGES RESULTING FROM PROJECT WORK.
3. COORDINATE MATERIALS TO BE RETAINED BY THE OWNER PRIOR TO THE START OF DEMOLITION WORK. RETAINED MATERIALS SHALL BE DELIVERED TO A POINT DESIGNATED BY THE OWNER WITHIN A 5-MILE RADIUS OF THE PROJECT SITE. PROPERLY DISPOSE OF ALL REMAINING DEMOLITION MATERIALS. COMPLY WITH MATERIAL RECYCLING REQUIREMENTS. DO NOT STAND IN PLACE ANY ITEMS IDENTIFIED TO BE REMOVED UNLESS OTHERWISE NOTED.
4. THE SCOPE OF DEMOLITION FOR ITEMS TO BE REMOVED INCLUDES ASSOCIATED SUPPORTS, POWER CONNECTIONS, CONTROLS, ETC.
5. REMOVE ALL DEMOLITION INDICATIONS INCLUDING THAT REQUIRED TO INSTALL NEW WORK. REMOVE AND REINSTALL MATERIALS TO REMAIN AS NEEDED WHERE REQUIRED TO EXPOSE OR DEMOLISH OR TO REINSTALL NEW WORK. REPAIR DAMAGED SURFACES TO MATCH EXISTING ADJACENT SURFACES.
6. REMOVE DUCT, PIPING AND CONDUIT BACK TO POINTS INDICATED. PREPARE OPEN ENDS FOR CONNECTION TO NEW WORK INDICATED OR CAPS.
7. REPAIR DAMAGE TO ANY OPENINGS IN LIFE-SAFETY RATED ASSEMBLIES CREATED BY THE DEMOLITION WORK PER APPROVED UL LISTED DETAIL IN ACCORDANCE WITH THE BUILDING CODE.
8. PIPING AND CONDUIT TO BE REMOVED THAT IS LOCATED BELOW CONCRETE SLAB-ON-GRADE FLOORS OR WITHIN CONCRETE SOLID OR BLOCK WALLS MAY BE ABANDONED IN PLACE UNLESS NECESSARY TO INSTALL NEW WORK OR NOTED OTHERWISE. WHEN ABANDONING, CUT PIPING OR CONDUIT BACK AT LEAST 1-INCH BEYOND THE SURFACE, PLUS THE ODS AND PROTECT THE SURFACE WITH 2-INCH MATERIAL.
9. CAPTURE AND RECYCLE REFRIGERANT FROM HVAC EQUIPMENT. COMPLY WITH THE EPA REFRIGERANT RECYCLING AND DISPOSAL REQUIREMENTS.
10. REMOVE AND REINSTALL LAYIN CEILING TILES AND GIRD AS NEEDED TO PERFORM CONTRACT WORK. STORE CEILING MATERIALS IN A CLEAN DRY PLACE. REPLACE DAMAGED TILES WITH NEW TO MATCH. SELECT ONE ROOM TO INSTALL ALL NEW TILING AND GIRD TO PROVIDE THE TILES NEEDED TO REPLACE DAMAGED TILES IN OTHER SPACES.

MECHANICAL SCHEMATIC SYMBOLS

Table of mechanical schematic symbols including gauges/sensors (pressure, temperature, humidity, freeze, differential pressure, magnetic, current transducer, air flow monitoring), flow switches, end switches, humidity-high limit switches, override switches, network points for BAS and building automation systems, electronic control points (transformer, relay, starter), and pneumatic symbols (electronic or electric to pneumatic switch/transducer).

HVAC SYMBOLS

Table of HVAC symbols including grilles (supply, return, exhaust, air device tag), concentric and eccentric transitions, radius elbows, mitered elbows with turning vanes, supply, return, and exhaust air ducts, flex duct, demolition ductwork or equipment, existing ductwork or equipment, new ductwork or equipment, rectangular take-off, round take-off, and access doors.

MECHANICAL PIPING SYSTEMS


Table of mechanical piping systems symbols and descriptions: AV (atmospheric vent), CD (condensate drain), D (drain), LPC (low pressure condensate), RD (refrigerant discharge), R (refrigerant), RF (refrigerant liquid line), RS (refrigerant suction line), RH (refrigerant hot gas), SP (steam pipe).

HVAC SYMBOLS CONTINUED

Table of HVAC symbols continued including dampers (automatic/motorized, manual, gravity backdraft), fire damper, controls (thermostat, humidity sensor, duct mounted smoke detector, non-fusible safety switch, fusible safety switch, combination motor starter safety switch, disconnect switch), and a scale table.



CAMPBELL UNIVERSITY POWELL HALL HVAC AND PLUMBING RENOVATION 84 DAY DORM ROAD BUJES CREEK, NC 27506 CONSTRUCTION DOCUMENTS



KEY PLAN

SCALE

Table for revisions with columns for NO., DESCRIPTION, and DATE.


NO. DESCRIPTION DATE
DRAWN BY: CDB
APPROVED BY: KSC
CHECKED BY: VWH
DATE: 05/20/2025

MECHANICAL SYMBOLS & ABBREVIATIONS

PROJECT NO. 00190405

M-001

SHEET NO.



1 CRAWLSPACE MECHANICAL DEMOLITION PLAN  
 SCALE: 3/16" = 1'-0"

**GENERAL NOTES:**

- STEAM SUPPLY TO POWELL HALL LOCATED OUTSIDE OF BUILDING, COORDINATE WITH CAMPBELL UNIVERSITY FACILITIES TO SHUT OFF STEAM TO BUILDING.
- DEMOLISH STEAM PIPING IN CRAWLSPACE AS NEEDED TO MAKE ROOM FOR NEW CONSTRUCTION.

**KEYNOTES:**

- CRAWLSPACE ACCESS DOOR LOCATED HERE.
- REMOVE ALL DRIVER UNIT IN THE VICINITY OF THE ELECTRICAL PANEL, REPAIR AND REPLACE DRY VENT HOSE AS REQUIRED, CONNECT ALL LOOSE VENT HOSES BACK TO VENT CAPS ON EXTERIOR WALL OF CRAWLSPACE.
- STEAM PIPING TO BE ABANDONED IN PLACE, AFTER STEAM SUPPLY TO BUILDING IS SHUT OFF, ALLOW STEAM SYSTEM TO COOL AND DRAIN SYSTEM OF CONDENSATE, DISCONNECT STEAM SUPPLY PIPING FROM PRESSURE REDUCING STATION AND CH PIPING END.
- DEMOLISH STEAM PIPING FROM POINT INDICATED.




Dowberry Engineers Inc.  
 2014 47th Road  
 Suite 100  
 Raleigh, NC 27607-0073  
 919.876.9222  
 NC License No. 42408




CAMPBELL UNIVERSITY  
 POWELL HALL  
 HVAC AND PLUMBING RENOVATION  
 84 DAY DORM ROAD  
 BUJES CREEK, NC 27506  
 CONSTRUCTION DOCUMENTS

SEAL



KEY PLAN



SCALE

REVISIONS

NO.	DESCRIPTION	DATE

DRAWN BY: CDB  
 APPROVED BY: KSC  
 CHECKED BY: WHH  
 DATE: 09/29/2018


TITLE  
**CRAWLSPACE MECHANICAL DEMOLITION PLAN**

PROJECT NO. 10180405

**MD101**

SHEET NO.





**1 SECOND FLOOR MECHANICAL DEMOLITION WORK PLAN**  
SCALE: 3/16" = 1'-0"

**GENERAL NOTES:**

1. ALL CEILING AND SOFFIT TO BE DEMOLISHED BY CAMPBELL UNIVERSITY FACILITIES. REMOVE AND STORE CEILING TILES TO PERFORM WORK. COORDINATE CEILING SCOPE WITH CAMPBELL UNIVERSITY.

**KEYNOTES:**

1. PRIOR TO DEMOLITION OF SPI IT SYSTEMS, CONTRACTOR SHALL RECOVER AND DISPOSE OF ALL REFRIGERANT IN ACCORDANCE WITH APPLICABLE FEDERAL, STATE, AND LOCAL LAWS.
2. DEMOLISH AIR CONDITIONING UNIT IN ITS ENTIRETY, DISCONNECT DUCT WORK PIPING AND INSET. DEMOLISH POWER AND CONTROL EQUIPMENT AND WIRING INCLUDING BUT NOT LIMITED TO SPACE THERMOSTATS.
3. DEMOLISH REFRIGERANT LINESET FROM THE INTERIOR UNIT TO THE EXTERIOR UNIT. PATCH AND PAINT WALL PENETRATIONS WITH LIKE MATERIALS. REFER TO DETAIL.
4. DEMOLISH CONDENSATE PIPING FROM POINT INDICATED TO LOCATION OF DISCHARGE TO GRADE. PATCH AND PAINT WALL PENETRATIONS WITH LIKE MATERIALS.
5. DEMOLISH DUCTWORK IN ITS ENTIRETY.
6. DEMOLISH STEAM RADIATOR, DEMOLISH STEAM PIPE LEVEL WITH FLOOR SURFACE, PROVIDE FLOOR PLATE TO COVER PIPE. MOUNT FLUSH WITH FLOOR. COORDINATE WITH GENERAL CONTRACTOR TO COVER NEWLY EXPOSED FLOOR AND WALL AREA.
7. PATCH MECHANICAL ROOM MASONRY WALL WITH LIKE MATERIALS, PROVIDE SLEEVES FOR WIRING, PIPING, AND OTHER UTILITIES AS NEEDED TO CREATE SMOKE TIGHT WALL.
8. DEMOLISH TOILET ROOM EXHAUST GOBBLE AND CAP DUCT. PATCH AND PAINT WALL TO MATCH ADJACENT FINISH.
9. DEMOLISH PLYWOOD ENCLOSURE AROUND AC. PATCH AND PAINT WALL TO MATCH ADJACENT FINISH.



Dowberry Engineers Inc.  
2014 45th Street  
Suite 410  
Raleigh, NC 27606-0073  
919.876.2025  
NC License No. 42409




CAMPBELL UNIVERSITY  
**POWELL HALL**  
HVAC AND PLUMBING RENOVATION  
84 DAY DORM ROAD  
BUIES CREEK, NC 27506  
CONSTRUCTION DOCUMENTS

SEAL



KEY PLAN



REVISIONS

NO.	DESCRIPTION	DATE

DRAWN BY: CDB  
APPROVED BY: KSC  
CHECKED BY: WH  
DATE: 09/29/2022

TITLE  
**SECOND FLOOR MECHANICAL DEMOLITION PLAN**

PROJECT NO. 50193045

**MD121**

SHEET NO.

F


E

D

C

B

A




1 THIRD FLOOR MECHANICAL DEMOLITION PLAN  
SCALE: 3/16" = 1'-0"

**GENERAL NOTES:**



1. ACT CEILING AND SOFFIT TO BE DEMOLISHED BY CAMPBELL UNIVERSITY FACILITY. REMOVE AND STORE CEILING TILES TO PERFORM WORK COORDINATE CEILING SCOPE WITH CAMPBELL UNIVERSITY.

**KEYNOTES:**

1. PRIOR TO DEMOLITION OF SPI IT SYSTEMS, CONTRACTOR SHALL RECOVER AND DISPOSE OF ALL REFRIGERANT IN ACCORDANCE WITH APPLICABLE FEDERAL, STATE, AND LOCAL LAWS.
2. DEMOLISH AIR CONDITIONING UNIT IN ITS ENTIRETY, DISCONNECT DUCT WORK, PIPING AND LINESET, DEMOLISH POWER AND CONTROL EQUIPMENT AND WIRING INCLUDING BUT NOT LIMITED TO SPACE THERMOSTATS.
3. DEMOLISH REFRIGERANT LINESET FROM THE INTERIOR UNIT TO THE EXTERIOR UNIT, PATCH AND PAINT WALL PENETRATIONS WITH LIKE MATERIALS, REFER TO DETAIL.
4. DEMOLISH CONDENSATE PIPING FROM POINT INDICATED TO LOCATION OF DISCHARGE TO GRADE, PATCH AND PAINT WALL PENETRATIONS WITH LIKE MATERIALS.
5. DEMOLISH DUCT WORK IN ITS ENTIRETY.
6. DEMOLISH STEAM RADIATOR, DEMOLISH STEAM PIPE LEVEL WITH FLOOR SURFACE, PROVIDE FLOOR PLATE TO COVER PIPE, MOUNT FLUSH WITH FLOOR, COORDINATE WITH GENERAL CONTRACTOR TO COVER NEWLY EXPOSED FLOOR AND WALL.
7. PATCH MECHANICAL ROOM MASONRY WALL WITH LIKE MATERIALS, PROVIDE SLEEVES FOR WIRING, PIPING, AND OTHER UTILITIES AS NEEDED TO CREATE SMOKE TIGHT WALL.
8. DEMOLISH TOILET ROOM EXHAUST GOBBLE AND CAP BUUCT, PATCH AND PAINT WALL TO MATCH ADJACENT FINISH.
9. DEMOLISH ROOF MOUNTED EXHAUST FAN, DEMO POWER AND CONTROL WIRE AND DISCONNECT, ROOF CURB TO REMAIN FOR REUSE.
10. DEMOLISH PLYWOOD ENCLOSURE AROUND AC, PATCH AND PAINT WALL TO MATCH ADJACENT FINISH.



CAMPBELL UNIVERSITY  
POWELL HALL  
HVAC AND PLUMBING RENOVATION  
84 DAY DORM ROAD  
BUIES CREEK, NC 27506  
CONSTRUCTION DOCUMENTS



**REVISIONS**


NO.	DESCRIPTION	DATE

DRAWN BY: CDB  
APPROVED BY: KSC  
CHECKED BY: WH  
DATE: 09/20/2024


**TITLE**  
THIRD FLOOR MECHANICAL DEMOLITION PLAN

PROJECT NO. 50183045

**MD131**  
SHEET NO.



CAMPBELL UNIVERSITY  
 POWELL HALL  
 HVAC AND PLUMBING RENOVATION  
 84 DAY DORM ROAD  
 BUJES CREEK, NC 27506  
 CONSTRUCTION DOCUMENTS



REVISIONS


NO.	DESCRIPTION	DATE
1	DOAS RELOCATION	8/11/20

DRAWN BY: CDB  
 APPROVED BY: JSC  
 CHECKED BY: WHH  
 DATE: 09/29/2020

TITLE  
**CRAWLSPACE MECHANICAL NEW WORK PLAN**

PROJECT NO. 1019045

**M-101**  
 SHEET NO.




**1 CRAWLSPACE MECHANICAL NEW WORK PLAN**  
 SCALE: 3/16" = 1'-0"

**GENERAL NOTES:**  
 1. DEMOLISH STEAM AND CONDENSATE PIPING IN CRAWLSPACE AS NEEDED TO MAKE ROOM FOR NEW CONSTRUCTION.

- KEYNOTES:**
- UP TO FC&A AND FC&A.
  - UP TO FC&A AND FC&A.
  - PROVIDE REFRIGERANT LINESET FROM CONDENSING UNITS TO INDOOR UNITS. SEE FIRST FLOOR FOR CONTINUATION.
  - DISCHARGE CONDENSATE @ ABOVE GRADE USING EXISTING CRAWLSPACE PENETRATIONS FROM DEMOLISHED UNITS. PROVIDE SPLASH BLOCK.

01/2020 10:11:34 AM  
 P:\2020\1019045\CRAWLSPACE MECHANICAL NEW WORK PLAN.DWG



1 FIRST FLOOR MECHANICAL NEW WORK PLAN AREA A  
SCALE: 3/16" = 1'-0"

GENERAL NOTES:

- COORDINATE WITH GENERAL CONTRACTOR FOR PENETRATIONS, DUCT SHAFTS, SOFFITS, AND CEILINGS.

KEYNOTES:

- PROVIDE DOAS, PROVIDE POWER AND CONTROL WIRING AND DISCONNECTING MEANS, LOCATE DOAS TO MEET ALL EQUIPMENT CLEARANCES, PROVIDE 1" DEEP CONCRETE PAD WITH CRUSHED GRAVEL BASE, PAD SHALL BE 6" LONGER AND WIDER THAN UNIT FOOT PRINT, PROVIDE OA DUCT, ROUTE TO GRAV SPACE AS SHOWN, PROVIDE BRICK LINTEL, SEE DETAILS FOR MORE INFORMATION.
- PROVIDE FAN COIL UNIT, PROVIDE DUCTWORK COMPLETE WITH INSULATION, SUPPORTS, AND ACCESSORIES AND ROUTE AS SHOWN.
- PROVIDE CONDENSING UNIT MOUNT TO EXISTING CONCRETE PAD, PROVIDE POWER AND CONTROL WIRE AND DISCONNECTING MEANS.
- EXTERIOR WALL PENETRATION, COORDINATE WITH GENERAL CONTRACTOR FOR WALL PENETRATION.
- PROVIDE PTAC WITH WALL SLEEVE AND SUBBASE, INSTALL PER MANUFACTURER'S INSTRUCTIONS, COORDINATE WITH GENERAL CONTRACTOR FOR WALL PENETRATION LINTEL.
- PROVIDE EXHAUST FAN, ROUTE DUCT TO EXISTING DUCT



- REFER TO LOCATED IN PLUMBING CHASE.
- PROVIDE UNIT HEATER WITH INTEGRAL THERMOSTAT, SURFACE MOUNT ON CONCRETE BLOCK WALL PER MANUFACTURER'S INSTRUCTIONS.
- PROVIDE DUCT DETECTOR AND HARDWARE TO DOAS OR SMOKE SHUT-DOWN, PROVIDE 10X6 HINGED DOOR ACCESS.
- PROVIDE THERMOSTAT AT 48" AFF, PROVIDE WIRE-MOLD FOR CONTROL WIRING EXPOSED BENEATH THE CEILING.
- OA DUCT DOWN INTO MECHANICAL ROOM, ROUTE TO EXISTING FLOOR PENETRATION FROM DEMO BHEID TRASH SHOOT, RESIST FLOOR PENETRATION AS NEEDED, PROVIDE SLEEVE AT FLOOR PENETRATION, ROUTE DUCT INTO BUILDING THROUGH EXISTING WALL OPENING, W/LL AND ISOLATE WALL AROUND DUCT AND PROVIDE A WALL SLEEVE.
- PROVIDE OPENING ABOVE TOILET DOOR BY REMOVING THE WOOD PANEL TRIMMING, OR PROVIDE SUB TRANSFER

- GRILLE CENTERED OVER TOILET ROOM FLOOR, 74" AFF.
- PROVIDE FAN SWITCH ADJACENT TO LIGHT SWITCH MOUNT AT 48" AFF.
- ROUTE CONDENSATE TO CONDENSATE RISER FROM FCL42.3, PROVIDE WIRE INTO RISER, ROUTE CONDENSATE DOWN TO GRAV SPACE, PROVIDE ESCORTION TO COVER FLOOR PENETRATION.
- PROVIDE SUPPLY GRILLE AT 84" AFF TO BOTTOM OF GRILLE, PROVIDE SUB ACCESS DOOR BELOW SUPPLY GRILLE FOR ACCESS TO VOLUME DAMPER, AFTER ALL BRANCHES, TRANSFER TO 19X19, SEE SHEET M-11 FOR CONTINUATION, COORDINATE WITH GENERAL CONTRACTOR TO PROVIDE DUCT CHASE AND ACCESS DOOR IN CHASE.
- UP TO FCL42-3, ROUTE ABOVE CEILING.
- PROVIDE EXTERIOR OA DUCT WITH ALUMINUM JACKETING.
- PROVIDE NETWORK CONTROL PANEL, PROVIDE 120V

- POWER AND DATA WIRING.
- GAS METER, REFER TO PLUMBING PLANS FOR MORE INFORMATION.
- PROVIDE EXHAUST FAN, PROVIDE POWER AND CONTROL WIRE, PROVIDE EXHAUST DUCT, ROUTE TO EXTERIOR WALL AND PROVIDE WALL VENT WITH BRD SCREEN AND BACKDRAFT DAMPER.
- DUCT ROUTED UP BETWEEN JOISTS.



CAMPBELL UNIVERSITY  
POWELL HALL  
HVAC AND PLUMBING RENOVATION  
64 DAY DORM ROAD  
BUJES CREEK, NC 27506  
CONSTRUCTION DOCUMENTS



REVISIONS

NO.	DESCRIPTION	DATE
1	DOAS RELOCATION	6/11/25
	DESCRIPTION	

DRAWN BY: CDB  
APPROVED BY: JSC  
CHECKED BY: WHH  
DATE: 06/23/2025

TITLE: FIRST FLOOR MECHANICAL NEW WORK PLAN AREA A

PROJECT NO.: 50193005

M-111  
SHEET NO.

6/11/2025 10:51:26 AM  
 P:\2025\06\11\25\MECH\NEW WORK PLAN AREA A.DWG

F


E

D

C

B

A



1 SECOND FLOOR MECHANICAL NEW WORK PLAN  
SCALE: 3/16" = 1'-0"



GENERAL NOTES:

KEYNOTES:

- PROVIDE FAN COIL UNIT. PROVIDE DUCT WORK FROM FAN COIL UNIT TO SPACES SERVED. PROVIDE FLEXIBLE DUCT CONNECTIONS AND TRANSITIONS AS NECESSARY.
- PROVIDE REFRIGERANT PIPING, INSET BETWEEN CORRESPONDING INDOOR AND OUTDOOR UNITS. PROVIDE WITH 1/2" ELASTOMERIC CLOSED CELL INSULATION. INSTALL PER MANUFACTURER'S INSTALLATION.
- PROVIDE PTAC. INSTALL PER MANUFACTURER'S INSTRUCTIONS. REFER TO DETAIL FOR ADDITIONAL INFORMATION.
- PROVIDE EXHAUST FAN. ROUTE DUCT TO EXISTING DUCT RISER, LOCATED IN PLUMBING CHASE.
- PROVIDE THERMOSTAT AT 48" AFF. PROVIDE WIRE-AND-FOR CABLE EXPOSED BENEATH THE CEILING.
- DOWN TO 1ST FLOOR & UP TO 3RD FLOOR.
- ROUTE SHALL WYE INTO CONDENSATE FROM FCU-3. ROUTE DOWN TO GRAVSPACE USING EXISTING CONDENSATE ROUTE. PROVIDE ESCUTCHEON TO COVER FLOOR PENETRATION.
- PROVIDE 80# TRANSFER GRILLE CENTERED OVER TOILET ROOM DOOR, 7'-0" AFF.
- RA DUCT 14X12 FROM UNIT. TRANSITION TO 16X10.
- AFTER ALL BRANCHES, TRANSITION TO 12X12. SEE SHEET M-131 FOR CONTINUATION.
- PROVIDE FIRE DAMPER WITH ACCESS DOOR AT FLOOR PENETRATION FOR DUCT RISER. COORDINATE WITH GENERAL CONTRACTOR TO PROVIDE DUCT CHASE AND ACCESS DOOR IN CHASE.
- DUCT ROUTED UP BETWEEN JOISTS.
- PROVIDE UNIT HEATER WITH INTEGRAL THERMOSTAT. SURFACE MOUNT ON CONCRETE BLOCK WALL PER MANUFACTURER'S INSTRUCTIONS.



CAMPBELL UNIVERSITY  
POWELL HALL  
HVAC AND PLUMBING RENOVATION  
84 DAY DORM ROAD  
BUIES CREEK, NC 27506  
CONSTRUCTION DOCUMENTS



REVISIONS

NO.	DESCRIPTION	DATE

1. DOAS RELOCATION 06/11/20  
NO. DESCRIPTION DATE

TITLE  
SECOND FLOOR MECHANICAL NEW WORK PLAN




PROJECT NO. 50183045

M-121  
SHEET NO.

© 2020 BY THE STATE OF NORTH CAROLINA. ALL RIGHTS RESERVED. THIS DOCUMENT IS THE PROPERTY OF THE STATE OF NORTH CAROLINA. IT IS TO BE USED ONLY FOR THE PROJECT AND SITE SPECIFICALLY IDENTIFIED HEREIN. IT IS NOT TO BE REPRODUCED, COPIED, OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE EXPRESS WRITTEN PERMISSION OF THE STATE OF NORTH CAROLINA.









1 DUCT 45° LATERAL TAKE-OFF SCALE: NTS 23313-206


2 DUCT MITERED 90° ELBOW SCALE: NTS 23313-207

3 AHU DRAIN TRAP - DRAW THROUGH SCALE: NTS 23330A-001



4 BRICK LINTELS SCALE: NTS 23330B-001

5 BRICK LINTELS SCALE: NTS 23330A-001



CAMPBELL UNIVERSITY  
POWELL HALL  
HVAC AND PLUMBING RENOVATION  
84 DAY DORM ROAD  
BUNES CREEK, NC 27706  
CONSTRUCTION DOCUMENTS



KEY PLAN

SCALE

REVISIONS

NO.	DESCRIPTION	DATE

NO. DESCRIPTION DATE

DRAWN BY            CDB

APPROVED BY            KSC

CHECKED BY            WHH

DATE            09/20/2026

TITLE

PROJECT NO. 50183045

**M-502**

SHEET NO.

DEDICATED OUTDOOR AIR UNIT SCHEDULE

Table with columns: MARK, MANUFACTURER / MODEL, TYPE, DRIVE TYPE, CAPACITY, CONNECT, SINGLE FAN, DEHUMIDIFICATION, COOLING CAPACITY, TOTAL SENSIBLE, SENSIBLE, EER, NUMBER, HEATING CAPACITY, REHEAT CAPACITY, ELECTRICAL, MAX SOUND, DIMENSIONS AND WEIGHT, NOTES.

- NOTES: 1. REFER TO SECTION 237433 FOR ADDITIONAL REQUIREMENTS. 2. MAX COOLING COIL FACE VELOCITY = 500 FPM. 3. PROVIDE SINGLE-POINT ELECTRICAL CONNECTION AND FUSED-DISCONNECT. 4. PROVIDE SCR CONTROLLER FOR ELECTRIC HEATING COILS. 5. PROVIDE LOW AMBIENT COOLING OPERATION DOWN TO -20 DEG F. 6. PROVIDE HAL GUARD FOR CONDENSING COIL. 7. PROVIDE CONCRETE AND THAT IS 4-INCHES LONGER AND WIDER THAN UNIT FOOTPRINT AND 4-INCHES DEEP WITH 4-INCHES DEEP CURBED STONE BASE. 8. PROVIDE MODULATING INVERTER COMPRESSOR CIRCUIT FOR MAINTAINING DEWPOINT CONTROL. 9. PROVIDE W/HD THERMOSTAT NOT ACCEPTABLE. 10. REFER TO CONDENSING UNIT SCHEDULE FOR ASSOCIATED DX COIL CONDENSING UNIT.

FAN COIL UNIT SCHEDULE

Table with columns: MARK, TYPE, MANUFACTURER / MODEL, SUPPLY AIR FAN, FAN SPEED, ESP, NOMINAL MOTOR, VOLTAGE, OUTSIDE AIR, COOLING COIL, REHEAT COIL, ELECTRICAL, DIMENSIONS AND WEIGHT, NOTES.

- NOTES: 1. REFER TO SECTION 238219 FOR ADDITIONAL REQUIREMENTS. 2. MAX COOLING COIL FACE VELOCITY = 500 FPM. 3. PROVIDE MOTOR-RATED DISCONNECT SWITCH. 4. PROVIDE COMBINATION MOTOR-STARTER AND DISCONNECT SWITCH. 5. PROVIDE AUXILIARY HEATER KIT (FAHR). 6. PROVIDE W/HD THERMOSTAT NOT ACCEPTABLE. 7. REFER TO CONDENSING UNIT SCHEDULE FOR ASSOCIATED DX COIL CONDENSING UNIT.

CONDENSING UNIT SCHEDULE

Table with columns: MARK, SERVICE, TYPE, MANUFACTURER / MODEL, COOLING, HEAT PUMP, NUMBER OF COILS, MAX SOUND, ELECTRICAL, DIMENSIONS AND WEIGHT, NOTES.

- NOTES: 1. REFER TO SECTION 238223 FOR ADDITIONAL REQUIREMENTS. 2. SOUND PERFORMANCE IS BASED ON SOUND PRESSURE LEVELS MEASURED AT 3 FEET FROM UNIT AT FULL CAPACITY IN ACCORDANCE WITH AHRU 270. 3. ALL UNITS SHALL MEET OR EXCEED SEASONAL ENERGY EFFICIENCY RATIO (SEER) FOR NOMINAL COOLING SIZES LESS THAN 65,000 BTU/h. 4. HEAT PUMPS SHALL MEET OR EXCEED HEATING SEASONAL PERFORMANCE FACTOR (HSPF) FOR NOMINAL COOLING SIZES LESS THAN 65,000 BTU/h. 5. SIZE REFRIGERANT PIPING PER MANUFACTURERS RECOMMENDATIONS. 6. PROVIDE FUSED-DISCONNECT SWITCH. 7. PROVIDE LOW AMBIENT TEMPERATURE OPTION.

FIRST FLOOR PACKAGE TERMINAL HEAT PUMP SCHEDULE

Table with columns: MARK, MANUFACTURER / MODEL, REFRIG, SUPPLY AIR FAN, COOLING COIL, HEATING COIL, ELECTRICAL, DIMENSIONS AND WEIGHT, NOTES.

- NOTES: 1. PROVIDE UNIT BY ONE OF THE FOLLOWING MANUFACTURERS: FRIEDRICH OR AMANA. 2. PROVIDE MANUFACTURER UNIT SUBBASE WITH INTEGRAL MOTOR-RATED DISCONNECT SWITCH. 3. PROVIDE WITH MANUFACTURER WALL SLEEVE, COORDINATE WALL SLEEVE WITH WALL THICKNESS EAST EACH LOCATION WALL THICKNESS VARIES. 4. PROVIDE WALL-MOUNTED WIRED, NON-PROGRAMMABLE THERMOSTAT. WIRELESS THERMOSTATS ARE NOT ACCEPTABLE. 5. PROVIDE ARCHITECTURAL EXTERIOR GRILLE, COORDINATE COLOR WITH OWNER. 6. PROVIDE 2 EXTRA FRONT-END AIR FILTERS FOR EACH UNIT. DELIVER TO OWNER PRIOR TO PROJECT CLOSEOUT.

SECOND FLOOR PACKAGE TERMINAL HEAT PUMP SCHEDULE

Table with columns: MARK, MANUFACTURER / MODEL, REFRIG, SUPPLY AIR FAN, COOLING COIL, HEATING COIL, ELECTRICAL, DIMENSIONS AND WEIGHT, NOTES.

- NOTES: 1. PROVIDE UNIT BY ONE OF THE FOLLOWING MANUFACTURERS: FRIEDRICH OR AMANA. 2. PROVIDE MANUFACTURER UNIT SUBBASE WITH INTEGRAL MOTOR-RATED DISCONNECT SWITCH. 3. PROVIDE WITH MANUFACTURER WALL SLEEVE, COORDINATE WALL SLEEVE WITH WALL THICKNESS EAST EACH LOCATION WALL THICKNESS VARIES. 4. PROVIDE WALL-MOUNTED WIRED, NON-PROGRAMMABLE THERMOSTAT. WIRELESS THERMOSTATS ARE NOT ACCEPTABLE. 5. PROVIDE ARCHITECTURAL EXTERIOR GRILLE, COORDINATE COLOR WITH OWNER. 6. PROVIDE 2 EXTRA FRONT-END AIR FILTERS FOR EACH UNIT. DELIVER TO OWNER PRIOR TO PROJECT CLOSEOUT.

GRAVITY ROOF VENTILATOR SCHEDULE

Table with columns: MARK, TYPE, MANUFACTURER / MODEL, AIR FLOW, APD, VENT SIZE, THROAT, MAX HEIGHT, DAMPER, TYPE, NOTES.

- NOTES: 1. REFER TO SECTION 239722 FOR ADDITIONAL REQUIREMENTS. 2. PROVIDE FACTORY-FABRICATED ROOF CURB. COORDINATE EXACT LOCATION AND SIZE OF EXISTING ROOF CURBS PRIOR TO ORDERING. MATCH EXISTING CURB SIZE OR PROVIDE CURB ADAPTER.


THIRD FLOOR PACKAGE TERMINAL HEAT PUMP SCHEDULE

Table with columns: MARK, MANUFACTURER / MODEL, REFRIG, SUPPLY AIR FAN, COOLING COIL, HEATING COIL, ELECTRICAL, DIMENSIONS AND WEIGHT, NOTES.

- NOTES: 1. PROVIDE UNIT BY ONE OF THE FOLLOWING MANUFACTURERS: FRIEDRICH OR AMANA. 2. PROVIDE MANUFACTURER UNIT SUBBASE WITH INTEGRAL MOTOR-RATED DISCONNECT SWITCH. 3. PROVIDE WITH MANUFACTURER WALL SLEEVE, COORDINATE WALL SLEEVE WITH WALL THICKNESS EAST EACH LOCATION WALL THICKNESS VARIES. 4. PROVIDE WALL-MOUNTED WIRED, NON-PROGRAMMABLE THERMOSTAT. WIRELESS THERMOSTATS ARE NOT ACCEPTABLE. 5. PROVIDE ARCHITECTURAL EXTERIOR GRILLE, COORDINATE COLOR WITH OWNER. 6. PROVIDE 2 EXTRA FRONT-END AIR FILTERS FOR EACH UNIT. DELIVER TO OWNER PRIOR TO PROJECT CLOSEOUT.



CAMPBELL UNIVERSITY POWELL HALL 84 DAY DORM ROAD BUIES CREEK, NC 27506 CONSTRUCTION DOCUMENTS



KEY PLAN

SCALE

REVISIONS

Table with columns: NO., DESCRIPTION, DATE

TITLE SCHEDULES

PROJECT NO. 5019005

M-601

SHEET NO.



F


E

D

C


B

A




- NOTES:
1. PROVIDE BAC NETWORK CONTROL PANEL IN GROUND FLOOR MECHANICAL ROOM, SEE FLOOR PLANS FOR LOCATION.
  2. PROVIDE DATA DROPTHERM (L&T) FROM NETWORK CONTROL PANEL TO FT PAT SERVER FOR FINAL TERMINATIONS BY CAMPBELL I.T GROUP.
  3. PROVIDE NEW FLEDMAN RATED COMMUNICATION CABLE THROUGHOUT BUILDING TO EACH EQUIPMENT CONTROLLER.

BUILDING CONTROL DETAIL



- NOTES:
1. WIRED WALL CONTROLLER WITH OCCUPANCY SENSOR, TEMPERATURE, AND HUMIDITY, FRIEDRICH VORPHEMUTZ OR SIMILAR.
  2. SET FAN TO OPERATE ON DEMAND FOR HEATING AND COOLING.

PTAC CONTROL DETAIL



- NOTES:
1. WIRED WALL CONTROLLER WITH OCCUPANCY SENSOR, TEMPERATURE, AND HUMIDITY, HONEYWELL TC300 OR SIMILAR.

AHU CONTROL DETAIL



Dowberry Engineers Inc.  
 2014 Sycamore Road  
 Suite 100  
 Raleigh, NC 27607-0073  
 919.876.2025  
 NC License No. 042608



CAMPBELL UNIVERSITY  
 POWELL HALL  
 HVAC AND PLUMBING RENOVATION  
 84 DAY DORM ROAD  
 BUJES CREEK, NC 27506  
 CONSTRUCTION DOCUMENTS

SEAL



KEY PLAN

SCALE

REVISIONS

NO.	DESCRIPTION	DATE

NO. DESCRIPTION DATE

DRAWN BY CDB

APPROVED BY KSC

CHECKED BY WH

DATE 09/20/2025

TITLE

CONTROLS

PROJECT NO. 5018045

M-701

SHEET NO.

ABBREVIATIONS - ELECTRICAL

Table with 2 columns: Abbreviation and Description. Includes items like AMP, AMPERE, ALTERNATING CURRENT, ABOVE CEILING, ARMORED CABLE, etc.

ABBREVIATIONS - ELECTRICAL

Table with 2 columns: Abbreviation and Description. Includes items like ISO, ISOLATED, JOINT BOX, KELVIN, etc.

ABBREVIATIONS - ELECTRICAL

Table with 2 columns: Abbreviation and Description. Includes items like W, WATT, WG, WIRE GUARD, XFR, TRANSFORMER, etc.

GENERAL NOTES - ELECTRICAL

- 1. ELECTRICAL PLANS ARE GENERALLY DIAGRAMMATIC IN NATURE AND DO NOT CONVEY ALL DETAILS REQUIRED FOR A COMPLETE INSTALLATION. HOWEVER, THESE PLANS SHALL BE FOLLOWED AS CLOSE AS POSSIBLE FOR INSTALLATION PROCEDURES, THE AMOUNTS WITH EQUIPMENT. REFER TO ARCHITECTURAL PLANS FOR EXACT LOCATIONS, DIMENSIONS AND CONNECTIONS. CONTRACTOR SHALL VERIFY ALL DIMENSIONS PRIOR TO COMMENCING WORK. CONTRACTOR SHALL VERIFY STRUCTURAL AND FINISH CONDITIONS PRIOR TO COMMENCING WORK. CONTRACTOR SHALL VERIFY ALL DIMENSIONS PRIOR TO COMMENCING WORK. CONTRACTOR SHALL VERIFY ALL DIMENSIONS PRIOR TO COMMENCING WORK. CONTRACTOR SHALL VERIFY ALL DIMENSIONS PRIOR TO COMMENCING WORK.

GENERAL NOTES - ELECTRICAL


- 21. ALL EXPOSED RACEWAY ENDS SHALL BE PROVIDED WITH PLASTIC BUSHINGS. 22. ALL ELECTRICAL CONDUCTORS, EQUIPMENT AND TERMINALS SHALL BE 75°C RATED UNLESS NOTED OTHERWISE. 23. MINIMUM CONDUCTOR SIZE OF 12AWG COPPER, THIRTYFOUR, FOR BRANCH CIRCUITS. 24. ALL BRANCH AND FEEDER CIRCUITS SHALL ORIGINATE FROM PANELS AND SERVE DEVICES AND EQUIPMENT AS INDICATED ON PLANS AND SCHEDULES. IN THE EVENT OF A CONFLICT, DEVIATION OR DISCREPANCY, CONTRACTOR SHALL PROVIDE WRITTEN NOTIFICATION TO ENGINEER OF RECORD FOR CLARIFICATION PRIOR TO COMMENCING WORK.

RENOVATION NOTES - ELECTRICAL

- 1. NEW WORK SHOWN BOLD AND CONTINUOUS. EXISTING TO REMAIN WORK SHOWN LIGHT AND CONTINUOUS. 2. NOT ALL ELECTRICAL DEVICES AND EQUIPMENT ARE SHOWN. LOCATIONS AND ASSOCIATED CIRCUITS OF EXISTING DEVICES AND EQUIPMENT SHOWN ARE BASED IN PART UPON PREVIOUS DRAWINGS. FIELD OBSERVATIONS AND INFORMATION FURNISHED BY OTHERS AND SHALL BE CONSIDERED APPROPRIATE. CONTRACTOR SHALL VERIFY EXISTING CONDITIONS PRIOR TO COMMENCING WORK. 3. ALL EXISTING DEVICES AND EQUIPMENT SHALL REMAIN IN PLACE AND OPERATIONAL UNLESS NOTED OTHERWISE.



CAMPBELL UNIVERSITY  
POWELL HALL  
HVAC AND PLUMBING RENOVATION  
84 DAY DORM ROAD  
BUILES CREEK, NC 27506  
CONSTRUCTION DOCUMENTS



KEY PLAN, SCALE, REVISIONS table with columns for NO., DESCRIPTION, DATE.

TITLE  
ELECTRICAL SYMBOLS & ABBREVIATIONS

PROJECT NO. 5019046

E-001

SHEET NO.





Dowberry Engineers Inc.  
2014 Sycamore Road  
Durham, NC 27603  
919.487.2000  
NC License No. 2408




CAMPBELL UNIVERSITY  
**POWELL HALL**  
HVAC AND PLUMBING RENOVATION  
84 DAY DORM ROAD  
BUJES CREEK, NC 27506  
CONSTRUCTION DOCUMENTS

SEAL



KEY PLAN



SCALE

REVISIONS

NO.	DESCRIPTION	DATE


NO. DESCRIPTION DATE  
DRAWN BY: BIS/SMS  
APPROVED BY: JWA/JSA  
CHECKED BY: JSA  
DATE: 09/20/2018

TITLE  
**FIRST FLOOR ELECTRICAL DEMOLITION PLAN AREA A**

PROJECT NO. 10180405

**ED111**

SHEET NO.



**1 FIRST FLOOR ELECTRICAL DEMOLITION PLAN AREA A**  
SCALE: 3/16" = 1'-0"

**GENERAL NOTES:**  
1. DEMOLISH ALL BRANCH CIRCUIT WIRING INDICATED BACK TO SOURCE. UNUSED PORTIONS OF CONDUIT TO BE REMOVED OTHERWISE RETAIN FOR REUSE.

**KEYNOTES:**  
1. UNKNOWN SOURCE, CONTRACTOR TO VERIFY BRANCH CIRCUIT SOURCE IN FIELD.  
2. CRAWL SPACE PANEL (BELOW).

09/20/2018 10:16:40 AM P:\2018\09\20\ED111\FIRST FLOOR ELECTRICAL DEMOLITION PLAN AREA A.JWB



F


E

D

C

B

A



**1 SECOND FLOOR ELECTRICAL DEMOLITION WORK PLAN**  
 SCALE: 3/16" = 1'-0"

**GENERAL NOTES:**

1. DEMOLISH ALL BRANCH CIRCUIT WIRING INDICATED BACK TO SOURCE. UNUSED PORTIONS OF CONDUIT TO BE REMOVED OTHERWISE RETAIN FOR REUSE.

**KEYNOTES:**

1.




Dowberry Engineers Inc.  
 2014 4th Street  
 Suite 100  
 Raleigh, NC 27606-0073  
 919.876.2025  
 NC License No. 42408




CAMPBELL UNIVERSITY  
**POWELL HALL**  
 HVAC AND PLUMBING RENOVATION  
 84 DAY DORM ROAD  
 BUJES CREEK, NC 27506  
 CONSTRUCTION DOCUMENTS

SEAL



KEY PLAN



SCALE: 1/8" = 1'-0"

REVISIONS

NO.	DESCRIPTION	DATE

DRAWN BY: BES/KMS  
 APPROVED BY: JWAK  
 CHECKED BY: HSA  
 DATE: 09/29/2020

TITLE  
**SECOND ELECTRICAL DEMOLITION PLAN**


PROJECT NO. 50183045

**ED121**

SHEET NO.

09/29/2020 10:47 AM P:\03\18ED010-C230-00140CA-01M021PDE\18ED010-C230-00140CA-01M021PDE.dwg






**1** FIRST FLOOR ELECTRICAL NEW WORK PLAN AREA A  
 SCALE: 3/16" = 1'-0"

**GENERAL NOTES:**



1. REFER TO SHEET E-101 FOR ELECTRICAL NOTES, SYMBOLS AND ABBREVIATIONS.

**KEYNOTES:**

- FAN PROVIDED WITH AN INTEGRAL LIGHT. BOTH OPERATE FROM EXISTING FAN WALL SWITCH. RECONNECT TO EXISTING FAN CIRCUIT.
- PFRACING LURES INTEGRAL DISCONNECT IN BASE. NEATLY INSTALL EXPOSED CONDUIT ALONG WALL TO DISCONNECT WITH BENDS NOT BOXES. CONTRACTOR TO PAINT EXPOSED CONDUIT IT'S EACH FITTING.
- PROVIDE DOAS DUCT DETECTOR IN CRAWL SPACE. REFER TO MECHANICAL PLAN, MECHANICAL CONTROLS TO SHUTDOWN DOAS. CONNECT TO EXISTING FIRE ALARM SYSTEM FOR SUPERBERRY ALARM. PROVIDE UPDATED NFPA 72 RECORD OF COMPLETION FOR ENGINEER REVIEW.
- PROVIDE 3P-200A FUSED DISCONNECT, NEMA 3R FUSED AT 125A.
- CRAWL SPACE PANEL (BELOW).
- ELECTRICAL CONTRACTOR TO INSTALL AND WIRE A 120V EPD SWITCH FOR PLUMBING EQUIPMENT, FURNISHED BY PLUMBING CONTRACTOR, COORDINATE LOCATION WITH PLUMBING.



CAMPBELL UNIVERSITY  
**POWELL HALL**  
 HVAC AND PLUMBING RENOVATION  
 84 DAY DORM ROAD  
 BUJES CREEK, NC 27506  
 CONSTRUCTION DOCUMENTS



REVISIONS

NO.	DESCRIPTION	DATE
1	DOAS RELOCATION	8/11/20


DRAWN BY: BES/SMS  
 APPROVED BY: JWAF  
 CHECKED BY: HSA  
 DATE: 09/29/2020

TITLE  
**FIRST FLOOR ELECTRICAL NEW WORK PLAN AREA A**

PROJECT NO. 20190005

**E-111**  
 SHEET NO.






**1 SECOND FLOOR ELECTRICAL NEW WORK PLAN**  
SCALE: 3/16" = 1'-0"

**GENERAL NOTES:**

1. REFER TO SHEET E-201 FOR ELECTRICAL NOTES, SYMBOLS AND ABBREVIATIONS.

**KEYNOTES:**

- 1. FAN PROVIDED WITH AN INTEGRAL LIGHT, BOTH OPERATE FROM EXISTING FAN WALL SWITCH. RECONNECT TO EXISTING FAN CIRCUIT.
- 2. IF TYPING LINES INTEGRAL, DISCONNECT BY BASE, NEATLY INSTALL EXPOSED CONDUIT ALONG WALL TO DISCONNECT WITH BENDS NOT BOXES, CONTRACTOR TO PAINT EXPOSED CONDUIT (TYP EACH PTAC).



CAMPBELL UNIVERSITY  
**POWELL HALL**  
 HVAC AND PLUMBING RENOVATION  
 84 DAY DORM ROAD  
 BUJES CREEK, NC 27506  
 CONSTRUCTION DOCUMENTS

SEAL

5/20/2024

KEY PLAN

SECOND FLOOR

SCALE

1" = 100'

REVISIONS

NO.	DESCRIPTION	DATE

NO. DESCRIPTION DATE

DRAWN BY: BES/SMS

APPROVED BY: JKW

CHECKED BY: HSA

DATE: 05/20/2024

TITLE

**SECOND ELECTRICAL NEW WORK PLAN**

PROJECT NO. 50183045

**E-121**

SHEET NO.

F


E

D

C

B

A



① THIRD FLOOR ELECTRICAL NEW WORK PLAN  
 SCALE: 3/16" = 1'-0"

**GENERAL NOTES:**

1. REFER TO SHEET E-101 FOR ELECTRICAL NOTES, SYMBOLS AND ABBREVIATIONS.

**KEYNOTES:**

- 1. FAN PROVIDED WITH AN INTEGRAL LIGHT, BOTH OPERATE FROM EXISTING FAN WALL SWITCH. RECONNECT TO EXISTING FAN CIRCUIT.
- 2. IF TYPING WIRE IS INTEGRAL, DISCONNECT BY BASE, NEATLY INSTALL EXPOSED CONDUIT ALONG WALL TO DISCONNECT WITH BENDS NOT BOXES, CONTRACTOR TO PAINT EXPOSED CONDUIT (TYP EACH PTAC).




Dowberry Engineers Inc.  
 2014 W 4th Street  
 Suite 410  
 Raleigh, NC 27604-0073  
 919.876.2025  
 NC License No. 42408




CAMPBELL UNIVERSITY  
**POWELL HALL**  
 HVAC AND PLUMBING RENOVATION  
 84 DAY DORM ROAD  
 BUJES CREEK, NC 27506  
 CONSTRUCTION DOCUMENTS

SEAL



KEY PLAN



REVISIONS

NO.	DESCRIPTION	DATE

DRAWN BY \_\_\_\_\_ VALUE  
 APPROVED BY \_\_\_\_\_ VALUE  
 CHECKED BY \_\_\_\_\_ VALUE  
 DATE \_\_\_\_\_ 09/29/2016

TITLE  
**THIRD FLOOR ELECTRICAL NEW WORK PLAN**

PROJECT NO. 50193045

**E-131**

SHEET NO.



EXISTING PANEL L				BRANCH: NORMAL				NEW WORK			
CKT	LOAD VA	DESCRIPTION	CIRCUIT BREAKER		PHASE		CIRCUIT BREAKER		DESCRIPTION	LOAD VA	CKT
			NOTE	FUNCTION TRIP	A	B	TRIP FUNCTION	NOTE			
1	0	EXHAUST FAN MAIN PANEL ROOM	EX	20	2500		30		PTAC-1-11 (2 #10 AWG + 1 #10GND, 3/4")	2500	2
3	180	DOAS YARD REC	EX	20	2500		30		PTAC-1-12 (2 #10 AWG + 1 #10GND, 3/4")	2500	4
5	0	SPACE								2500	6
7	0	SPACE							PTAC-1-13 (2 #10 AWG + 1 #10GND, 3/4")	2500	8
9	0	SPACE							SPACE	0	10
11	0	FPE ALARMS AND HVAC POWER SUPPLY	EX	20	0	0	20	EX	ROOF FAN	0	12
13	0	1ST 2ND FLOOR	EX	20	0	0	20	EX	ROOF FAN C-FLAMP	0	14
15	0	EXF LIGHTS JAMES SIDE	EX	20	2500		30	EX	PTAC-1-13 (2 #10 AWG + 1 #10GND, 3/4")	2500	16
17	0	ENERGY MAN	EX	20	2500		30	EX	ENERGY MAN 3RD FLOOR	2500	18
19	750	CPM1	2	20	180	750	20	EX	SPACE	0	20
21	180	CP1	2	20	180		20	EX	SPACE	0	22
23	0	SPACE							SPACE	0	24
25	0	MEYER'S SYSTEM	EX	20	0	0	20	EX	SPACE	0	26
27	0	SPACE							PTAC-1-14 (2 #10 AWG + 1 #10GND, 3/4")	2500	28
29	0	SPACE							SPACE	0	30
31	0	SPACE	EX	20	0	0		EX	SPACE	0	32
33	0	SPACE							SPACE	0	34
35	0	SPACE							SPACE	0	36
37	0	SPACE							SPACE	0	38
39	0	SPACE							SPACE	0	40
41	0	SPACE							SPACE	0	42

LOAD TYPE				CONNECTED				DEMAND			
EXISTING	0	125%	0	EXISTING	0	125%	0	EXISTING	0	125%	0
RECEPTACLES	180	100%	180	RECEPTACLES	0	100%	0	RECEPTACLES	0	100%	0
MOTOR	0	100%	0	MOTOR	0	100%	0	MOTOR	0	100%	0
LARGEST MOTOR	0	125%	0	LARGEST MOTOR	0	125%	0	LARGEST MOTOR	0	125%	0
HVAC	3000	100%	3000	HVAC	15000	100%	15000	HVAC	15000	100%	15000
LIGHTING	0	125%	0	LIGHTING	0	125%	0	LIGHTING	0	125%	0
KITCHEN	0	100%	0	KITCHEN	0	100%	0	KITCHEN	0	100%	0
OTHER	900	100%	900	OTHER	0	100%	0	OTHER	0	100%	0
TOTAL	2110		2110	TOTAL	10000		10000	TOTAL	10000		10000

FUNCTIONS AND ABBREVIATIONS				PANEL DEMAND TOTALS			
1. PROVIDE NEW BREAKER IN EXISTING SPACE	AFBC: ARC FAULT CB	SFCB: SUFFICED CB	L LONG TIME	PH A	7500	VA	62.5 AMP
2. PROVIDE NEW CIRCUIT CONNECT TO EXISTING BREAKER	CB: CIRCUIT BREAKER	SFL: SUFFICED LUGS	S SHORT TIME	PH B	7500	VA	62.5 AMP
3. MAKE EXISTING SPARE	EX: EXISTING	SR: SEE RISER	I INSTANTANEOUS				
4.	GFCP: GND FAULT CB (30mA/100mA)	ST: SHUNT TRIP	G GROUND FAULT				
	GFCB: GND FAULT CB (50mA)	UV: UNDERVOLTAGE TRIP	A ALARM				
	ARMS: ARC FLASH REDUCTION MAINTENANCE SWITCH						

EXISTING PANEL H				BRANCH: NORMAL				NEW WORK			
CKT	LOAD VA	DESCRIPTION	CIRCUIT BREAKER		PHASE		CIRCUIT BREAKER		DESCRIPTION	LOAD VA	CKT
			NOTE	FUNCTION TRIP	A	B	TRIP FUNCTION	NOTE			
1	3500	PTAC-1-08 (2 #10 AWG + 1 #10GND, 3/4")	2	40	8000		40		PTAC-1-08 (2 #10 AWG + 1 #10GND, 3/4")	2500	2
3	2500	SPACE							SPACE	0	4
5	0	AC #13 - LITELINE	EX	40	0	0	40	EX	SPACE	0	6
7	0	SPACE							SPACE	0	8
9	0	SPACE							SPACE	0	10
11	0	SPACE							SPACE	0	12
13	0	SPACE							SPACE	0	14
15	0	SPACE							SPACE	0	16
17	0	SPACE	EX	20	0	0	20	EX	SPACE	0	18
19	0	SPACE	EX	20	0	0	20	EX	SPACE	0	20
21	0	SPACE							SPACE	0	22
23	0	SPACE							SPACE	0	24
25	0	SPACE							SPACE	0	26
27	0	SPACE							SPACE	0	28
29	0	SPACE							SPACE	0	30
31	0	SPACE							SPACE	0	32
33	0	SPACE							SPACE	0	34
35	0	SPACE							SPACE	0	36
37	0	SPACE							SPACE	0	38
39	0	SPACE							SPACE	0	40
41	0	SPACE							SPACE	0	42

LOAD TYPE				CONNECTED				DEMAND			
EXISTING	0	25%	0	EXISTING	0	25%	0	EXISTING	0	25%	0
RECEPTACLES	0	0%	0	RECEPTACLES	0	0%	0	RECEPTACLES	0	0%	0
MOTOR	0	0%	0	MOTOR	0	0%	0	MOTOR	0	0%	0
LARGEST MOTOR	0	0%	0	LARGEST MOTOR	0	0%	0	LARGEST MOTOR	0	0%	0
HVAC	10000	0%	0	HVAC	68000	100%	68000	HVAC	68000	100%	68000
LIGHTING	0	25%	0	LIGHTING	0	25%	0	LIGHTING	0	25%	0
KITCHEN	0	0%	0	KITCHEN	0	0%	0	KITCHEN	0	0%	0
OTHER	0	0%	0	OTHER	0	0%	0	OTHER	0	0%	0
TOTAL	10000	0%	10000	TOTAL	88000	100%	88000	TOTAL	25330	100%	25330

FUNCTIONS AND ABBREVIATIONS				PANEL DEMAND TOTALS			
1. PROVIDE NEW BREAKER IN EXISTING SPACE	AFBC: ARC FAULT CB	SFCB: SUFFICED CB	L LONG TIME	PH A	18500	VA	154.2 AMP
2. PROVIDE NEW CIRCUIT CONNECT TO EXISTING BREAKER	CB: CIRCUIT BREAKER	SFL: SUFFICED LUGS	S SHORT TIME	PH B	18500	VA	154.2 AMP
3. MAKE EXISTING SPARE	EX: EXISTING	SR: SEE RISER	I INSTANTANEOUS				
4.	GFCP: GND FAULT CB (30mA/100mA)	ST: SHUNT TRIP	G GROUND FAULT				
	GFCB: GND FAULT CB (50mA)	UV: UNDERVOLTAGE TRIP	A ALARM				
	ARMS: ARC FLASH REDUCTION MAINTENANCE SWITCH						


EXISTING PANEL J				BRANCH: NORMAL				NEW WORK			
CKT	LOAD VA	DESCRIPTION	CIRCUIT BREAKER		PHASE		CIRCUIT BREAKER		DESCRIPTION	LOAD VA	CKT
			NOTE	FUNCTION TRIP	A	B	TRIP FUNCTION	NOTE			
1	0	SPACE							PTAC-1-16 (2 #10 AWG + 1 #10GND, 3/4")	2500	2
3	0	SPACE							SPACE	0	4
5	2500	PTAC-1-07 (2 #10 AWG + 1 #10GND, 3/4")	2	40	5000		40	EX	PTAC-1-16 (2 #10 AWG + 1 #10GND, 3/4")	2500	6
7	2500	SPACE							SPACE	0	8
9	0	NIGHT LIGHTS	EX	20	0	0	20	EX	RECEPTACLES/BATHROOMS	0	10
11	0	ROOF FAN	EX	20	0	0	20	EX	SPACE	0	12
13	0	ROOF FAN	EX	20	0	0	20	EX	SPACE	0	14
15	0	AC FAN #11	EX	20	0	0	20	EX	PTAC-1-13 (2 #10 AWG + 1 #10GND, 3/4")	2500	16
17	0	RECEPTACLES/BATHROOMS	EX	30	0	0	30	EX	SPACE	0	18
19	0	AC FAN #12	EX	20	0	0	20	EX	SPACE	0	20
21	0	SPACE							SPACE	0	22
23	0	SPACE							SPACE	0	24
25	0	SPACE							SPACE	0	26
27	0	10WV HEAT	EX	60	0	0	60	EX	BASE BOARD RECEIPT	0	28
29	0	5KV HEAT	EX	30	0	0	30	EX	OUTSIDE RECEPTACLES	0	30
31	0	SPACE							LIGHTS UNDER FLOOR	0	32
33	0	SPACE							SPACE	0	34
35	0	SPACE							SPACE	0	36
37	0	SPACE							SPACE	0	38
39	0	SPACE							SPACE	0	40
41	0	SPACE							SPACE	0	42

LOAD TYPE				CONNECTED				DEMAND			
EXISTING	0	125%	0	EXISTING	0	125%	0	EXISTING	0	125%	0
RECEPTACLES	0	100%	0	RECEPTACLES	0	100%	0	RECEPTACLES	0	100%	0
MOTOR	0	100%	0	MOTOR	0	100%	0	MOTOR	0	100%	0
LARGEST MOTOR	0	125%	0	LARGEST MOTOR	0	125%	0	LARGEST MOTOR	0	125%	0
HVAC	15000	100%	15000	HVAC	15000	100%	15000	HVAC	15000	100%	15000
LIGHTING	0	125%	0	LIGHTING	0	125%	0	LIGHTING	0	125%	0
KITCHEN	0	100%	0	KITCHEN	0	100%	0	KITCHEN	0	100%	0
OTHER	0	0%	0	OTHER	0	0%	0	OTHER	0	0%	0
TOTAL	15000		15000	TOTAL	10000		10000	TOTAL	10000		10000



FUNCTIONS AND ABBREVIATIONS				PANEL DEMAND TOTALS			
1. PROVIDE NEW BREAKER IN EXISTING SPACE	AFBC: ARC FAULT CB	SFCB: SUFFICED CB	L LONG TIME	PH A	7500	VA	62.5 AMP
2. PROVIDE NEW CIRCUIT CONNECT TO EXISTING BREAKER	CB: CIRCUIT BREAKER	SFL: SUFFICED LUGS	S SHORT TIME	PH B	7500	VA	62.5 AMP
3. MAKE EXISTING SPARE	EX: EXISTING	SR: SEE RISER	I INSTANTANEOUS				
4.	GFCP: GND FAULT CB (30mA/100mA)	ST: SHUNT TRIP	G GROUND FAULT				
	GFCB: GND FAULT CB (50mA)	UV: UNDERVOLTAGE TRIP	A ALARM				
	ARMS: ARC FLASH REDUCTION MAINTENANCE SWITCH						

NEW PANEL D				BRANCH: NORMAL				NEW WORK			
CKT	LOAD VA	DESCRIPTION	CIRCUIT BREAKER		PHASE		CIRCUIT BREAKER		DESCRIPTION	LOAD VA	CKT
			NOTE	FUNCTION TRIP	A	B	TRIP FUNCTION	NOTE			
1	3500	PTAC-2-01 (2 #10 + 1 #10 GND, 3/4")	30	5000		30			PTAC-2-02 (2 #10 + 1 #10 GND, 3/4")	2500	2
3	2500	SPACE							SPACE	0	4
5	2500	PTAC-2-03 (2 #10 + 1 #10 GND, 3/4")	30	5000		30			PTAC-2-04 (2 #10 + 1 #10 GND, 3/4")	2500	6
7	2500	SPACE									





**1 FIRST FLOOR ELECTRICAL NEW WORK PLAN AREA A**  
SCALE: 3/16" = 1'-0"  
0' 2' 4' 8'



REVISIONS		
NO.	DESCRIPTION	DATE
1	DOAS RELOCATION	6/11/26

**GENERAL NOTES:**  
1. REFER TO SHEET E-001 FOR ELECTRICAL NOTES, SYMBOLS AND ABBREVIATIONS.

- KEYNOTES:**
- FAN PROVIDED WITH AN INTEGRAL LIGHT. BOTH OPERATE FROM EXISTING FAN WALL SWITCH. RECONNECT TO EXISTING FAN CIRCUIT.
  - PTAC INCLUDES INTEGRAL DISCONNECT IN BASE. NEATLY INSTALL EXPOSED CONDUIT ALONG WALL TO DISCONNECT WITH BENDS NOT BOXES. CONTRACTOR TO PAINT EXPOSED CONDUIT (TYP EACH PTAC).
  - PROVIDE DOAS DUCT DETECTOR IN CRAWL SPACE. REFER TO MECHANICAL PLAN. MECHANICAL CONTROLS TO SHUTDOWN DOAS. CONNECT TO EXISTING FIRE ALARM SYSTEM FOR SUPERVISORY ALARM. PROVIDE UPDATED NFPA 72 RECORD OF COMPLETION FOR ENGINEER REVIEW.
  - PROVIDE 3P-200A FUSED DISCONNECT, NEMA 3R FUSED AT 125A.
  - CRAWL SPACE PANEL (BELOW).
  - ELECTRICAL CONTRACTOR TO INSTALL AND WIRE A 120V EPO SWITCH FOR PLUMBING EQUIPMENT. FURNISHED BY PLUMBING CONTRACTOR, COORDINATE LOCATION WITH PLUMBING.

DRAWN BY                      BRS, KMS  
APPROVED BY                      WAK  
CHECKED BY                      POA  
DATE                      05/20/2026

TITLE  
**FIRST FLOOR  
ELECTRICAL NEW  
WORK PLAN AREA  
A**

PROJECT NO.                      50193045

**E-111**

SHEET NO.

6/16/2026 4:07:37 AM P:\0193045\CAD\ELECTRICAL\50193045 E-111 FIRST FLOOR ELECTRICAL NEW WORK PLAN AREA A.DWG

6/16/2026 4:07:16 AM P:\01930360\CAD\ELECTRICAL\9109045 E-601 SCHEDULES.DWG

EXISTING PANEL L				BRANCH: NORMAL				NEW WORK					
CKT	LOAD VA	DESCRIPTION	CIRCUIT BREAKER			PHASE			CIRCUIT BREAKER			LOAD VA	CKT
			NOTE	FUNCTION	TRIP	A	B	TRIP	FUNCTION	NOTE	DESCRIPTION		
1	0	EXHAUST FAN MAIN PANEL ROOM		EX	20	2500		2680	30		2	PTAC-1-01 (2 #10 AWG + 1 #10GND, 3/4")	2500 2
3	180	DOAS YARD REC			20								2500 4
5	0	SPARE		EX	20	2500			30		2	PTAC-1-02 (2 #10 AWG + 1 #10GND, 3/4")	2500 6
7	0	SPARE	3		20			2500					2500 8
9	0				0				20			ROOF FAN	0 10
11	0	FIRE ALARM AND HVAC POWER SUPPLY		EX	20		0	20				ROOF FAN	0 12
13	0	A/H 2ND FLOOR			20	0		20				C-PUMP	0 14
15	0	EXT LIGHTS JONES SIDE		EX	20		2500		30		2	PTAC-1-03 (2 #10 AWG + 1 #10GND, 3/4")	2500 16
17	0	ENERGY MAN		EX	20	2500			30				2500 18
19	750	GWH-1		2	20		750	20	EX			ENERGY MAN. 3RD FLOOR	0 20
21	180	CP-1		2	20	180			20	EX		SPARE	0 22
23	0	SPACE					0	20				SPARE	0 24
25	0	METYSIS SYSTEM		EX	20	0		20				SPARE	0 26
27	0	SPARE	3		20		2500		30		1	PTAC-1-04 (2 #10 AWG + 1 #10GND, 3/4")	2500 28
29	0				2500								2500 30
31	0	SPARE		EX	20		0						0 32
33	0	SPACE					0						0 34
35	0	SPACE					0						0 36
37	0	SPACE					0						0 38
39	0	SPACE					0						0 40
41	0	SPACE					0						0 42

EXISTING PANEL H				BRANCH: NORMAL				NEW WORK					
CKT	LOAD VA	DESCRIPTION	CIRCUIT BREAKER			PHASE			CIRCUIT BREAKER			LOAD VA	CKT
			NOTE	FUNCTION	TRIP	A	B	TRIP	FUNCTION	NOTE	DESCRIPTION		
1	2500	PTAC-1-08 (2 #10 AWG + 1 #10GND, 3/4")	2		40	5000		5000	40		2	PTAC-1-09 (2 #10 AWG + 1 #10GND, 3/4")	2500 2
3	2500												2500 4
5	0	A/C #13 - LITE LINE		EX	40				40		3	SPARE	0 6
7	0												0 8
9	0	SPACE											0 10
11	0	SPACE											0 12
13	0	SPACE											0 14
15	0	SPACE		EX	20		0	20	EX				0 16
17	0	SPACE		EX	20	0		20	EX				0 18
19	0	SPACE		EX	20	0		20	EX				0 20
21	0	SPACE											0 22
23	0	SPACE											0 24
25	0	SPACE											0 26
27	0	SPACE											0 28
29	0	SPACE											0 30
31	0	SPACE											0 32
33	0	SPACE											0 34
35	0	SPACE											0 36
37	0	SPACE											0 38
39	0	SPACE											0 40
41	0	SPACE											0 42

NEW PANEL F				BRANCH: NORMAL				NEW WORK					
CKT	LOAD VA	DESCRIPTION	CIRCUIT BREAKER			PHASE			CIRCUIT BREAKER			LOAD VA	CKT
			NOTE	FUNCTION	TRIP	A	B	C	TRIP	FUNCTION	NOTE		
1	2500	PTAC-3-01 (2 #10 + 1 #10 GND, 3/4")			30	5000			30			PTAC-3-02 (2 #10 + 1 #10 GND, 3/4")	2500 2
3	2500						5000						2500 4
5	2500	PTAC-3-03 (2 #10 + 1 #10 GND, 3/4")			30			5000	30			PTAC-3-04 (2 #10 + 1 #10 GND, 3/4")	2500 6
7	2500						5000						2500 8
9	2500	PTAC-3-05 (2 #10 + 1 #10 GND, 3/4")			30			5000	30			PTAC-3-06 (2 #10 + 1 #10 GND, 3/4")	2500 10
11	2500							5000					2500 12
13	2500	PTAC-3-07 (2 #10 + 1 #10 GND, 3/4")			30			5000	30			PTAC-3-08 (2 #10 + 1 #10 GND, 3/4")	2500 14
15	2500							5000					2500 16
17	2500	PTAC-3-09 (2 #10 + 1 #10 GND, 3/4")			30			5000	30			PTAC-3-10 (2 #10 + 1 #10 GND, 3/4")	2500 18
19	2500							5000					2500 20
21	2500	PTAC-3-11 (2 #10 + 1 #10 GND, 3/4")			30			3500				FCU-3 (3 #12 + 1 #12 GND, 3/4")	1000 22
23	2500							3500		20			1000 24
25	0	SPACE				1000							1000 26
27	0	SPACE					0						0 28
29	0	SPACE						0					0 30
31	0	SPACE						0					0 32
33	0	SPACE					0						0 34
35	0	SPACE					0						0 36
37	0	SPACE					0						0 38
39	0	SPACE					0						0 40
41	0	SPACE					0						0 42

NEW PANEL C				BRANCH: NORMAL				NEW WORK					
CKT	LOAD VA	DESCRIPTION	CIRCUIT BREAKER			PHASE			CIRCUIT BREAKER			LOAD VA	CKT
			NOTE	FUNCTION	TRIP	A	B	C	TRIP	FUNCTION	NOTE		
1	1000					2000			20			UNIT HEATER 1 (3 #12 + 1 #12 GND, 3/4")	1000 2
3	1000	UNIT HEATER 1 (3 #12 + 1 #12 GND, 3/4")			20			2000	20			UNIT HEATER 2 (3 #12 + 1 #12 GND, 3/4")	1000 4
5	1000							2000					1000 6
7	1000							2000					1000 8
9	1000	FCU-1 (3 #12 + 1 #12 GND, 3/4")			20			2000	20			UNIT HEATER 3 (3 #12 + 1 #12 GND, 3/4")	1000 10
11	1000							2000					1000 12
13	2306	CU-1 (2 #10 + 1 #10 GND, 3/4")			30	4612			30			CU-2 (2 #10 + 1 #10 GND, 3/4")	2306 14
15	2306						4612						2306 16
17	2306	CU-3 (2 #10 + 1 #10 GND, 3/4")			30			2306				SPACE	0 18
19	2306							2306				SPACE	0 20
21	0	SPACE					0					SPACE	0 22
23	0	SPACE					0					SPACE	0 24
25	0	SPACE					0					SPACE	0 26
27	0	SPACE					0					SPACE	0 28
29	0	SPACE					0					SPACE	0 30
31	0	SPACE					0					SPACE	0 32
33	0	SPACE					0					SPACE	0 34
35	0	SPACE					0					SPACE	0 36
37	0	SPACE					0					SPACE	0 38
39	0	SPACE					0					SPACE	0 40
41	0	SPACE					0					SPACE	0 42

NEW PANEL D				BRANCH: NORMAL				NEW WORK					
CKT	LOAD VA	DESCRIPTION	CIRCUIT BREAKER			PHASE			CIRCUIT BREAKER			LOAD VA	CKT
			NOTE	FUNCTION	TRIP	A	B	C	TRIP	FUNCTION	NOTE		
1	2500	PTAC-2-01 (2 #10 + 1 #10 GND, 3/4")			30	5000			30			PTAC-2-02 (2 #10 + 1 #10 GND, 3/4")	2500 2
3	2500						5000						2500 4
5	2500	PTAC-2-03 (2 #10 + 1 #10 GND, 3/4")			30			5000	30			PTAC-2-04 (2 #10 + 1 #10 GND, 3/4")	2500 6
7	2500						5000						2500 8
9	2500	PTAC-2-05 (2 #10 + 1 #10 GND, 3/4")			30			5000	30			PTAC-2-06 (2 #10 + 1 #10 GND, 3/4")	2500 10
11	2500							5000					2500 12
13	2500	PTAC-2-07 (2 #10 + 1 #10 GND, 3/4")			30			5000	30			PTAC-2-08 (2 #10 + 1 #10 GND, 3/4")	2500 14
15	2500							5000					2500 16
17	2500	PTAC-2-09 (2 #10 + 1 #10 GND, 3/4")			30			5000	30			PTAC-2-10 (2 #10 + 1 #10 GND, 3/4")	2500 18
19	2500							5000					2500 20
21	2500	PTAC-2-11 (2 #10 + 1 #10 GND, 3/4")			30			3500				FCU-2 (3 #12 + 1 #12 GND, 3/4")	1000 22
23	2500							3500		20			1000 24
25	0	SPACE				1000							1000 26
27	0	SPACE					0						0 28
29	0	SPACE						0					0 30
31	0	SPACE					0						0 32
33	0	SPACE					0						0 34
35	0	SPACE					0						0 36
37	0	SPACE					0						0 38
39	0	SPACE					0						0 40
41	0	SPACE					0						0 42

NEW PANEL E				BRANCH: NORMAL				NEW WORK					
CKT	LOAD VA	DESCRIPTION	CIRCUIT BREAKER			PHASE			CIRCUIT BREAKER			LOAD VA	CKT
			NOTE	FUNCTION	TRIP	A	B	C	TRIP	FUNCTION	NOTE		
1	0	SPARE				2500			2500		2	PTAC-1-05 (2 #10 AWG + 1 #10GND, 3/4")	2500 2
3	0			EX	15			2500					2500 4
5	2500	PTAC-1-07 (2 #10 AWG + 1 #10GND, 3/4")	2		40			5000	40			PTAC-1-06 (2 #10 AWG + 1 #10GND, 3/4")	2500 6
7	2500							5000					2500 8
9	0	NIGHT LIGHTS		EX	20	0		20	EX			RECEPTACLES/BATHROOMS	0 10
11	0	LIGHTS		EX	20	0		0			3	SPARE	0 12
13	0	A/C FAN #11		EX	20	0		0					0 14
15	0							0					0 16
17	0	RECEPTACLES/BATHROOMS		EX	30	0		0			3	SPARE	0 18
19	0	A/C #13 FAN			20	0		0				BASE BOARD RECEPT	0 20
21	0	SPARE		S	EX	30	0		0		EX		0 22
23	0	SPACE						0			EX	OUTSIDE RECEPTACLES	0 24
25	0	10KW HEAT		EX	60								

**ABBREVIATIONS - MECHANICAL**

THIS IS A MASTER ABBREVIATIONS LIST. SOME ABBREVIATIONS MAY NOT APPLY TO THIS PROJECT.

(E)	EXISTING
AC	AIR CONDITIONING
AD	ACCESS DOOR
ADJ	ADJUSTABLE
AF	AIRFLOW
AFB	ABOVE FINISHED FLOOR
AHU	AIR HANDLING UNIT
AI	ANALOG INPUT
AO	ANALOG OUTPUT
ARCH	ARCHITECTURAL
ASHRAE	AMERICAN SOCIETY OF HEATING, REFRIGERATING, AND AIR-CONDITIONING ENGINEERS
ATC	AUTOMATIC TEMPERATURE CONTROL
BAS	BUILDING AUTOMATION SYSTEM
BHP	BRAKE HORSEPOWER
BI	BINARY INPUT
BMS	BUILDING MANAGEMENT SYSTEM
BO	BINARY OUTPUT
BTU	BRITISH THERMAL UNIT
BTUH	BRITISH THERMAL UNIT PER HOUR
CD	CONDENSATE DRAIN
CFM	CUBIC FEET PER MINUTE
CHWP	CHILLED WATER PUMP
CO	CARBON MONOXIDE
CO2	CARBON DIOXIDE
CONT	CONTROLS, CONTINUED
CRU	CONDENSATE RETURN UNIT
CU	CONDENSING UNIT
CUH	CABINET UNIT HEATER
Cv	VALVE COEFFICIENT
DB	DRY BULB
DBL	DOUBLE
DEG	DEGREE
DI	DIGITAL INPUT
DIA	DIAMETER
DMSS	DUCTLESS MINI-SPLIT SYSTEM
DN	DOWN
DO	DIGITAL OUTPUT
DOAS	DEDICATED OUTDOOR AIR SYSTEM
DP	DIFFERENTIAL PRESSURE
DPS	DIFFERENTIAL PRESSURE (SENSOR)
DP	DEW POINT
DWG	DRAWING
DWH	DOMESTIC WATER HEATER
DX	DIRECT EXPANSION
EA	EXHAUST AIR
EAT	ENTERING AIR TEMPERATURE
ECM	ELECTRONICALLY COMMUTATED MOTOR
EF	EXHAUST FAN
EHC	ELECTRIC HEATING COIL
ELEC	ELECTRICAL
ESP	EXTERNAL STATIC PRESSURE
ETC	ETCETERA
EUH	ELECTRIC UNIT HEATER
EUW	ELECTRIC WATER HEATER
EWT	ENTERING WATER TEMPERATURE
F	DEGREES FAHRENHEIT
FD	FIRE DAMPER OR FLOOR DRAIN
FLA	FULL LOAD AMPS
FLEX	FLEXIBLE
FP	FAN POWERED
PPM	FEET PER MINUTE
FPTD	FAN POWERED TERMINAL DEVICE
FS	FLOW SWITCH
FT	FOOT/FEET
GA	GAUGE
GAL	GALLONS
GALV	GALVANIZED
GC	GENERAL CONTRACTOR
GPH	GALLONS PER HOUR
GPM	GALLONS PER MINUTE
GR	GRAINS
GUH	GAS FIRED UNIT HEATER

**ABBREVIATIONS - MECHANICAL**

THIS IS A MASTER ABBREVIATIONS LIST. SOME ABBREVIATIONS MAY NOT APPLY TO THIS PROJECT.

H	HEIGHT
H2O	WATER
HD	HEAD
HP	HORSEPOWER
HVAC	HEATING, VENTILATION, AND AIR-CONDITIONING
IN	INCH
KW	KILOWATT
LAT	LEAVING AIR TEMPERATURE
LBS	POUNDS
LF	LINEAR FEET
M	MOTOR OR MOTORIZED DAMPER OR METER
MBH	1,000 BRITISH THERMAL UNITS PER HOUR
MCA	MINIMUM CIRCUIT AMPACITY
MERV	MINIMUM EFFICIENCY REPORTING VALUE
MFR	MANUFACTURER
MOC	MAXIMUM OVERCURRENT PROTECTION
NC	NORMALLY CLOSED OR NOISE CRITERIA
NO	NORMALLY OPEN OR NUMBER
NTS	NOT TO SCALE
OAS	OUTDOOR AIR
OAT	OUTDOOR AIR TEMPERATURE
OD	OUTSIDE DIAMETER
OS	OCCUPANCY SENSOR
P	PRESSURE OR PRESSURE SENSOR
PD	PRESSURE DROP
PH	PHASE
PHC	PREHEAT COIL
PPM	PARTS PER MILLION
PRV	PRESSURE REDUCING VALVE
PSI	POUNDS PER SQUARE INCH
PSIA	POUNDS PER SQUARE INCH ABSOLUTE
PSIG	POUNDS PER SQUARE INCH GAUGE
PTAC	PACKAGED TERMINAL AIR CONDITIONER
QTY	QUANTITY
R	RADIUS, RISE, OR REMOVE
RA	RETURN AIR
RAT	RETURN AIR TEMPERATURE
RH	RELATIVE HUMIDITY, REHEAT
RF	RETURN AIR FAN
RHC	REHEAT COIL
RPM	REVOLUTIONS PER MINUTE
SA	SUPPLY AIR
SAF	SUPPLY AIR FAN
SAT	SUPPLY AIR TEMPERATURE
SCH	SCHEDULE
SEC	SECONDS
SF	SUPPLY FAN OR SQUARE FOOT
SP	STATIC PRESSURE
SS	SPLIT SYSTEM OR STAINLESS STEEL
T, TEMP	TEMPERATURE
T&P	TEMPERATURE AND PRESSURE
T-STAT	THERMOSTAT
TON	COOLING TONS (12,000 BTUH)
TSP	TOTAL STATIC PRESSURE
TYP	TYPICAL
UH	UNIT HEATER
V, VOLT	VOLTAGE
VAV	VARIABLE AIR VOLUME
VEL	VELOCITY
VF	VENTILATION FAN
W	WIDTH OR WATTS
W/	WITH
WB	WET BULB
WC	WATER COLUMN
WG	WATER GAUGE
WPD	WATER PRESSURE DROP

**MECHANICAL GENERAL  
NEW WORK NOTES**

- ALL WORK SHALL BE PERFORMED IN ACCORDANCE WITH APPLICABLE FEDERAL, STATE AND LOCAL CODES AND REGULATIONS. MECHANICAL EQUIPMENT SHALL BE SELECTED TO MEET OR EXCEED THE REQUIREMENTS OF THE ENERGY CONSERVATION CODE. MECHANICAL WORK SHALL COMPLY WITH PROJECT SPECIFICATIONS.
- FURNISH AND INSTALL ALL INCIDENTAL ACCESSORIES REQUIRED TO MAKE THE MECHANICAL WORK COMPLETE AND OPERATIONAL.
- CONTRACTOR SHALL BE RESPONSIBLE FOR INSPECTING, TESTING AND VERIFYING OPERATION OF THE EQUIPMENT. ALL EQUIPMENT, DAMPERS, ETC. SHALL BE FUNCTIONAL BEFORE PROJECT CLOSEOUT. COORDINATE WITH ELECTRICAL AND TAB CONTRACTORS.
- THESE DRAWINGS ARE DIAGRAMMATIC. EXACT EQUIPMENT LOCATIONS AND DUCT AND PIPING ROUTING SHALL BE COORDINATED WITH THE BUILDING AND SITE CONDITIONS. THE ACTUAL EQUIPMENT AND MINIMUM CLEARANCE DIMENSIONS SHALL BE VERIFIED WITH THE SUPPLIERS.
- EQUIPMENT, DUCTWORK, PIPING AND CONDUIT LAYOUT SHALL BE COORDINATED WITH BUILDING COMPONENTS AND OTHER TRADES PRIOR TO INSTALLATION. THE SYSTEM SHALL BE NEATLY ARRANGED TO MAXIMIZE SPACE ABOVE CEILINGS AND WITHIN CHASES. MAINTAIN MINIMUM EQUIPMENT AND DEVICE MAINTENANCE CLEARANCES. DEVICES SHALL BE READILY MAINTAINABLE. METERS AND GAGES SHALL BE ORIENTED FOR BEST VIEW. INSTALLED MATERIALS NOT COORDINATED SHALL BE REMOVED AND REINSTALLED AT NO ADDITIONAL COST TO THE OWNER.
- DUCT OFFSETS SHALL BE MADE AT 15 OR 30-DEGREE ANGLES WHERE POSSIBLE BUT AT NEVER MORE THAN 45-DEGREES.
- EXACT LOCATIONS OF CEILING-MOUNTED EQUIPMENT SHALL BE COORDINATED WITH THE REFLECTED CEILING PLANS AND THE EXISTING CONDITIONS. AIR OUTLETS AND SMOKE DETECTORS SHALL BE COORDINATED TO BE NO LESS THAN 36-INCHES APART.
- WALL-MOUNTED CONTROL SENSORS SHALL BE INSTALLED AT 48-INCHES ABOVE THE FLOOR TO THE TOP OF BACK-BOX. COORDINATE EXACT LOCATIONS WITH LIGHT SWITCHES. WHEN BOTH ARE INDICATED ADJACENT TO A DOOR, LOCATE THE SWITCH CLOSEST TO THE DOOR AND THE SENSOR WITHIN 12-INCHES OF THE SWITCH.
- CONTROL AND ALARM DEVICES SHALL BE INSTALLED IN BACK-BOXES WITHIN NEW AND EXISTING WALLS. SURFACE-MOUNTED CONDUIT AND RACEWAY WILL NOT BE ACCEPTED EXCEPT FOR EXISTING SOLID CONCRETE WALLS. DEVICE BACK-BOXES IN FIRE-RATED WALLS SHALL HAVE FIRESTOP PUTTY PADS OR EQUIVALENT UL-LISTED INSTALLATION.
- INSTALL PENETRATIONS OF LIFE-SAFETY RATED ASSEMBLIES PER APPROVED UL-LISTED DETAIL IN ACCORDANCE WITH THE BUILDING CODE.
- PROVIDE A DUCT ACCESS DOOR FOR EACH DUCT-MOUNTED DEVICE REQUIRING MAINTENANCE OR INSPECTION. REFER TO SECTION 23 33 00 FOR DOOR SIZING REQUIREMENTS. COORDINATE CEILING AND WALL ACCESS DOORS WITH DUCT ACCESS DOORS.
- HVAC PIPING SHALL BE NO LESS THAN 3/4-INCH, EXCEPT REFRIGERANT PIPING.
- ALL MOTORIZED EQUIPMENT SHALL BE CONNECTED TO DUCTWORK OR PIPING WITH FLEXIBLE CONNECTIONS.
- EXTEND POWER CONDUIT AND WIRING FROM DEDICATED POWER SOURCES TO CONTROL EQUIPMENT AND DEVICES. COORDINATE POWER SOURCES WITH ELECTRICAL CONTRACTOR.
- DUCT BRANCH DUCT FROM MAIN TAKEOFF TO AIR INLET OR OUTLET SHALL MATCH SCHEDULED NECK SIZE UNLESS OTHERWISE NOTED.
- MAINTAIN MINIMUM 36-INCH CLEARANCE FOR 120/208V POWER OR 42-INCH CLEARANCE FOR 277/480V POWER AS REQUIRED BY THE NATIONAL ELECTRIC CODE FOR ELECTRICAL EQUIPMENT AND TO PROVIDE MAINTENANCE ACCESS.
- FIELD VERIFY EXACT PIPING SIZES AND FLOW DIRECTIONS PRIOR TO CONNECTING TO PIPING SYSTEM.
- SCHEDULE ALL SERVICE DISRUPTIONS AND SHUTDOWNS WITH THE OWNER NO LESS THAN 1 WEEK IN ADVANCE.
- AIR HANDLING UNIT INTAKES SHALL BE SEPARATED BY MINIMUM 10 FEET FROM EXHAUST FANS, EXHAUST VENTS, FLUES, PLUMBING VENTS, ETC.

**MECHANICAL GENERAL  
DEMOLITION WORK NOTES**

- VERIFY PROJECT SITE EXISTING CONDITIONS PRIOR TO BID. EXISTING CONDITIONS INDICATED IN THESE DOCUMENTS ARE APPROXIMATE AND DO NOT INCLUDE EVERY COMPONENT.
- RECORD EXISTING CONDITIONS PRIOR TO THE START OF WORK. REPAIR DAMAGES RESULTING FROM PROJECT WORK.
- COORDINATE MATERIALS TO BE RETAINED BY THE OWNER PRIOR TO THE START OF DEMOLITION WORK. RETAINED MATERIALS SHALL BE DELIVERED TO A POINT DESIGNATED BY THE OWNER WITHIN A 10-MILE RADIUS OF THE PROJECT SITE. PROPERLY DISPOSE OF ALL REMAINING DEMOLITION MATERIALS. COMPLY WITH MATERIAL RECYCLING REQUIREMENTS. DO NOT ABANDON IN PLACE ANY ITEMS IDENTIFIED TO BE REMOVED UNLESS OTHERWISE NOTED.
- THE SCOPE OF DEMOLITION FOR ITEMS TO BE REMOVED INCLUDES ASSOCIATED SUPPORTS, POWER CONNECTIONS, CONTROLS, ETC.
- PERFORM ALL DEMOLITION INDICATED INCLUDING THAT REQUIRED TO INSTALL NEW WORK. REMOVE AND REINSTALL MATERIALS TO REMAIN AS NEEDED WHERE REQUIRED TO PERFORM DEMOLITION OR TO INSTALL NEW WORK. REPAIR DAMAGED SURFACES TO MATCH EXISTING ADJACENT SURFACES.
- REMOVE DUCT, PIPING AND CONDUIT BACK TO POINTS INDICATED. PREPARE OPEN ENDS FOR CONNECTION TO NEW WORK INDICATED OR CAP.
- REPAIR DAMAGE TO ANY OPENINGS IN LIFE-SAFETY RATED ASSEMBLIES CREATED BY THE DEMOLITION WORK PER APPROVED UL-LISTED DETAIL IN ACCORDANCE WITH THE BUILDING CODE.
- PIPING AND CONDUIT TO BE REMOVED THAT IS LOCATED BELOW CONCRETE SLAB-ON-GRADE FLOORS OR WITHIN CONCRETE SOLID OR BLOCK WALLS MAY BE ABANDONED IN PLACE UNLESS NECESSARY TO INSTALL NEW WORK OR NOTED OTHERWISE. WHEN ABANDONING, CUT PIPING OR CONDUIT BACK AT LEAST 1-INCH BEHIND THE SURFACE. PLUG THE ENDS AND PATCH THE SURFACE WITH SIMILAR MATERIAL.
- CAPTURE AND RECYCLE REFRIGERANT FROM HVAC EQUIPMENT. COMPLY WITH THE EPA REFRIGERANT RECYCLING AND DISPOSAL REQUIREMENTS.
- REMOVE AND REINSTALL LAY-IN CEILING TILES AND GRID AS NEEDED TO PERFORM CONTRACT WORK. STORE CEILING MATERIALS IN A CLEAN DRY PLACE. REPLACE DAMAGED TILES WITH NEW TO MATCH. SELECT ONE ROOM TO INSTALL ALL NEW TILE AND GRID TO PROVIDE THE TILES NEEDED TO REPLACE DAMAGED TILES IN OTHER SPACES.

**MECHANICAL SCHEMATIC SYMBOLS**

GAUGES/SENSORS	
	PRESSURE GAUGE
	TEMPERATURE GAUGE
	TEMPERATURE SENSOR
	HUMIDITY SENSOR
	TEMPERATURE SENSOR (IN AIR FLOW)
	FREEZE SENSOR (IN AIR FLOW)
	DIFFERENTIAL PRESSURE SENSOR
	MAGNEHELIC GAUGE
	CURRENT TRANSDUCER (SENSOR)
	AIR FLOW MONITORING STATION
	FLOW SWITCH
	END SWITCH
	HUMIDITY - HIGH LIMIT SWITCH
	OVERRIDE SWITCH
	NETWORK POINT FOR BAS
	NETWORK BUILDING AUTOMATION SYSTEM CONTROL PANEL
ELECTRONIC CONTROLS	
	DDC CONTROL POINTS
	TRANSFORMER
	RELAY
	STARTER
PNEUMATIC SYMBOLS	
	ELECTRONIC OR ELECTRIC TO PNEUMATIC SWITCH
	ELECTRONIC OR ELECTRIC TO PNEUMATIC TRANSDUCER

**MECHANICAL PIPING SYSTEMS**

SYMBOL	DESCRIPTION
	ATMOSPHERIC VENT
	CONDENSATE DRAIN
	DRAIN
	LOW PRESSURE CONDENSATE
	REFRIGERANT DISCHARGE
	REFRIGERANT
	REFRIGERANT LIQUID LINE
	REFRIGERANT SUCTION LINE
	REFRIGERANT HOT GAS
	STEAM PIPE

**HVAC SYMBOLS**

SYMBOL	DESCRIPTION
GRILLES	
	SUPPLY AIR DEVICE
	RETURN AIR DEVICE
	EXHAUST AIR DEVICE
	AIR DEVICE TAG "TYPE" / "CFM" (SEE SCHEDULE)
	ECCENTRIC TRANSITION
	CONCENTRIC TRANSITION
	RADIUS OFFSET (IN THE VERTICAL)
	MITERED OFFSET (IN THE VERTICAL)
	RADIUS ELBOW
	MITERED ELBOW WITH TURNING VANES
	SUPPLY DUCT
	RETURN AIR DUCT
	EXHAUST AIR DUCT
	FLEX DUCT
	DEMOLITION DUCTWORK OR EQUIPMENT
	EXISTING DUCTWORK OR EQUIPMENT
	NEW DUCTWORK OR EQUIPMENT
	RECTANGULAR TAKE-OFF
	ROUND TAKE-OFF
	ACCESS DOORS

**HVAC SYMBOLS CONTINUED**

SYMBOL	DESCRIPTION
DAMPERS	
	AUTOMATIC/MOTORIZED DAMPER
	MANUAL DAMPER
	GRAVITY BACKDRAFT DAMPER
	MOTORIZED PARALLEL BLADE DAMPER
	MOTORIZED OPPOSED BLADE DAMPER
	FIRE DAMPER
CONTROLS	
	THERMOSTAT
	HUMIDITY SENSOR
	DUCT MOUNTED SMOKE DETECTOR
	NON-FUSIBLE SAFETY SWITCH
	FUSIBLE SAFETY SWITCH
	COMBINATION MOTOR STARTER/SAFETY SWITCH, ENCLOSED CIRCUIT BREAKER
	DISCONNECT SWITCH (FURNISHED BY OTHERS)

**Dewberry**  
Dewberry Engineers Inc.  
2610 Wyoff Road  
Suite 410  
Raleigh, NC 27607-3073  
919.851.9939  
NC License No. F-0929

**CAMPBELL UNIVERSITY**

CAMPBELL UNIVERSITY  
POWELL HALL  
HVAC AND PLUMBING RENOVATION  
84 DAY DORM ROAD  
BUJES CREEK, NC 27506  
CONSTRUCTION DOCUMENTS

SEAL

Signed by:

6/16/2026

KEY PLAN

SCALE

REVISIONS

NO.	DESCRIPTION	DATE

NO. DESCRIPTION DATE

DRAWN BY CDB  
APPROVED BY KRC  
CHECKED BY WH  
DATE 05/20/2026

TITLE

**MECHANICAL SYMBOLS & ABBREVIATIONS**

PROJECT NO. 50193045


**M-001**

SHEET NO.



6/16/2026 10:16:59 AM P:\0703045\CAD\MCHANICAL\0703045 M-001 MECHANICAL SYMBOLS & ABBREVIATIONS.DWG



CAMPBELL UNIVERSITY  
**POWELL HALL**  
HVAC AND PLUMBING RENOVATION  
84 DAY DORM ROAD  
BUJES CREEK, NC 27506  
CONSTRUCTION DOCUMENTS



**1 CRAWLSPACE MECHANICAL DEMOLITION PLAN**  
SCALE: 3/16" = 1'-0"  
0' 2' 4' 8'



REVISIONS

NO.	DESCRIPTION	DATE

**GENERAL NOTES:**

1. STEAM SUPPLY TO POWELL HALL LOCATED OUTSIDE OF BUILDING. COORDINATE WITH CAMPBELL UNIVERSITY FACILITIES TO SHUT OFF STEAM TO BUILDING.
2. DEMOLISH STEAM PIPING IN CRAWLSPACE AS NEEDED TO MAKE ROOM FOR NEW CONSTRUCTION.

**KEYNOTES:**

1. CRAWLSPACE ACCESS DOOR LOCATED HERE.
2. REMOVE ALL DRYER LINT IN THE VICINITY OF THE ELECTRICAL PANEL. REPAIR AND REPLACE DRY VENT HOSE AS REQUIRED. CONNECT ALL LOOSE VENT HOSES BACK TO VENT CAPS ON EXTERIOR WALL OF CRAWL SPACE.
3. STEAM PIPING TO BE ABANDONED IN PLACE. AFTER STEAM SUPPLY TO BUILDING IS SHUT OFF, ALLOW STEAM SYSTEM TO COOL AND DRAIN SYSTEM OF CONDENSATE. DISCONNECT STEAM SUPPLY PIPING FROM PRESSURE REDUCING STATION AND CAP PIPING END.
4. DEMOLISH STEAM PIPING FROM POINT INDICATED.

DRAWN BY: CDB  
APPROVED BY: KRC  
CHECKED BY: WH  
DATE: 05/20/2026

**CRAWLSPACE MECHANICAL DEMOLITION PLAN**

PROJECT NO. 50193045


**MD101**

SHEET NO.




6/16/2026 10:16:51 AM  
P:\0783045\CAD\MCHANICAL\0783045 MD101 CRAWLSPACE MECHANICAL DEMOLITION PLAN.DWG



CAMPBELL UNIVERSITY  
**POWELL HALL**  
HVAC AND PLUMBING RENOVATION  
84 DAY DORM ROAD  
BUJES CREEK, NC 27506  
CONSTRUCTION DOCUMENTS



**1 FIRST FLOOR MECHANICAL DEMOLITION PLAN AREA A**  
SCALE: 3/16" = 1'-0"



REVISIONS		
NO.	DESCRIPTION	DATE
1	DOAS RELOCATION	6/11/26

**GENERAL NOTES:**

- ACT CEILING AND SOFFIT TO BE DEMOLISHED BY CAMPBELL UNIVERSITY FACILITIES. REMOVE AND STORE CEILING TILES TO PERFORM WORK. COORDINATE CEILING SCOPE WITH CAMPBELL UNIVERSITY.

**KEYNOTES:**

- PRIOR TO DEMOLITION OF SPLIT SYSTEMS, CONTRACTOR SHALL RECOVER AND DISPOSE OF ALL REFRIGERANT IN ACCORDANCE WITH APPLICABLE FEDERAL, STATE, AND LOCAL LAWS.
- DEMOLISH AIR CONDITIONING UNIT IN ITS ENTIRETY. DISCONNECT DUCT WORK, PIPING AND LINESET. DEMOLISH POWER AND CONTROL EQUIPMENT AND WIRING, INCLUDING BUT NOT LIMITED TO SPACE THERMOSTATS.
- DEMOLISH CONDENSING UNIT IN ITS ENTIRETY. DISCONNECT LINESET. DEMOLISH POWER AND CONTROL EQUIPMENT AND WIRING. DEMOLISH CONCRETE PAD.
- DEMOLISH REFRIGERANT LINESET FROM THE INTERIOR UNIT TO THE EXTERIOR UNIT. PATCH AND PAINT WALL PENETRATIONS WITH LIKE MATERIALS.
- DEMOLISH CONDENSATE PIPING FROM POINT INDICATED TO LOCATION OF DISCHARGE TO GRADE. PATCH AND PAINT WALL PENETRATIONS WITH LIKE MATERIALS. REFER TO DETAIL.
- DEMOLISH DUCT WORK IN ITS ENTIRETY.

- DEMOLISH STEAM RADIATOR. DEMOLISH STEAM PIPE LEVEL WITH FLOOR SURFACE. PROVIDE FLOOR PLATE TO COVER PIPE. MOUNT FLUSH WITH FLOOR. COORDINATE WITH GENERAL CONTRACTOR TO COVER NEWLY EXPOSED FLOOR AND WALL AREA.
- REMOVE WINDOW UNIT AND RELINQUISH TO CAMPBELL UNIVERSITY FACILITIES.
- PATCH MECHANICAL ROOM MASONRY WALL WITH LIKE MATERIALS. PROVIDE SLEEVES FOR WIRING, PIPING, AND OTHER UTILITIES AS NEEDED TO CREATE SMOKE TIGHT WALL.
- DEMOLISH TOILET ROOM EXHAUST GRILLE AND CAP DUCT. PATCH AND PAINT WALL TO MATCH ADJACENT FINISH.

DRAWN BY: CDB  
APPROVED BY: KRC  
CHECKED BY: WH  
DATE: 05/20/2026

**FIRST FLOOR MECHANICAL DEMOLITION PLAN AREA A**

PROJECT NO. 50193045


**MD111**

SHEET NO.

6/11/2026 10:16:05 AM P:\0729CB4A-4DF9-85AE-82E3-9BA783A8950B\MD111 FIRST FLOOR MECHANICAL DEMOLITION PLAN AREA A.DWG




CAMPBELL UNIVERSITY  
**POWELL HALL**  
HVAC AND PLUMBING RENOVATION  
84 DAY DORM ROAD  
BUJES CREEK, NC 27506  
CONSTRUCTION DOCUMENTS



**1 SECOND FLOOR MECHANICAL DEMOLITION WORK PLAN**  
SCALE: 3/16" = 1'-0"

SEAL  
Signed by  
*Katherine E. Rohrer*  
KATHERINE E. ROHRER  
REGISTERED PROFESSIONAL ENGINEER  
STATE OF NORTH CAROLINA  
SEAL  
057983  
6/16/2026



REVISIONS

NO.	DESCRIPTION	DATE

**GENERAL NOTES:**

- ACT CEILING AND SOFFIT TO BE DEMOLISHED BY CAMPBELL UNIVERSITY FACILITIES. REMOVE AND STORE CEILING TILES TO PERFORM WORK. COORDINATE CEILING SCOPE WITH CAMPBELL UNIVERSITY.

**KEYNOTES:**

- PRIOR TO DEMOLITION OF SPLIT SYSTEMS, CONTRACTOR SHALL RECOVER AND DISPOSE OF ALL REFRIGERANT IN ACCORDANCE WITH APPLICABLE FEDERAL, STATE, AND LOCAL LAWS.
- DEMOLISH AIR CONDITIONING UNIT IN ITS ENTIRETY. DISCONNECT DUCT WORK, PIPING AND LINESET. DEMOLISH POWER AND CONTROL EQUIPMENT AND WIRING, INCLUDING BUT NOT LIMITED TO SPACE THERMOSTATS.
- DEMOLISH REFRIGERANT LINESET FROM THE INTERIOR UNIT TO THE EXTERIOR UNIT. PATCH AND PAINT WALL PENETRATIONS WITH LIKE MATERIALS. REFER TO DETAIL.
- DEMOLISH CONDENSATE PIPING FROM POINT INDICATED TO LOCATION OF DISCHARGE TO GRADE. PATCH AND PAINT WALL PENETRATIONS WITH LIKE MATERIALS.
- DEMOLISH DUCTWORK IN ITS ENTIRETY.
- DEMOLISH STEAM RADIATOR. DEMOLISH STEAM PIPE LEVEL WITH FLOOR SURFACE. PROVIDE FLOOR PLATE TO COVER PIPE. MOUNT FLUSH WITH FLOOR. COORDINATE WITH GENERAL CONTRACTOR TO COVER NEWLY EXPOSED FLOOR AND WALL AREA.
- PATCH MECHANICAL ROOM MASONRY WALL WITH LIKE MATERIALS. PROVIDE SLEEVES FOR WIRING, PIPING, AND OTHER UTILITIES AS NEEDED TO CREATE SMOKE TIGHT WALL.
- DEMOLISH TOILET ROOM EXHAUST GRILLE AND CAP DUCT. PATCH AND PAINT WALL TO MATCH ADJACENT FINISH.
- DEMOLISH PLYWOOD ENCLOSURE AROUND AC. PATCH AND PAINT WALL TO MATCH ADJACENT FINISH.

DRAWN BY: CDB  
APPROVED BY: KRC  
CHECKED BY: WH  
DATE: 05/20/2026

TITLE  
**SECOND FLOOR MECHANICAL DEMOLITION PLAN**

PROJECT NO. 50193045


**MD121**

SHEET NO.



6/16/2026 10:57:42 AM P:\0783085\CAD\MCHANICAL\0783045 MD121 SECOND FLOOR MECHANICAL DEMOLITION PLAN.DWG



CAMPBELL UNIVERSITY  
**POWELL HALL**  
HVAC AND PLUMBING RENOVATION  
84 DAY DORM ROAD  
BUJES CREEK, NC 27506  
CONSTRUCTION DOCUMENTS



**1 THIRD FLOOR MECHANICAL DEMOLITION PLAN**  
SCALE: 3/16" = 1'-0"



REVISIONS

NO.	DESCRIPTION	DATE

**GENERAL NOTES:**

- ACT CEILING AND SOFFIT TO BE DEMOLISHED BY CAMPBELL UNIVERSITY FACILITIES. REMOVE AND STORE CEILING TILES TO PERFORM WORK COORDINATE CEILING SCOPE WITH CAMPBELL UNIVERSITY.

**KEYNOTES:**

- PRIOR TO DEMOLITION OF SPLIT SYSTEMS, CONTRACTOR SHALL RECOVER AND DISPOSE OF ALL REFRIGERANT IN ACCORDANCE WITH APPLICABLE FEDERAL, STATE, AND LOCAL LAWS.
- DEMOLISH AIR CONDITIONING UNIT IN ITS ENTIRETY. DISCONNECT DUCT WORK, PIPING AND LINESET. DEMOLISH POWER AND CONTROL EQUIPMENT AND WIRING, INCLUDING BUT NOT LIMITED TO SPACE THERMOSTATS.
- DEMOLISH REFRIGERANT LINESET FROM THE INTERIOR UNIT TO THE EXTERIOR UNIT. PATCH AND PAINT WALL PENETRATIONS WITH LIKE MATERIALS. REFER TO DETAIL.
- DEMOLISH CONDENSATE PIPING FROM POINT INDICATED TO LOCATION OF DISCHARGE TO GRADE. PATCH AND PAINT WALL PENETRATIONS WITH LIKE MATERIALS.
- DEMOLISH DUCT WORK IN ITS ENTIRETY.
- DEMOLISH STEAM RADIATOR. DEMOLISH STEAM PIPE LEVEL WITH FLOOR SURFACE. PROVIDE FLOOR PLATE TO COVER PIPE. MOUNT FLUSH WITH FLOOR. COORDINATE WITH GENERAL CONTRACTOR TO COVER NEWLY EXPOSED FLOOR AND WALL.

- PATCH MECHANICAL ROOM MASONRY WALL WITH LIKE MATERIALS. PROVIDE SLEEVES FOR WIRING, PIPING, AND OTHER UTILITIES AS NEEDED TO CREATE SMOKE TIGHT WALL.
- DEMOLISH TOILET ROOM EXHAUST GRILLE AND CAP DUCT. PATCH AND PAINT WALL TO MATCH ADJACENT FINISH.
- DEMOLISH ROOF MOUNTED EXHAUST FAN. DEMO POWER AND CONTROL WIRE AND DISCONNECT. ROOF CURB TO REMAIN FOR REUSE.
- DEMOLISH PLYWOOD ENCLOSURE AROUND AC. PATCH AND PAINT WALL TO MATCH ADJACENT FINISH.

DRAWN BY: CDB  
APPROVED BY: KRC  
CHECKED BY: WH  
DATE: 05/20/2026

TITLE  
**THIRD FLOOR MECHANICAL DEMOLITION PLAN**

PROJECT NO. 50193045

**MD131**  
SHEET NO.


6/14/2026 10:52:26 AM P:\0783045\CAD\MCHANICAL\0783045 MD131 THIRD FLOOR MECHANICAL DEMOLITION PLAN.DWG





Dewberry Engineers Inc.  
 2610 Wycliff Road  
 Suite 410  
 Raleigh, NC 27607-3073  
 919.881.9939  
 NC License No. F-0929



CAMPBELL UNIVERSITY  
**POWELL HALL**  
 HVAC AND PLUMBING RENOVATION  
 84 DAY DORM ROAD  
 BUJES CREEK, NC 27506  
 CONSTRUCTION DOCUMENTS



**1 CRAWLSPACE MECHANICAL NEW WORK PLAN**  
 SCALE: 3/16" = 1'-0" 0' 2' 4' 8'



REVISIONS		
NO.	DESCRIPTION	DATE
1	DOAS RELOCATION	6/11/26

**GENERAL NOTES:**

- DEMOLISH STEAM AND CONDENSATE PIPING IN CRAWLSPACE AS NEEDED TO MAKE ROOM FOR NEW CONSTRUCTION.

**KEYNOTES:**

- UP TO FCU-1.
- UP TO FCU-2 AND FCU-3.
- PROVIDE REFRIGERANT LINESET FROM CONDENSING UNITS TO INDOOR UNITS. SEE FIRST FLOOR FOR CONTINUATION.
- DISCHARGE CONDENSATE 6" ABOVE GRADE USING EXISTING CRAWLSPACE PENETRATIONS FROM DEMOLISHED UNITS. PROVIDE SPLASH BLOCK.

DRAWN BY: CDB  
 APPROVED BY: KRC  
 CHECKED BY: WH  
 DATE: 05/20/2026

**TITLE**  
**CRAWLSPACE MECHANICAL NEW WORK PLAN**


PROJECT NO. 50193045

**M-101**  
 SHEET NO.

6/11/2026 10:57:24 AM P:\0193045\CAD\MCHANICAL\0193045 M-101 CRAWLSPACE MECHANICAL NEW WORK PLAN.DWG




CAMPBELL UNIVERSITY  
**POWELL HALL**  
HVAC AND PLUMBING RENOVATION  
84 DAY DORM ROAD  
BUJES CREEK, NC 27506  
CONSTRUCTION DOCUMENTS



**1 FIRST FLOOR MECHANICAL NEW WORK PLAN AREA A**  
SCALE: 3/16" = 1'-0"

SEAL  
Signed by  
Katherine  
SWANSON  
PROFESSIONAL ENGINEER  
STATE OF NORTH CAROLINA  
SEAL  
057983  
ENGINEER  
J. E. ROBEY, COMPANY  
6/16/2026



REVISIONS

NO.	DESCRIPTION	DATE
1	DOAS RELOCATION	6/11/26

DRAWN BY: CDB  
APPROVED BY: KRC  
CHECKED BY: WH  
DATE: 05/20/2026

**FIRST FLOOR MECHANICAL NEW WORK PLAN AREA A**

PROJECT NO. 50193045

**M-111**

SHEET NO.

**GENERAL NOTES:**

- COORDINATE WITH GENERAL CONTRACTOR FOR PENETRATIONS, DUCT SHAFTS/SOFFITS, AND CEILINGS.

**KEYNOTES:**

- PROVIDE DOAS. PROVIDE POWER AND CONTROL WIRING AND DISCONNECTING MEANS. LOCATE DOAS TO MEET ALL EQUIPMENT CLEARANCES. PROVIDE 6" DEEP CONCRETE PAD WITH CRUSHED GRAVEL BASE. PAD SHALL BE 6" LONGER AND WIDER THAN UNIT FOOT PRINT. PROVIDE OA DUCT, ROUTE TO CRAWLSPACE AS SHOWN. PROVIDE BRICK LINTEL. SEE DETAILS FOR MORE INFORMATION.
- PROVIDE FAN COIL UNIT. PROVIDE DUCTWORK COMPLETE WITH INSULATION, SUPPORTS, AND ACCESSORIES AND ROUTE AS SHOWN.
- PROVIDE CONDENSING UNIT. MOUNT TO EXISTING CONCRETE PAD. PROVIDE POWER AND CONTROL WIRE AND DISCONNECTING MEANS.
- EXTERIOR WALL PENETRATION. COORDINATE WITH GENERAL CONTRACTOR FOR PENETRATION.
- PROVIDE PTAC WITH WALL SLEEVE AND SUBBASE. INSTALL PER MANUFACTURERS INSTRUCTIONS. COORDINATE WITH GENERAL CONTRACTOR FOR WALL PENETRATION LINTEL.
- PROVIDE EXHAUST FAN. ROUTE DUCT TO EXISTING DUCT

- RISER LOCATED IN PLUMBING CHASE.
- PROVIDE UNIT HEATER WITH INTEGRAL THERMOSTAT. SURFACE MOUNT ON CONCRETE BLOCK WALL PER MANUFACTURERS INSTRUCTIONS.
- PROVIDE DUCT DETECTOR AND HARDWIRE TO DOAS DOR SMOKE SHUTDOWN. PROVIDE 12X12 HINGED DOOR ACCESS.
- PROVIDE THERMOSTAT AT 48" AFF. PROVIDE WIRE-MOLD FOR CONTROL WIRING EXPOSED BENEATH THE CEILING.
- OA DUCT DOWN INTO MECHANICAL ROOM. ROUTE TO EXISTING FLOOR PENETRATION FROM DEMOLISHED TRASH SHOOT. RESIZE FLOOR PENETRATION AS NEEDED. PROVIDE SLEEVE AT FLOOR PENETRATION. ROUTE DUCT INTO BUILDING THROUGH EXISTING WALL OPENING. INFILL AND INSULATE WALL AROUND DUCT AND PROVIDE A WALL SLEEVE.
- PROVIDE OPENING ABOVE TOILET DOOR BY REMOVING THE WOOD PANEL TRANSOM. OR PROVIDE 8X8 TRANSFER

- GRILLE CENTERED OVER TOILET ROOM FLOOR, 7'-6" AFF.
- PROVIDE FAN SWITCH ADJACENT TO LIGHT SWITCH. MOUNT AT 48" AFF.
- ROUTE CONDENSATE TO CONDENSATE RISER FROM FCU-2,3. PROVIDE WYE INTO RISER. ROUTE CONDENSATE DOWN TO CRAWLSPACE. PROVIDE ESCUTCHEON TO COVER FLOOR PENETRATION.
- PROVIDE SUPPLY GRILLE AT 60" AFF TO BOTTOM OF GRILLE. PROVIDE 6X6 ACCESS DOOR BELOW SUPPLY GRILLE FOR ACCESS TO VOLUME DAMPER. AFTER ALL BRANCHES, TRANSITION TO 18X12. SEE SHEET M-121 FOR CONTINUATION. COORDINATE WITH GENERAL CONTRACTOR TO PROVIDE DUCT CHASE AND ACCESS DOOR IN CHASE.
- UP TO FCU-2,3. ROUTE ABOVE CEILING.
- PROVIDE EXTERIOR OA DUCT WITH ALUMINUM JACKETING.
- PROVIDE NETWORK CONTROL PANEL. PROVIDE 120V


- POWER AND DATA WIRING.
- GAS METER. REFER TO PLUMBING PLANS FOR MORE INFORMATION.
- PROVIDE EXHAUST FAN. PROVIDE POWER AND CONTROL WIRE. PROVIDE EXHAUST DUCT, ROUTE TO EXTERIOR WALL AND PROVIDE WALL VENT WITH BIRD SCREEN AND BACKDRAFT DAMPER.
- DUCT ROUTED UP BETWEEN JOISTS.

6/16/2026 10:17:52 AM P:\0783036\CAD\MCHANICAL\0783045 M-111 FIRST FLOOR MECHANICAL NEW WORK PLAN AREA A.DWG





F  
E  
D  
C  
B  
A

6/14/2026 10:17:17 AM P:\070306\CAD\MCHANICAL\0193045 M-121 SECOND FLOOR MECHANICAL NEW WORK PLAN.DWG



**1 SECOND FLOOR MECHANICAL NEW WORK PLAN**  
SCALE: 3/16" = 1'-0"



REVISIONS

NO.	DESCRIPTION	DATE
1	DOAS RELOCATION	06/11/26

**GENERAL NOTES:**

**KEYNOTES:**

1. PROVIDE FAN COIL UNIT. PROVIDE DUCT WORK FROM FAN COIL UNIT TO SPACES SERVED. PROVIDE FLEXIBLE DUCT CONNECTIONS AND TRANSITIONS AS NECESSARY.
2. PROVIDE REFRIGERANT PIPING LINESET BETWEEN CORRESPONDING INDOOR AND OUTDOOR UNITS. PROVIDE WITH 1-1/2" ELASTOMERIC CLOSED CELL INSULATION. INSTALL PER MANUFACTURERS INSTALLATION INSTRUCTION.
3. PROVIDE PTAC. INSTALL PER MANUFACTURERS INSTRUCTIONS. REFER TO DETAIL FOR ADDITIONAL INFORMATION.
4. PROVIDE EXHAUST FAN. ROUTE DUCT TO EXISTING DUCT RISER. LOCATED IN PLUMBING CHASE.
5. PROVIDE THERMOSTAT AT 48" AFF. PROVIDE WIRE-MOLD FOR CABLE EXPOSED BENEATH THE CEILING.
6. DOWN TO 1ST FLOOR & UP TO 3RD FLOOR.
7. ROUTE SHALL WYE INTO CONDENSATE FROM FCU-3. ROUTE DOWN TO CRAWLSPACE USING EXISTING CONDENSATE ROUTE. PROVIDE ESCUTCHEON TO COVER

8. FLOOR PENETRATION.
9. PROVIDE 8x8 TRANSFER GRILLE CENTERED OVER TOILET ROOM DOOR, 7'-6" AFF.
10. RA DUCT 14X12 FROM UNIT, TRANSITION TO 16X10.
11. AFTER ALL BRANCHES, TRANSITION TO 12X12. SEE SHEET M-131 FOR CONTINUATION.
12. PROVIDE FIRE DAMPER WITH ACCESS DOOR AT FLOOR PENETRATION FOR DUCT RISER. COORDINATE WITH GENERAL CONTRACTOR TO PROVIDE DUCT CHASE AND ACCESS DOOR IN CHASE.
13. DUCT ROUTED UP BETWEEN JOISTS.
14. PROVIDE UNIT HEATER WITH INTEGRAL THERMOSTAT. SURFACE MOUNT ON CONCRETE BLOCK WALL PER MANUFACTURER'S INSTRUCTIONS.


DRAWN BY: CDB  
APPROVED BY: KRC  
CHECKED BY: WH  
DATE: 05/20/2026

**TITLE**  
**SECOND FLOOR MECHANICAL NEW WORK PLAN**



PROJECT NO. 50193045

**M-121**

SHEET NO.



**1 THIRD FLOOR MECHANICAL NEW WORK PLAN**  
SCALE: 3/16" = 1'-0"



REVISIONS

NO.	DESCRIPTION	DATE
1	DOAS RELOCATION	6/11/26

**GENERAL NOTES:**

**KEYNOTES:**

1. PROVIDE FAN COIL UNIT. PROVIDE DUCT WORK FROM FAN COIL UNIT TO SPACES SERVED. PROVIDE FLEXIBLE DUCT CONNECTIONS AND TRANSITIONS AS NECESSARY.
2. PROVIDE REFRIGERANT PIPING LINES BETWEEN CORRESPONDING INDOOR AND OUTDOOR UNITS. PROVIDE WITH 1-1/2" ELASTOMERIC CLOSED CELL INSULATION. INSTALL PER MANUFACTURERS INSTALLATION INSTRUCTION.
3. PROVIDE PTAC. INSTALL PER MANUFACTURERS INSTRUCTIONS. REFER TO DETAIL FOR ADDITIONAL INFORMATION.
4. PROVIDE EXHAUST FAN. ROUTE DUCT TO EXISTING DUCT RISER LOCATED IN PLUMBING CHASE.
5. PROVIDE THERMOSTAT AT 48" AFF. PROVIDE WIRE-MOLD FOR CABLE EXPOSED BENEATH THE CEILING.
6. DOWN TO 2ND FLOOR.
7. ROUTE CONDENSATE DOWN EXISTING FLOOR PENETRATION. PROVIDE ESCUTCHEON TO COVER FLOOR PENETRATION.

8. PROVIDE GRAVITY VENT ON ROOF. CONNECT TO EXISTING EXHAUST-DUCT RISER. MOUNT ON EXISTING ROOF CURB.
9. PROVIDE 8x8 TRANSFER GRILLE CENTERED OVER TOILET ROOM DOOR, 7'-6" AFF.
10. RA DUCT 14X12 FROM UNIT. TRANSITION TO 16X10.
11. PROVIDE FIRE DAMPER WITH ACCESS DOOR AT FLOOR PENETRATION FOR DUCT RISER. COORDINATE WITH GENERAL CONTRACTOR TO PROVIDE DUCT CHASE AND ACCESS DOOR IN CHASE.
12. DUCT ROUTED UP BETWEEN JOISTS.
13. PROVIDE UNIT HEATER WITH INTEGRAL THERMOSTAT. SURFACE MOUNT ON CONCRETE BLOCK WALL PER MANUFACTURER'S INSTRUCTIONS.

DRAWN BY: CDB  
APPROVED BY: KRC  
CHECKED BY: WH  
DATE: 05/20/2026

**TITLE**  
**THIRD FLOOR MECHANICAL NEW WORK PLAN**


PROJECT NO. 50193045

**M-131**



SHEET NO.

6/11/2026 10:57:25 AM  
P:\070306\CAD\MCHANICAL\070306 M-501 DETAILS.DWG

F  
E  
D  
C  
B  
A



1 FCU TYPICAL SECTION VIEW SCALE: NTS 237313




3 DUCT TRANSITION SCALE: NTS 233113-009

**GENERAL NOTES:**


- IT IS THE RESPONSIBILITY OF THE GENERAL CONTRACTOR TO COORDINATE BETWEEN THE ELECTRICAL AND OTHER TRADES.
- ELECTRICAL CONTRACTOR PROVIDES DISCONNECT SWITCH IF NEEDED FOR OWNER FURNISHED EQUIPMENT.

**KEYNOTES:**


- EQUIPMENT BY MECHANICAL CONTRACTOR.
- CONDUIT & WIRING BY ELECTRICAL CONTRACTOR.
- IF AN ADDITIONAL DISCONNECT IS REQUIRED BY NEC IT SHALL BE PROVIDED AND INSTALLED BY ELECTRICAL CONTRACTOR.
- A COMBINATION STARTER MAY BE USED IN LIEU OF A SEPARATE DISCONNECT SWITCH AND STARTER. DISCONNECT SWITCH AND STARTER PROVIDED BY ELECTRICAL CONTRACTOR. LOCATE DISCONNECT SWITCH ADJACENT TO STARTER.
- FEEDEE CIRCUIT WIRING AND CONDUIT IN ELECTRICAL WORK. SEE PANELBOARD SCHEDULE FOR BREAKER SIZES AND BRANCH OR FEEDER SCHEDULES FOR WIRE/CONDUIT SIZES.
- EQUIPMENT PROVIDED WITH INTEGRAL DISCONNECTING MEANS BY MECHANICAL CONTRACTOR.
- MECHANICAL CONTRACTOR SUPPLYING THE EQUIPMENT SHALL MAKE FINAL CONNECTIONS, START UP, AND TEST EQUIPMENT.




4 MECHANICAL TO ELECTRICAL EQUIPMENT SCALE: NTS ME002-02




5 PTAC FRONTAL AND SIDE VIEW TYPICAL INSTALLATION SCALE: NTS



6 REFRIGERANT LINE - WALL PENETRATION SCALE: NTS 232300-002



7 GRILLE AND DIFFUSER ASSEMBLY SCALE: NTS 233713-001



8 DUCT SLEEVE WITH COLLAR SCALE: NTS M587-11

**Dewberry**  
Dewberry Engineers Inc.  
2610 Wyckoff Road  
Suite 410  
Raleigh, NC 27607-3073  
919.851.9939  
NC License No. F-0929

**CAMPBELL UNIVERSITY**

CAMPBELL UNIVERSITY  
**POWELL HALL**  
HVAC AND PLUMBING RENOVATION  
84 DAY DORM ROAD  
BUJES CREEK, NC 27506  
CONSTRUCTION DOCUMENTS

SEAL

Professional Engineer Seal for Robert J. Campbell, State of North Carolina, License No. 057983, dated 6/16/2026.

KEY PLAN

SCALE

REVISIONS

NO.	DESCRIPTION	DATE
1	DOAS RELOCATION	6/11/26


DRAWN BY: CDB  
APPROVED BY: KRC  
CHECKED BY: WH  
DATE: 05/20/2026  
TITLE: DETAILS

PROJECT NO. 50193045


**M-501**

SHEET NO.


6/16/2026 10:57:01 AM  
 P:\0183045\CAD\MCHANICAL\0183045 M-502 DETAILS.DWG



- NOTES:**
1. PROVIDE 45° LATERAL WYE TAKE-OFFS.
  2. WHEN SPACE DOES NOT ALLOW 45° LATERAL WYE TAKE-OFF, USE 90° CONICAL TEE CONNECTIONS.
  3. STRAIGHT IN FACTORY BUILT CONNECTIONS ARE PERMITTED FOR:
  - A. SINGLE DIFFUSER, GRILLE OR REGISTER RUNOUTS FOR EXHAUST OR RETURN AIR APPLICATIONS.
  - B. SINGLE DIFFUSER, GRILLE OR REGISTER RUNOUTS ON THE LOW PRESSURE SIDE OF TERMINAL BOXES.
  4. STANDOFF REQUIRED FOR DAMPER HANDLE ON ALL INSULATED DUCT.



- NOTES:**
1. SINGLE VANES ALLOWED IN ELBOWS LESS THAN OR EQUAL TO 18\" X 18\".
  2. TURNING VANES NOT REQUIRED IN ELBOWS SMALLER THAN 12\" X 12\".



**DESIGNER NOTE:**  
CHECK YOUR HEIGHT CLEARANCE.

EQUIPMENT CAPACITY	MIN. PIPE DIAMETER
UP TO 20 TONS OF REFRIGERATION	0'-0 3/4"
OVER 20 TONS TO 40 TONS OF REFRIGERATION	0'-1"
OVER 40 TONS TO 90 TONS OF REFRIGERATION	0'-1 1/4"
OVER 90 TONS TO 125 TONS OF REFRIGERATION	0'-1 1/2"
OVER 125 TONS TO 250 TONS OF REFRIGERATION	0'-2"

- NOTES:**
1. ALL CONDENSATE PIPING SHALL BE TYPE L HARD COPPER. SIZED TO MATCH AHU OUTLET. RUN FULL SIZE TO DRAIN.
  2. INSULATE DRAIN PIPING WITH CLOSED CELL INSULATION. SEE SPECIFICATIONS.

**1 DUCT 45° LATERAL TAKE-OFF** SCALE: NTS 233113-005


**2 DUCT MITERED 90° ELBOW** SCALE: NTS 233113-007

**3 AHU DRAIN TRAP - DRAW THROUGH** SCALE: NTS 237300-001




- LINTEL NOTES:**
1. MINIMUM MASONRY END BEARING FOR ANGLES SHALL BE 8\". CUT BRICK AT BEARINGS AS REQUIRED TO INSTALL LINTELS.
  2. SEE MECHANICAL DRAWINGS FOR SIZE AND HEIGHT OF NEW WALL OPENING.
  3. CONTRACTOR SHALL ADEQUATELY AND SAFELY SHORE EXISTING BRICK ABOVE NEW WALL OPENING DURING DEMOLITION OF EXISTING WALL AND UNTIL NEW STEEL ANGLE LINTELS ARE FULLY INSTALLED.
  4. USE FOR CLEAR SPANS LESS THAN 4'-0\".
  5. ANGLES SHALL BE GALVANIZED AT EXTERIOR WALL LOCATIONS.


**4 BRICK LINTELS** SCALE: NTS 237300-001



**5 BRICK LINTELS** SCALE: NTS 237300-001



CAMPBELL UNIVERSITY  
 POWELL HALL  
 HVAC AND PLUMBING RENOVATION  
 84 DAY DORM ROAD  
 BUJES CREEK, NC 27506  
 CONSTRUCTION DOCUMENTS



6/16/2026  
KEY PLAN

SCALE

**REVISIONS**

NO.	DESCRIPTION	DATE

DRAWN BY: CDB  
 APPROVED BY: KRC  
 CHECKED BY: WH  
 DATE: 05/20/2026  
 TITLE:

**DETAILS**  
 PROJECT NO. 50193045  
**M-502**  
 SHEET NO.

**DEDICATED OUTDOOR AIR UNIT SCHEDULE**

Table with columns for MARK, MANUFACTURER / MODEL, TYPE, DRIVE TYPE, CAPACITY, CONNECT, SINGLE FAN, DEHUMIDIFICATION, COOLING CAPACITY, TOTAL SENSIBLE CAPACITY, HEATING CAPACITY, REHEAT CAPACITY, ELECTRICAL, MAX SOUND LEVEL, DIMENSIONS AND WEIGHT, and NOTES.

NOTES:

- 1. REFER TO SECTION 237433 FOR ADDITIONAL REQUIREMENTS. REFER TO UNIT DETAILS AND DIAGRAMS FOR COMPLETE CONFIGURATION AND DIMENSIONAL DETAILS.
- 2. MAX. COOLING COIL FACE VELOCITY = 500 FPM.
- 3. PROVIDE SINGLE-POINT ELECTRICAL CONNECTION AND FUSED-DISCONNECT.
- 4. PROVIDE SCR CONTROLLER FOR ELECTRIC HEATING COILS.
- 5. PROVIDE LOW AMBIENT COOLING OPERATION DOWN TO -20 DEG F. OUTFIT WITH HIGH OUTPUT CONDENSING FANS AND LOW AMBIENT REFRIGERANT CIRCUIT.
- 6. PROVIDE HAIL GUARD FOR CONDENSING COIL.
- 7. PROVIDE CONCRETE PAD THAT IS 6-INCHES LONGER AND WIDER THAN UNIT FOOTPRINT AND 6-INCHES DEEP WITH 4-INCHES DEEP CRUSHED STONE BASE.
- 8. PROVIDE MODULATING INVERTER COMPRESSOR CIRCUIT FOR MAINTAINING DEWPOINT CONTROL OF 50°F WITH HOT GAS REHEAT TO MAINTAIN 65°F.

**FAN COIL UNIT SCHEDULE**

Table with columns for MARK, TYPE, MANUFACTURER / MODEL, SUPPLY AIR FAN, COOLING COIL, REHEAT COIL, FILTRATION, DIMENSIONS AND WEIGHT, and NOTES.

NOTES:

- 1. REFER TO SECTION 238219 FOR ADDITIONAL REQUIREMENTS.
- 2. MAX. COOLING COIL FACE VELOCITY = 500 FPM.
- 3. PROVIDE MOTOR-RATED DISCONNECT SWITCH.
- 4. PROVIDE COMBINATION MOTOR-STARTER AND DISCONNECT SWITCH.
- 5. PROVIDE WIRE THERMOSTAT. REMOTE THERMOSTAT NOT ACCEPTABLE.
- 6. REFER TO CONDENSING UNIT SCHEDULE FOR ASSOCIATED DX COIL CONDENSING UNIT.

**CONDENSING UNIT SCHEDULE**

Table with columns for MARK, SERVICE, TYPE, MANUFACTURER / MODEL, COOLING, HEAT PUMP, NUMBER OF COMP., MAX SOUND, ELECTRICAL, DIMENSIONS AND WEIGHT, and NOTES.

NOTES:

- 1. REFER TO SECTION 238223 FOR ADDITIONAL REQUIREMENTS.
- 2. SOUND PERFORMANCE IS BASED ON SOUND PRESSURE LEVELS MEASURED AT 3 FEET FROM UNIT AT FULL CAPACITY IN ACCORDANCE WITH AHRI 270.
- 3. ALL UNITS SHALL MEET OR EXCEED SEASONAL ENERGY EFFICIENCY RATIO (SEER) FOR NOMINAL COOLING SIZES LESS THAN 65,000 BTUH.
- 4. HEAT PUMPS SHALL MEET OR EXCEED HEATING SEASONAL PERFORMANCE FACTOR (HSPF) FOR NOMINAL COOLING SIZES LESS THAN 65,000 BTUH.
- 5. SIZE REFRIGERANT PIPING PER MANUFACTURER'S RECOMMENDATIONS.
- 6. PROVIDE FUSED-DISCONNECT SWITCH.
- 7. PROVIDE LOW AMBIENT TEMPERATURE OPTION.

**FIRST FLOOR PACKAGE TERMINAL HEAT PUMP SCHEDULE**

Table with columns for MARK, MANUFACTURER / MODEL, REFRIG. TYPE, SUPPLY AIR FAN, COOLING COIL, HEATING COIL, HEATING COIL, DIMENSIONS AND WEIGHT, and NOTES.

NOTES:

- 1. PROVIDE UNIT BY ONE OF THE FOLLOWING MANUFACTURERS: FRIEDRICH OR AMANA.
- 2. PROVIDE MANUFACTURER UNIT SUBBASE WITH INTEGRAL MOTOR-RATED DISCONNECT SWITCH.
- 3. PROVIDE WITH MANUFACTURER WALL SLEEVE. COORDINATE WALL SLEEVE WITH WALL THICKNESS EAST EACH LOCATION. WALL THICKNESS VARIES.
- 4. PROVIDE WALL-MOUNTED, WIRED, NON-PROGRAMMABLE THERMOSTAT. WIRELESS THERMOSTATS ARE NOT ACCEPTABLE.
- 5. PROVIDE ARCHITECTURAL EXTERIOR GRILLE. COORDINATE COLOR WITH OWNER.
- 6. PROVIDE 2 EXTRA FRONT-END AIR FILTERS FOR EACH UNIT. DELIVER TO OWNER PRIOR TO PROJECT CLOSEOUT.

**SECOND FLOOR PACKAGE TERMINAL HEAT PUMP SCHEDULE**

Table with columns for MARK, MANUFACTURER / MODEL, REFRIG. TYPE, SUPPLY AIR FAN, COOLING COIL, HEATING COIL, HEATING COIL, DIMENSIONS AND WEIGHT, and NOTES.

NOTES:

- 1. PROVIDE UNIT BY ONE OF THE FOLLOWING MANUFACTURERS: FRIEDRICH OR AMANA.
- 2. PROVIDE MANUFACTURER UNIT SUBBASE WITH INTEGRAL MOTOR-RATED DISCONNECT SWITCH.
- 3. PROVIDE WITH MANUFACTURER WALL SLEEVE. COORDINATE WALL SLEEVE WITH WALL THICKNESS EAST EACH LOCATION. WALL THICKNESS VARIES.
- 4. PROVIDE WALL-MOUNTED, WIRED, NON-PROGRAMMABLE THERMOSTAT. WIRELESS THERMOSTATS ARE NOT ACCEPTABLE.
- 5. PROVIDE ARCHITECTURAL EXTERIOR GRILLE. COORDINATE COLOR WITH OWNER.
- 6. PROVIDE 2 EXTRA FRONT-END AIR FILTERS FOR EACH UNIT. DELIVER TO OWNER PRIOR TO PROJECT CLOSEOUT.

**GRAVITY ROOF VENTILATOR SCHEDULE**

Table with columns for MARK, TYPE, MANUFACTURER / MODEL, AIR FLOW, APD, VENT. SIZE, THROAT SIZE, MAX HEIGHT, DAMPER TYPE, and NOTES.

NOTES:

- 1. REFER TO SECTION 233723 FOR ADDITIONAL REQUIREMENTS.
- 2. PROVIDE FACTORY-FABRICATED ROOF CURB. COORDINATE EXACT LOCATION AND SIZE OF EXISTING ROOF CURBS PRIOR TO ORDERING. MATCH EXISTING CURB SIZE OR PROVIDE CURB ADAPTER.

**THIRD FLOOR PACKAGE TERMINAL HEAT PUMP SCHEDULE**

Table with columns for MARK, MANUFACTURER / MODEL, REFRIG. TYPE, SUPPLY AIR FAN, COOLING COIL, HEATING COIL, HEATING COIL, DIMENSIONS AND WEIGHT, and NOTES.

NOTES:


- 1. PROVIDE UNIT BY ONE OF THE FOLLOWING MANUFACTURERS: FRIEDRICH OR AMANA.
- 2. PROVIDE MANUFACTURER UNIT SUBBASE WITH INTEGRAL MOTOR-RATED DISCONNECT SWITCH.
- 3. PROVIDE WITH MANUFACTURER WALL SLEEVE. COORDINATE WALL SLEEVE WITH WALL THICKNESS EAST EACH LOCATION. WALL THICKNESS VARIES.
- 4. PROVIDE WALL-MOUNTED, WIRED, NON-PROGRAMMABLE THERMOSTAT. WIRELESS THERMOSTATS ARE NOT ACCEPTABLE.
- 5. PROVIDE ARCHITECTURAL EXTERIOR GRILLE. COORDINATE COLOR WITH OWNER.
- 6. PROVIDE 2 EXTRA FRONT-END AIR FILTERS FOR EACH UNIT. DELIVER TO OWNER PRIOR TO PROJECT CLOSEOUT.



Dewberry Engineers Inc. 2610 Wycliff Road Suite 410 Raleigh, NC 27607-3073 919.851.9939 NC License No. F-0929



CAMPBELL UNIVERSITY POWELL HALL HVAC AND PLUMBING RENOVATION 84 DAY DORM ROAD BUJES CREEK, NC 27506 CONSTRUCTION DOCUMENTS



KEY PLAN

SCALE

Table for REVISIONS with columns for NO., DESCRIPTION, and DATE.

1 DOAS RELOCATION 6/11/26  
NO. DESCRIPTION DATE

DRAWN BY: CDB  
APPROVED BY: KRC  
CHECKED BY: WH  
DATE: 05/20/2026

**SCHEDULES**

PROJECT NO. 50193045

**M-601**

SHEET NO.

6/11/2026 10:12:02 AM P:\0193045\CAD\MCHANICAL\0193045 M-601 SCHEDULES.DWG

6/11/2026 10:12:57 AM P:\0193045\CAD\MCHANICAL\0193045 M-602 SCHEDULES.DWG

F  
E  
D  
C  
B  
A

### FAN SCHEDULE

MARK	TYPE	MANUFACTURER / MODEL	AIR FLOW (CFM)	ESP (IN WG)	EC MOTOR (Y or N)	DRIVE TYPE	SPEED (RPM)	BRAKE MOTOR (HP)	NOMINAL MOTOR (HP)	MAX SOUND (SONES)	DAMPER TYPE	VOLTAGE/ PHASE	STARTER/ DSCNCT MEANS	NOTES
EF-1-01	CEILING CABINET	GREENHECK / SP-LP0511L	50	0.40	YES	DIRECT	720	0.01	0.29 (AMPS)	1.4	BACKDRAFT	120/1	MRS	1,2,3,4
EF-1-02	CEILING CABINET	GREENHECK / SP-LP0511L	50	0.40	YES	DIRECT	720	0.01	0.29 (AMPS)	1.4	BACKDRAFT	120/1	MRS	1,2,3,4
EF-1-03	CEILING CABINET	GREENHECK / SP-LP0511L	50	0.40	YES	DIRECT	720	0.01	0.29 (AMPS)	1.4	BACKDRAFT	120/1	MRS	1,2,3,4
EF-1-04	CEILING CABINET	GREENHECK / SP-LP0511L	50	0.40	YES	DIRECT	720	0.01	0.29 (AMPS)	1.4	BACKDRAFT	120/1	MRS	1,2,3,4
EF-1-05	CEILING CABINET	GREENHECK / SP-LP0511L	50	0.25	YES	DIRECT	720	0.01	0.29 (AMPS)	1.4	BACKDRAFT	120/1	MRS	1,2,3,4
EF-2-01	CEILING CABINET	GREENHECK / SP-LP0511L	50	0.40	YES	DIRECT	720	0.01	0.29 (AMPS)	1.4	BACKDRAFT	120/1	MRS	1,2,3,4
EF-2-02	CEILING CABINET	GREENHECK / SP-LP0511L	50	0.40	YES	DIRECT	720	0.01	0.29 (AMPS)	1.4	BACKDRAFT	120/1	MRS	1,2,3,4
EF-2-03	CEILING CABINET	GREENHECK / SP-LP0511L	50	0.40	YES	DIRECT	720	0.01	0.29 (AMPS)	1.4	BACKDRAFT	120/1	MRS	1,2,3,4
EF-2-04	CEILING CABINET	GREENHECK / SP-LP0511L	50	0.40	YES	DIRECT	720	0.01	0.29 (AMPS)	1.4	BACKDRAFT	120/1	MRS	1,2,3,4
EF-2-05	CEILING CABINET	GREENHECK / SP-LP0511L	50	0.40	YES	DIRECT	720	0.01	0.29 (AMPS)	1.4	BACKDRAFT	120/1	MRS	1,2,3,4
EF-2-06	CEILING CABINET	GREENHECK / SP-LP0511L	50	0.40	YES	DIRECT	720	0.01	0.29 (AMPS)	1.4	BACKDRAFT	120/1	MRS	1,2,3,4
EF-3-01	CEILING CABINET	GREENHECK / SP-LP0511L	50	0.40	YES	DIRECT	720	0.01	0.29 (AMPS)	1.4	BACKDRAFT	120/1	MRS	1,2,3,4
EF-3-02	CEILING CABINET	GREENHECK / SP-LP0511L	50	0.40	YES	DIRECT	720	0.01	0.29 (AMPS)	1.4	BACKDRAFT	120/1	MRS	1,2,3,4
EF-3-03	CEILING CABINET	GREENHECK / SP-LP0511L	50	0.40	YES	DIRECT	720	0.01	0.29 (AMPS)	1.4	BACKDRAFT	120/1	MRS	1,2,3,4
EF-3-04	CEILING CABINET	GREENHECK / SP-LP0511L	50	0.40	YES	DIRECT	720	0.01	0.29 (AMPS)	1.4	BACKDRAFT	120/1	MRS	1,2,3,4
EF-3-05	CEILING CABINET	GREENHECK / SP-LP0511L	50	0.40	YES	DIRECT	720	0.01	0.29 (AMPS)	1.4	BACKDRAFT	120/1	MRS	1,2,3,4
EF-3-06	CEILING CABINET	GREENHECK / SP-LP0511L	50	0.40	YES	DIRECT	720	0.01	0.29 (AMPS)	1.4	BACKDRAFT	120/1	MRS	1,2,3,4

#### NOTES:

- REFER TO SECTION 233400 FOR ADDITIONAL REQUIREMENTS.
- PROVIDE STARTING AND DISCONNECTING MEANS AS SCHEDULED. (MRS = MOTOR RATED SWITCH; MS/D = COMBINATION MOTOR-STARTER AND DISCONNECT; VFD = VARIABLE FREQUENCY DRIVE; AND DISC = DISCONNECT)
- PROVIDE CEILING CASSETTE FAN WITH INTEGRAL LIGHT.
- BATHROOM EXHAUST FAN OPERATION SHALL BE TIED TO BATHROOM LIGHT SWITCH. WHEN LIGHT TURNS ON, FAN SHALL TURN ON.

### AIR DISTRIBUTION SCHEDULE

MARK	SERVICE	TYPE	MANUFACTURER / SERIES	MATERIAL	COLOR	PATTERN	MAX AIR FLOW (CFM)	FACE SIZE (IN x IN)	NECK SIZE (IN x IN)	APD (IN WG)	MAX SOUND (NC)	NOTES
S1	SUPPLY	STANDARD BLADE GRILLE	TITUS 300	ALUMINUM	WHITE	90 DEG.	115	8 x 8	6 x 6	0.05	20	1,2,3,4
S2	SUPPLY	STANDARD BLADE GRILLE	TITUS 300	ALUMINUM	WHITE	90 DEG.	200	12 x 8	10 x 6	0.05	20	1,2,3,4
S3	SUPPLY	SQUARE LOUVER FACE	TITUS TMSA	ALUMINUM	WHITE	360-DEG.	100	12 x 12	6	0.1	20	1,2,3,4
R1	RETURN	STANDARD BLADE GRILLE	TITUS 350	ALUMINUM	WHITE	N/A	600	20 X 10	18 X 8	0.1	30	1,2,3,4
R2	RETURN	SQUARE PERFORATED FACE	TITUS PAR	ALUMINUM	WHITE	N/A	130	12 x 12	6	0.1	20	1,2,3,4
EX		EXISTING DIFFUSER BALANCE TO AIRFLOW INDICATED.										

#### NOTES:

- REFER TO SECTION 233713 FOR ADDITIONAL REQUIREMENTS.
- SOUND LEVELS SHALL BE BASED ON ASHRAE 70.
- VERIFY MOUNTING FRAME STYLE WITH ARCHITECTURAL REFLECTED CEILING PLANS, FINISH SCHEDULES AND EXISTING CEILINGS.
- DUCT BRANCH FROM MAIN TAKEOFF TO AIR INLET / OUTLET SHALL MATCH SCHEDULED NECK SIZE UNLESS OTHERWISE NOTED.

### UNIT HEATER SCHEDULE

MARK	TYPE	MANUFACTURER / MODEL	FAN			AIR			ELECTRIC			NOTES
			AIR FLOW (CFM)	MOTOR (HP)	VOLTAGE/ PHASE	EAT (F)	LAT (F)	MIN. CAP. (KW)	DESIGN (KW)	VOLTAGE/ PHASE		
UH-1	HORIZ. EXPOSED CABINET HEATER	TRANE / UHWA-03	200	0.008	208/3	60	100	2.5	3.0	208/3	1,2,3,4,5,6	
UH-2	HORIZ. EXPOSED CABINET HEATER	TRANE / UHWA-03	200	0.008	208/3	60	100	2.5	3.0	208/3	1,2,3,4,5,6	
UH-3	HORIZ. EXPOSED CABINET HEATER	TRANE / UHWA-03	200	0.008	208/3	60	100	2.5	3.0	208/3	1,2,3,4,5,6	
UH-4	HORIZ. EXPOSED CABINET HEATER	TRANE / UHWA-03	200	0.008	208/3	60	100	2.5	3.0	208/3	1,2,3,4,5,6	
UH-5	HORIZ. EXPOSED CABINET HEATER	TRANE / UHWA-03	200	0.008	208/3	60	100	2.5	3.0	208/3	1,2,3,4,5,6	
UH-6	HORIZ. EXPOSED CABINET HEATER	TRANE / UHWA-03	200	0.008	208/3	60	100	2.5	3.0	208/3	1,2,3,4,5,6	
UH-7	HORIZ. EXPOSED CABINET HEATER	TRANE / UHWA-03	200	0.008	208/3	60	100	2.5	3.0	208/3	1,2,3,4,5,6	

#### NOTES:

- REFER TO SECTION 238239 FOR ADDITIONAL REQUIREMENTS.
- PROVIDE MOTOR-RATED DISCONNECT SWITCH.
- PROVIDE FACTORY-FABRICATED WALL SUPPORT AND EXTENSION SLEEVE FOR SURFACE-MOUNTING. MOUNT AT 12" AFF TO BOTTOM OF HEATER UNLESS OTHERWISE NOTED ON PLANS.
- PROVIDE WITH INTEGRAL THERMOSTAT SET TO 65°F.
- PROVIDE SINGLE-STEP CONTROLLER FOR ELECTRIC COILS. COIL CAPACITIES SHALL BE NO LESS THAN MINIMUM AND NO MORE THAN THE ELECTRICAL DESIGN BASIS SCHEDULED.
- PROVIDE TAMPER-RESISTANT THERMOSTAT COVER PLATE.



Dewberry Engineers Inc.  
2610 Wycliff Road  
Suite 410  
Raleigh, NC 27607-3073  
919.851.9939  
NC License No. F-0929



CAMPBELL UNIVERSITY  
 POWELL HALL  
 HVAC AND PLUMBING RENOVATION  
 84 DAY DORM ROAD  
 BUJES CREEK, NC 27506  
 CONSTRUCTION DOCUMENTS

#### SEAL



#### KEY PLAN

#### SCALE

#### REVISIONS

NO.	DESCRIPTION	DATE
1	DOAS RELOCATION	6/11/26

DRAWN BY: CDB  
 APPROVED BY: KRC  
 CHECKED BY: WH  
 DATE: 05/20/2026

#### TITLE

# SCHEDULES

PROJECT NO. 50193045

# M-602

SHEET NO.

