2400 Weston Parkway
Cary, NC 27513
www.bobbitt.com

Angier and Black River Fire Station #2 (25-0006)
Butler Coordination

02 November 2026

Summary:

STRUCTURAL

1. S1 – STRUCTURAL PLANS
    a. **REVISE** portal frames to be flush portal frames at grids A6 & A7, F6 & F7 as well as B1 & B2, E1 & E2.

2. S2 – STRUCTURAL DETAILS
    a. **ADD** a note alluding to the final Butler drawings and reactions and explaining that the foundation design is based on the loading conditions provided by Butler.

PREPARED BY:

Madeline Morrissette
Project Designer II

Attachments:
Structural Drawings (2 Sheet)