



Permit Reviews

Harnett County

Permit Number: **BCOM2607-0008**

Description: **110' x 70' Angier & Black River Fire Station #2**

Applied: **7/21/2026**

Approved:

Site Address: **783 MANGUM RD**

Issued:

Finalized:

City, State Zip Code: **ANGIER, NC 27501**

Status: **RECEIVED**

Applicant: **Bobbitt Construction Inc.**

Parent Permit:

Owner: **ANGIER AND BLACK RIVER FIRE DEPT INC**

Parent Project:

Contractor: **Bobbitt Construction Inc.**

Details:

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: AUTO						
7/21/2026	7/21/2026		COMMERCIAL INTAKE	CP Bucket	DISAPPROVED	SITE2606-0002
Notes:						
7/21/2026	7/27/2026	8/4/2026	COMMERCIAL BUILDING REVIEW	Brad Sutton	DISAPPROVED	
Notes: 1. Specify sprinkler system type to be used throughout building. 2. Provide comcheck with plans. Verify comcheck requirements match architectural requirements for building. 3. 2018 NCBC requires emergency escape and rescue openings for R-2 Sleeping units. 2 of these units do not have EERO. For 1030.1 Ex.2 to apply, explain why corridor is not fire separated? If corridor is updated/separated, provide updated door schedule and mechanical fire damper locations. 3. Provide whether generator/ATS will be wired as separately derived system.						
7/21/2026	8/3/2026	8/4/2026	FIRE MARSHAL	Leslie Jackson	APPROVED	See Attached Letter/Notes
Notes: Review notes (LJ)						
7/27/2026			COMMERCIAL BUILDING REVIEW	Building Bucket		
Notes:						