HARNETT COUNTY

CHILDCARE CENTER APPLICATION

INSTRUCTIONS:

-Complete application pages 1-2

-Return application pages 1-2 ***and*** *required supporting documentation to:*

Harnett County Central Permitting

c/o Michelle Myatt (910-814-6421)

420 McKinney Pkwy.

Lillington, NC 27546

Reviewed for Fire Code Compliance

Harnett COUNTY NORTH CAROLINA

Leslie Jackson

10/06/2026 3:00:04 PM

FACILITY INFORMATION

Facility Name: Little Dreamers Family Empowerment Center

Facility Location Address: 2277 NC. Hwy 24, Cameron, NC 28326

-Construction type:

___New

___Remodel existing structure

✓Change of ownership

-Ages of children served: ____Infant ____1 ✓2 ✓3 ✓4 ✓5 ✓School age

-Meals:

✓Students bring own lunch

___Center kitchen on site

___Catered meals

___Other

-Water Supply:

✓Municipal/Public

___Well

-Wastewater Disposal:

___Municipal/Public

✓On-site septic system

Reviewed for Fire Code Compliance

Harnett COUNTY NORTH CAROLINA

Leslie Jackson

10/06/2026 2:59:39 PM

OWNER INFORMATION

Owner of facility: Steve McNiell

Contact person: Anisa Poole

Phone Number: 910-987-9850

Email Address: anisa@littledreamersfcc.com

Required Supporting Documentation:

-Proposed foodservice menu – N/A

-Floor plans drawn to scale including storage areas, laundry, kitchen/dining areas (including equipment) and canwash/mopsink. Age of children served should be indicated for each classroom. Please indicate locations of diaper changing stations, handsinks and food prep areas in each classroom.


Signature of Applicant: Anisa Poole

Printed Name of Applicant: Anisa Poole

Date: 9/9/26

LDFEC Building Layout

Reviewed for Fire Code Compliance
Harnett County NORTH CAROLINA
Leslie Jackson
10/06/2026 3:00:26 PM



KEY	
	Evacuation Route 1
	Evacuation Route 2
HS	Horn Strobe
	Breaker Box
PS	Pull Station
	Strobe
FE	Smoke Detector
	Fire Extinguisher


Rooms used for children must have an emergency escape and rescue opening with a net clear opening of 5.7 sqft. The bottom of the opening shall not be greater than 32" measured from the floor for classrooms serving grade 5 and younger.
Rooms serving children 2.5 years and younger must have direct exits to the exterior of the building.

NOTICE TO CONTRACTOR
All construction must comply with current NC Building Codes and is subject to field inspections and verification.

Reviewed for Code Compliance

10/05/2026

Harnett COUNTY NORTH CAROLINA


LDFEC Building Layout
Playground
(53X53)
Front
Storage
(25X12)
2
Teacher
lounge(25X12)
1
Two,s
(26X26)
3
Bathroom
Bathroom
C
EC
Bathroom
Preschool 1
(25X26)
5
School Age
(25X25)
7
Back
Playground
(92X63)
Meeting
Spot
Mechanical
Parking (1 HC & 5 Others)
Front Porch &
Ramp
HS
PS
FE
(7X7)
Office
(26X26)
4
School agers
(25X24)
Bathroom
Bathroom
Bathroom
6
Preschool 2
(25X26)
8
Kitchen
(25X12)
9
Cafeteria
(25X12)
Parking Area (21 spaces)
Parking Area (2 Handicap + 9 Others)
Parking Area (6 Others)
KEY
Evacuation Route 1
Evacuation Route 2
Horn Strobe
Breaker Box
Pull Station
Strobe
Smoke Detector
Fire Extinguisher

Little Dreamers Family Empowerment Center

Exterior Drawing

