Harnett
COUNTY
NORTH CAROLINA

Department of Public Health

www.harnett.org

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550
fax: 910-893-9429

October 12, 2026

Campbell University
c/o Meghan Cusack
445 Leslie Campbell Ave.
Lillington, NC 27546

RE: Shake Smart

To whom it may concern,

A plan review application was received by this office concerning the above referenced facility. The application is approved with the following comments:

-No rinse sink is available in the blender area. Per phone conversation 10/12/26, you indicated the facility would maintain 25+ blender pitchers and these pitchers will be taken individually to the three compartment sink for proper washing, rinsing and sanitizing.

Any item not shown on the plans or referenced above will be required to comply with 15A NCAC 18A .2600, **"Rules Governing the Sanitation of Food Service Establishments" and the 2017 NC Food Code.** This review does not cover any other aspects of construction regulated by other jurisdictions.

If you require further assistance, please call 910-893-7547.

Sincerely,

C. Pierce, REHS

Cindy Pierce, REHS
Environmental Health Section
Harnett County Health Department