Permit Reviews
Harnett County

Permit Number: BCOM2610-0007

Description: **Maynard Crossing Apts Bldg 100 (2BR/6 units, 1BR/6 units)**

Applied: **10/14/2026**
Approved:
Issued:
Finaled:
Site Address: **100 MAYNARD LAKE RD**
City, State Zip Code: **ERWIN, NC 28339**
Status: **RECEIVED**
Applicant: **MILLS CONSTRUCTION CO OF SC**
Parent Permit:
Owner: **MAYNARD CROSSING APARTMENTS LLC**
Parent Project:
Contractor: **MILLS CONSTRUCTION CO OF SC**

Details:

LIST OF REVIEWS						
SENT DATE	**RETURNED DATE**	**DUE DATE**	**TYPE**	**CONTACT**	**STATUS**	**REMARKS**
Review Group: AUTO						
10/14/2026	10/14/2026		COMMERCIAL INTAKE	CP Bucket	APPROVED	
Notes:						
10/14/2026	10/22/2026	10/28/2026	COMMERCIAL BUILDING REVIEW	Steven Gazlay	DISAPPROVED	Harnett County is in climate zone 4A. Update insulation spec
Notes: Harnett County is in climate zone 4A. Update insulation specifications.						
10/14/2026	10/26/2026	10/28/2026	FIRE MARSHAL	Roger Sullivan	APPROVED	see attached letter
Notes: See attached letter.						
10/22/2026			COMMERCIAL BUILDING REVIEW	Building Bucket		
Notes:						