



**Harnett County**  
108 EAST FRONT STREET  
LILLINGTON, NC 27546  
Phone:  
Fax:

8/15/2018

**SUBJECT: BRES1807-0021**  
**BUILDING RESIDENTIAL**

To: LUMBER RIVER QUALITY BUILDERS LLC

Here are the results of all Inspections located at **92 W WASHINGTON ST:**

Inspection Type: FINAL  
Scheduled Date/Time: 7/31/2018  
Completed Date/Time: 7/31/2018  
Inspector: Deen Taylor  
Result: FAIL  
Remarks:  
Notes: Repair exterior duct and seal at foundation wall

Inspection Type: FINAL  
Scheduled Date/Time: 8/1/2018  
Completed Date/Time: 8/1/2018  
Inspector: Deen Taylor  
Result: PASS  
Remarks:  
Notes: