



Permit Inspections Harnett County

Permit Number: BRES1807-0021

Description: **INTERIOR RENOVATIONS**

Applied: **7/18/2018**

Approved:

Site Address: **92 W WASHINGTON ST**

Issued:

Finalized: **8/1/2018**

City, State Zip Code: **COATS, NC 27521**

Status: **FINALED**

Applicant: **LUMBER RIVER QUALITY BUILDERS LLC**

Parent Permit:

Owner: **THOMAS MICHAEL H**

Parent Project:

Contractor: **LUMBER RIVER QUALITY BUILDERS LLC**

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
	7/31/2018	7/31/2018	FINAL	Deen Taylor	FAIL	

Notes:

Repair exterior duct and seal at foundation wall

	8/1/2018	8/1/2018	FINAL	Deen Taylor	PASS	
--	----------	----------	-------	-------------	------	--

Notes:

