

HTE #: BRES1807-0025

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: Hunt Construction Phone #: 919.539.3775

Address: 260 Old Cabin Ct. Angier, NC 27501

Name of Mobile Home Park or S/D: Atkins Place Lot 2

Name of Owner (if different): Jane Rode

Address of Owner (if different): 245 Atkins Place Cr. Fuquay-Varina, NC 27526

Property Location (State Road name and #): 245 Atkins Place Cr.

Purpose of Inspection: Deck extension (9'x22') - Revised to meet septic setbacks. 9ft deep deck with foundation pillars no more than 7ft off SFD to meet septic setbacks.

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM


Signature of Environmental Health Specialist

08/13/2018
Date