

03-5-8338

OPERATIONS PERMIT

Name: (owner) ATKINS PLACE LLC New Installation Septic Tank
 Property Location: SR# 1448 ATKINS PLACE RD Repairs Nitrification Line
 Subdivision ATKINS PLACE Lot # 2
 TAX ID# _____ Quadrant # _____
 Contractor: STANCIL BUILDERS Registration # _____


Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: 100 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other POLYSTYRENE AGG TRENCH
 Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
 Subsurface Drainage Field No. of 3 exact length 70 width of 3 depth of 30-36 in.
 ditches of each ditch ft. ditches ft. ditches in.
 French Drain: _____ Linear feet

Date: 4/2/04
 Inspected by: [Signature]
 Environmental Health Specialist

PERMIT NO. 21023



HTE 03-5-8338

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) ATKINS PLACE LLC New Installation Septic Tank
Property Location: SR# 1448 ATKINS RD Repairs Nitrification Line

Subdivision ATKINS PLACE Lot # 2

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: .35 AC

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 100 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other 25% REDUCTION

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 70 ft. width of ditches 3 ft. depth of ditches 30-18 in. ^{MAX!}


French Drain Required: _____ Linear feet

Date: 12/29/03

This permit is subject to revocation if site plans or intended use change.

Signed: [Signature] RS (OLIVER TOLKPOFF)
113' Environmental Health Specialist

- * MAINTAIN ALL SETBACKS
- * USE STEPDOWN WHERE NEEDED
- * CALL WITH ANY QUESTIONS PRIOR TO INSTALLATION



DRAWING NTS