

CERTIFICATE OF COMPLETION / OPERATIONAL PERMIT

Name: (owner) Kil Arnold Corp New Installation Septic Tank
Property Location: SR# Hwy 24 Repairs Nitrification Line
Subdivision Heritage Village Lot # B 18
TAX ID# _____ Quadrant # _____
Contractor: W. Shaepc Registration # _____

Basement with Plumbing: Garage:
Water Supply: Well Public Community
Distance From Well: N/A ft.

Following are the specifications for the sewage disposal system on above captioned property.


Type of system: Conventional Other Pump Conventional
Size of tank: Septic Tank: 1000 gallons Pump Tank: 1000 gallons
Subsurface Drainage Field No. of exact length width of depth of
ditches 1 of each ditch 200 ft. ditches 3 ft. ditches 18 in.
French Drain: 110 Linear feet

Date: 9-19-94

PERMIT NO. 09261

Inspected by: Joe WARS

Environmental Health Specialist



IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) KILARNOLD Corp New Installation Septic Tank
Property Location: SR# HWY 24 Repairs Nitrification Line

Georgia Way

Subdivision Heritage Way Lot # B-18

Tax ID# _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 74,862.83 sq. ft

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: N/A ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other Pump SYSTEM

Size of tank: Septic Tank: 1000 gallons Pump Tank: 1000 gallons

Subsurface Drainage Field No. of ditches 2 exact length of each ditch 120 ft. width of ditches 3 ft. depth of ditches 18-24 in.

French Drain required: _____ Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 7-7-94

Signed: Joe West RS

Environmental Health Specialist

VOID AFTER 5 YEARS

